

BAGDARIN, Russian FederationWMO: **305540**Lat: **54.442N**Lon: **113.581E**Elev: **2961**StdP: **13.19**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-43.3	-39.3	-47.3	0.4	-42.7	-43.6	0.5	-39.0	11.7	0.0	9.7	-1.1	0.0	0	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.2	80.9	61.5	77.7	60.1	74.6	58.8	64.6	74.9	62.7	73.0	60.9	71.0	5.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	89.7	67.8	59.0	83.2	66.3	57.0	77.4	65.2	31.4	75.1	29.9	72.7	28.5	71.1	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.7	9.8	DB	-47.7	86.4	4.3	3.8	-50.8	89.1	-53.3	91.3	-55.7	93.5	-58.9	96.2	(4)
(5)			WB	-47.5	68.3	3.7	2.8	-50.2	70.3	-52.4	71.9	-54.5	73.5	-57.2	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	-17.7	-8.1	7.3	27.0	42.1	55.1	60.5	55.5	41.8	23.9	-0.3	-15.6
	DBStd	29.03	9.51	9.59	11.93	9.15	7.18	6.36	4.79	5.55	7.61	9.80	12.37	10.30
	HDD50	10656	2098	1626	1324	690	259	25	1	17	264	808	1509	2035
	HDD65	15420	2563	2046	1789	1140	709	298	151	295	697	1273	1959	2500
	CDD50	726	0	0	0	0	15	179	327	188	17	0	0	0
	CDD65	15	0	0	0	0	0	2	12	1	0	0	0	0
	CDH74	785	0	0	0	0	13	229	427	110	6	0	0	0
	CDH80	130	0	0	0	0	1	33	84	12	0	0	0	0
Wind	WSAvg	2.9	1.2	1.9	3.4	4.8	5.2	3.6	3.1	2.8	3.3	2.9	1.8	1.0
Precipitation	PrecAvg	15.6	0.1	0.1	0.1	0.6	1.3	3.1	4.1	3.9	1.5	0.4	0.3	0.1
	PrecMax	22.1	0.3	0.3	0.4	1.9	3.5	7.6	7.9	8.1	4.0	1.2	1.2	0.5
	PrecMin	7.6	0.0	0.0	0.0	0.0	0.1	0.3	1.2	0.6	0.2	0.0	0.0	0.0
	PrecStd	3.5	0.1	0.1	0.1	0.5	1.0	1.9	1.9	0.8	0.3	0.2	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.8	27.9	46.6	61.3	75.9	84.0	86.3	81.2	73.6	56.3	38.7	18.7
		MCWB	11.4	21.9	35.1	43.7	54.1	61.6	64.7	61.2	54.2	43.1	31.9	15.3
	2%	DB	7.1	21.1	39.7	54.0	69.9	79.6	82.3	77.1	67.6	49.4	29.8	11.4
		MCWB	4.9	16.8	30.7	39.8	51.0	59.6	62.7	60.0	51.9	38.6	24.9	9.1
	5%	DB	2.2	15.6	34.0	49.3	65.3	76.3	78.8	73.4	62.5	44.6	23.9	5.3
		MCWB	0.7	12.3	26.5	37.1	48.2	58.0	61.8	58.7	49.4	35.5	20.6	3.7
	10%	DB	-2.1	10.8	28.9	44.7	60.7	72.9	75.5	69.9	57.9	40.0	19.3	-0.2
		MCWB	-3.2	8.4	23.2	34.3	45.9	56.5	60.7	57.7	47.4	32.5	16.7	-1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	22.0	35.4	44.4	54.8	65.9	67.9	65.0	57.6	43.4	31.8	15.6
		MCDB	14.7	27.3	45.9	60.0	73.5	78.8	78.8	72.4	70.1	55.3	38.5	18.5
	2%	WB	4.9	16.8	30.7	40.4	51.8	62.4	65.5	62.7	54.0	39.1	25.1	9.2
		MCDB	6.9	20.9	39.3	52.8	67.6	74.0	77.4	72.9	63.0	48.7	29.0	11.4
	5%	WB	0.8	12.4	26.7	37.6	49.1	60.2	63.7	60.8	51.1	36.0	20.9	3.9
		MCDB	2.1	15.5	33.5	48.5	63.4	71.1	74.1	70.1	60.5	44.0	23.6	5.2
	10%	WB	-3.2	8.3	23.3	34.8	46.6	58.2	62.1	59.0	48.2	32.8	16.6	-1.1
		MCDB	-2.2	10.8	28.9	44.2	59.6	69.7	72.1	67.2	57.4	39.2	19.2	-0.2
Mean Daily Temperature Range	5% DB	MDBR	25.4	35.4	34.8	27.4	27.0	28.4	26.2	25.7	26.2	26.3	26.2	23.0
		MCDBR	27.7	38.1	35.8	34.6	38.6	37.5	34.7	33.8	34.6	30.7	28.0	25.8
		MCWBR	26.0	33.8	27.3	21.6	21.2	19.2	17.7	17.9	19.5	20.3	23.3	23.6
	5% WB	MCD BR	27.5	37.5	34.9	33.2	35.5	29.9	27.9	28.7	30.1	29.4	27.1	25.5
		MCWBR	25.8	33.3	26.6	21.0	20.0	16.6	15.8	16.5	17.5	19.7	22.6	23.4
Clear-Sky Solar Irradiance	taub	0.235	0.265	0.294	0.371	0.459	0.461	0.405	0.375	0.323	0.280	0.253	0.230	
	taud	2.177	2.159	2.166	2.109	1.960	2.072	2.306	2.371	2.463	2.448	2.249	2.131	
	Ebn at Noon	232	262	279	269	249	251	265	267	270	259	221	203	
	Edh at Noon	19	28	35	43	54	49	38	33	27	21	18	16	
All-Sky Solar Radiation	RadAvg	329	652	1161	1632	1755	1820	1686	1430	1077	706	382	244	
	RadStd	15	19	32	56	111	117	153	102	78	39	20	13	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-5	(47)

Nomenclature: See separate page