

YEROFEY PAVLOVICH, Russian Federation

WMO: 306830

Lat: 53.967N

Lon: 121.933E

Elev: 522

StdP: 95.21

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -37.4	(c) -35.4	(d) -39.8	(e) 0.1	(f) -37.0	(g) -37.9	(h) 0.1	(i) -35.0	(j) 6.9	(k) -20.1	(l) 5.7	(m) -18.9	(n) 0.3	(o) 320	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	28.8	18.5	27.0	17.9	25.3	17.2	20.5	25.6	19.5	24.3	18.5	23.1	2.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.6	22.8	17.9	13.7	21.5	16.9	12.8	20.9	62.0	25.2	58.2	24.2	54.9	23.1	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.2	(b) 5.3	(c) 4.3	(e) -39.9	(f) 31.8	(g) 2.1	(h) 1.8	(i) -41.4	(j) 33.1	(k) -42.7	(l) 34.1	(m) -43.9	(n) 35.1	(o) -45.5	(p) 36.4		
(a) 6.2	(b) 5.3	(c) 4.3	(e) -39.9	(f) 21.8	(g) 2.1	(h) 1.1	(i) -41.4	(j) 22.7	(k) -42.7	(l) 23.3	(m) -43.9	(n) 24.0	(o) -45.4	(p) 24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.6	-24.5	-20.1	-11.2	0.0	8.4	16.2	18.5	15.5	8.2	-2.3	-16.4	-24.4		
	DBStd	16.26	4.51	4.89	6.34	4.74	3.96	3.46	2.68	3.35	4.11	5.33	6.68	4.84		
	HDD10.0	5278	1071	843	658	302	77	2	0	3	81	382	793	1068		
	HDD18.3	7700	1329	1077	916	551	307	80	31	98	303	640	1043	1326		
	CDD10.0	683	0	0	0	1	28	189	264	173	28	0	0	0		
	CDD18.3	63	0	0	0	0	1	16	37	10	0	0	0	0		
	CDH23.3	863	0	0	0	2	18	287	389	161	8	0	0	0		
	CDH26.7	184	0	0	0	0	2	68	89	23	1	0	0	0		
	WSAvg	1.3	0.9	1.0	1.4	1.8	1.9	1.5	1.3	1.2	1.4	1.2	0.9	0.8		
	PrecAvg	419	3	5	10	22	33	67	105	95	49	18	12	6		
(15) Precipitation	PrecMax	605	12	17	40	70	77	178	225	247	176	49	31	15		
	PrecMin	221	0	0	0	2	2	7	47	16	2	1	1	0		
	PrecStd	95	3	5	8	16	21	45	44	46	36	12	7	4		
	PrecStd	95	3	5	8	16	21	45	44	46	36	12	7	4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.9	-2.5	8.3	19.3	25.7	31.2	31.4	29.0	24.1	14.9	2.7	-8.6		
		MCWB	-11.6	-5.5	2.2	8.2	13.4	18.9	19.0	19.0	15.2	7.6	-0.9	-9.7		
	2%	DB	-12.7	-6.2	4.6	14.6	22.4	28.6	29.1	27.0	21.1	11.3	-1.4	-11.5		
		MCWB	-13.9	-8.4	-0.3	6.4	11.5	17.9	19.0	18.2	13.9	5.5	-3.6	-12.6		
	5%	DB	-14.8	-8.8	1.7	11.1	20.0	26.5	27.2	25.1	18.7	8.4	-3.9	-14.4		
		MCWB	-15.7	-10.4	-2.1	4.3	10.5	16.7	18.6	17.4	12.1	3.7	-5.2	-15.3		
	10%	DB	-16.9	-11.2	-0.9	8.4	17.6	24.6	25.5	23.1	16.3	6.0	-6.3	-16.8		
		MCWB	-17.6	-12.5	-3.9	2.6	9.3	16.1	18.1	16.8	11.0	1.9	-7.6	-17.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.6	-5.5	2.5	9.7	14.5	21.6	21.8	21.0	16.7	7.9	-0.7	-9.4		
		MCDB	-10.2	-2.7	8.1	18.4	22.8	27.3	26.8	25.4	22.5	13.8	2.3	-8.5		
	2%	WB	-13.9	-8.3	-0.2	6.7	12.7	19.4	20.9	19.6	14.8	5.9	-3.3	-12.6		
		MCDB	-12.7	-6.3	4.3	14.2	20.3	25.9	26.0	24.5	19.1	10.5	-1.8	-11.5		
	5%	WB	-15.7	-10.3	-2.0	4.7	11.3	18.1	20.0	18.6	13.4	4.1	-5.3	-15.2		
		MCDB	-14.8	-8.7	1.4	10.4	18.1	24.2	24.7	23.1	17.1	8.0	-3.9	-14.4		
	10%	WB	-17.6	-12.5	-3.8	3.0	9.9	17.0	19.1	17.5	11.9	2.2	-7.6	-17.4		
		MCDB	-16.8	-11.2	-1.0	7.7	16.5	23.0	23.3	21.7	15.5	5.7	-6.3	-16.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	14.8	14.4	12.3	12.8	13.3	11.7	12.3	12.5	11.5	12.0	11.2		
		MCDBR	13.2	16.6	15.5	17.4	18.5	17.4	16.1	16.7	17.0	15.1	13.2	11.4		
		MCWBR	12.1	14.6	11.2	10.4	9.6	8.0	7.5	8.6	9.8	9.9	10.8	10.5		
		MCDBR	13.2	16.4	14.7	16.0	15.6	14.6	12.0	13.1	14.0	14.2	13.0	11.2		
	5% WB	MCWBR	12.1	14.4	10.8	9.8	8.8	7.3	6.5	7.3	8.6	9.5	10.7	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.244	0.273	0.315	0.428	0.514	0.464	0.445	0.402	0.349	0.316	0.272	0.248		
	taud		2.156	2.134	2.087	1.946	1.846	2.104	2.208	2.314	2.412	2.352	2.179	2.080		
	Ebn at Noon		720	816	853	788	738	789	798	815	821	763	667	612		
	Edh at Noon		63	92	122	163	191	149	132	112	89	75	62	56		
(44) All-Sky Solar Radiation	RadAvg		1.19	2.33	4.05	5.34	5.17	5.85	5.17	4.47	3.38	2.21	1.32	0.88		
	RadStd		0.05	0.06	0.14	0.33	0.38	0.46	0.42	0.47	0.27	0.12	0.06	0.04		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page