

DZHALINDA, Russian FederationWMO: **306950**Lat: **53.472N**Lon: **123.907E**Elev: **871**StdP: **14.24**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.3	-34.5	-43.0	0.5	-38.0	-39.2	0.6	-34.0	17.0	-6.9	15.9	-5.7	3.1	320	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	86.6	68.0	82.8	66.9	79.4	65.8	71.5	80.5	69.7	78.5	68.0	76.2	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.8	109.4	75.9	66.9	102.2	73.3	65.1	95.8	71.8	36.1	80.5	34.4	78.6	32.9	76.2	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
16.7	14.9	12.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-41.9	93.1	3.7	3.8	-44.5	95.8	-46.6	98.0	-48.7	100.1	-51.4	102.8
			-42.7	74.4	4.0	2.1	-45.6	75.9	-48.0	77.1	-50.3	78.3	-53.2	79.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	-15.0	-6.2	12.0	34.1	49.3	62.7	67.4	62.5	48.6	29.8	1.9	-14.3	(6)
(7)		DBStd	31.00	8.91	8.70	11.66	8.38	6.86	6.31	5.23	5.92	7.72	9.44	12.47	9.52	(7)
(8)		HDD50	9519	2015	1574	1177	478	94	1	0	2	116	626	1442	1994	(8)
(9)		HDD65	13730	2480	1994	1642	926	487	115	36	116	492	1091	1892	2459	(9)
(10)		CDD50	1464	0	0	0	3	74	382	540	389	75	1	0	0	(10)
(11)		CDD65	197	0	0	0	0	1	46	111	38	1	0	0	0	(11)
(12)		CDH74	2315	0	0	0	3	58	771	1053	408	22	0	0	0	(12)
(13)		CDH80	663	0	0	0	1	9	239	331	82	1	0	0	0	(13)
(14)	Wind	WSAvg	4.5	4.6	4.4	5.1	5.6	5.3	3.8	3.5	3.6	4.3	4.9	4.2	4.7	(14)
(15)	Precipitation	PrecAvg	19.2	0.3	0.2	0.2	0.8	1.9	3.1	4.6	4.0	2.2	1.0	0.6	0.3	(15)
(16)		PrecMax	26.0	0.6	0.6	0.8	2.3	3.7	6.7	8.7	6.4	4.7	3.3	1.3	1.2	(16)
(17)		PrecMin	14.0	0.0	0.0	0.0	0.1	0.4	0.7	0.7	1.8	0.6	0.0	0.0	0.0	(17)
(18)		PrecStd	2.7	0.2	0.1	0.2	0.6	1.0	1.7	2.1	1.3	1.1	0.9	0.4	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	25.9	48.2	69.3	81.3	91.0	92.2	86.4	77.3	61.1	33.6	16.7	(19)
MCWB			9.3	20.8	36.8	47.9	57.9	69.4	69.0	70.8	63.1	48.7	28.6	14.3	(20)	
2%		DB	7.7	19.4	42.0	61.3	74.9	86.2	87.5	81.9	71.7	54.3	29.1	11.0	(21)	
		MCWB	5.9	16.5	32.6	44.5	54.3	66.9	68.1	68.1	59.9	43.2	26.4	9.1	(22)	
5%		DB	3.9	14.8	36.5	55.6	70.7	82.2	83.5	78.5	67.2	48.7	25.0	5.1	(23)	
		MCWB	2.4	12.0	29.1	41.6	52.9	64.9	68.2	66.5	56.8	40.0	22.5	3.6	(24)	
10%		DB	0.0	9.8	32.0	50.7	66.0	78.2	79.8	75.1	63.0	44.3	20.6	-0.3	(25)	
		MCWB	-1.2	7.6	26.7	38.8	50.6	63.2	67.6	64.7	54.3	37.1	18.3	-1.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	21.4	37.4	49.4	60.3	74.0	74.5	73.0	64.8	48.3	29.8	14.4	(27)
MDCB			11.7	25.6	47.8	66.9	75.4	85.0	82.1	82.1	73.8	60.1	31.7	16.5	(28)	
2%		WB	6.0	16.5	32.6	45.1	57.0	69.3	72.3	70.1	61.3	44.0	26.4	9.1	(29)	
		MDCB	7.7	19.2	40.6	59.5	69.2	81.6	80.9	78.5	68.8	52.7	29.2	10.9	(30)	
5%		WB	2.4	11.9	29.6	42.1	54.7	67.0	70.5	68.1	58.9	40.8	22.7	3.6	(31)	
		MDCB	3.8	14.6	35.7	54.5	67.0	78.7	79.0	75.4	64.3	47.7	24.9	5.0	(32)	
10%		WB	-1.2	7.6	26.7	39.4	52.1	64.9	69.0	66.2	56.3	37.4	18.4	-1.3	(33)	
		MDCB	0.0	9.8	32.1	49.7	63.8	75.4	76.9	73.2	61.9	43.9	20.6	-0.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	21.8	28.0	29.2	24.8	26.1	25.9	21.4	22.4	23.8	21.6	21.4	19.1	(35)	
5% DB		MCDBR	22.3	29.9	29.3	33.7	36.1	32.9	30.0	29.1	29.2	28.7	21.8	19.3	(36)	
		MCWBR	20.8	26.6	20.9	19.2	18.1	15.0	13.3	15.5	17.1	18.3	18.6	17.7	(37)	
		MCDBR	22.2	29.5	27.6	31.3	30.3	28.2	22.6	23.6	23.9	27.3	21.7	19.3	(38)	
5% WB		MCWBR	20.7	26.3	19.9	18.2	16.0	14.1	11.7	13.4	14.8	17.7	18.4	17.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.254	0.285	0.338	0.477	0.539	0.496	0.466	0.412	0.366	0.340	0.289	0.260	(40)	
taud		2.136	2.096	2.017	1.824	1.796	2.015	2.162	2.301	2.365	2.271	2.144	2.067	(41)		
Ebn at Noon		226	254	262	235	228	242	248	256	255	232	205	191	(42)		
Edh at Noon		21	31	42	59	64	52	44	36	30	26	21	19	(43)		
(44)	All-Sky Solar Radiation	RadAvg	398	763	1306	1662	1666	1920	1666	1465	1115	722	431	298	(44)	
(45)		RadStd	17	20	50	125	117	172	155	140	91	40	22	16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page