

DZHALINDA, Russian FederationWMO: **306950**Lat: **53.472N**Lon: **123.907E**Elev: **266**StdP: **98.17**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.0	(c) -36.9	(d) -41.7	(e) 0.1	(f) -38.9	(g) -39.6	(h) 0.1	(i) -36.7	(j) 7.6	(k) -21.6	(l) 7.1	(m) -20.9	(n) 1.4	(o) 320	(p) 0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	30.3	20.0	28.2	19.4	26.3	18.8	22.0	27.0	20.9	25.8	20.0	24.5	2.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.6	24.4	19.4	14.6	23.0	18.4	13.7	22.1	66.0	27.0	62.1	25.9	58.8	24.6	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.6	5.4	-41.0	33.9	2.0	2.1	-42.5	35.4	-43.7	36.7	-44.8	37.8	-46.3	39.3		
			-41.5	23.5	2.2	1.2	-43.1	24.4	-44.4	25.1	-45.7	25.7	-47.3	26.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.3	-26.1	-21.2	-11.1	1.2	9.6	17.0	19.7	16.9	9.2	-1.2	-16.7	-25.7
	DBStd	17.22	4.95	4.83	6.48	4.66	3.81	3.50	2.91	3.29	4.29	5.25	6.93	5.29
	HDD10.0	5288	1119	874	654	266	52	1	0	1	64	348	801	1108
	HDD18.3	7628	1378	1108	912	514	271	64	20	64	273	606	1051	1366
	CDD10.0	813	0	0	0	2	41	212	300	216	42	1	0	0
	CDD18.3	109	0	0	0	0	1	26	62	21	1	0	0	0
	CDH23.3	1286	0	0	0	2	32	428	585	227	12	0	0	0
	CDH26.7	368	0	0	0	1	5	133	184	46	1	0	0	0
Wind	WSAvg	2.0	2.0	1.9	2.3	2.5	2.4	1.7	1.6	1.6	1.9	2.2	1.9	2.1
Precipitation	PrecAvg	488	7	5	6	20	48	80	116	102	55	25	15	8
	PrecMax	660	16	14	20	59	94	171	222	163	120	85	34	31
	PrecMin	355	1	0	0	3	11	19	18	46	15	1	1	1
	PrecStd	69	4	3	5	14	25	44	53	32	28	22	9	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-11.2	-3.4	9.0	20.7	27.4	32.8	33.4	30.2	25.2	16.1	0.9	-8.5
		MCWB	-12.6	-6.2	2.7	8.8	14.4	20.8	20.5	21.6	17.3	9.3	-1.9	-9.9
	2%	DB	-13.5	-7.0	5.6	16.3	23.8	30.1	30.8	27.7	22.0	12.4	-1.6	-11.7
		MCWB	-14.5	-8.6	0.4	7.0	12.4	19.4	20.0	20.1	15.5	6.2	-3.1	-12.7
	5%	DB	-15.6	-9.6	2.5	13.1	21.5	27.9	28.6	25.8	19.5	9.3	-3.9	-14.9
		MCWB	-16.4	-11.1	-1.6	5.3	11.6	18.3	20.1	19.2	13.8	4.4	-5.3	-15.8
	10%	DB	-17.8	-12.3	0.0	10.4	18.9	25.7	26.6	23.9	17.2	6.8	-6.3	-17.9
		MCWB	-18.5	-13.6	-3.0	3.8	10.3	17.4	19.8	18.2	12.4	2.9	-7.6	-18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-12.4	-5.9	3.0	9.7	15.7	23.3	23.6	22.8	18.2	9.0	-1.2	-9.8
		MCDB	-11.3	-3.6	8.8	19.4	24.1	29.4	27.8	27.8	23.2	15.6	-0.2	-8.6
	2%	WB	-14.5	-8.6	0.3	7.3	13.9	20.7	22.4	21.2	16.3	6.7	-3.1	-12.7
		MCDB	-13.5	-7.1	4.8	15.3	20.7	27.5	27.1	25.8	20.4	11.5	-1.6	-11.7
	5%	WB	-16.4	-11.2	-1.3	5.6	12.6	19.5	21.4	20.0	14.9	4.9	-5.2	-15.8
		MCDB	-15.7	-9.7	2.1	12.5	19.5	26.0	26.1	24.1	18.0	8.7	-4.0	-15.0
	10%	WB	-18.4	-13.5	-3.0	4.1	11.1	18.3	20.6	19.0	13.5	3.0	-7.6	-18.5
		MCDB	-17.8	-12.4	0.1	9.8	17.7	24.1	25.0	22.9	16.6	6.6	-6.3	-17.9
Mean Daily Temperature Range	5% DB	MDBR	12.1	15.5	16.2	13.8	14.5	14.4	11.9	12.4	13.2	12.0	11.9	10.6
		MCDBR	12.4	16.6	16.3	18.7	20.0	18.3	16.7	16.2	16.2	16.0	12.1	10.7
		MCWBR	11.6	14.8	11.6	10.7	10.1	8.3	7.4	8.6	9.5	10.2	10.4	9.8
	5% WB	MCDBR	12.3	16.4	15.3	17.4	16.8	15.6	12.6	13.1	13.3	15.2	12.1	10.7
		MCWBR	11.5	14.6	11.0	10.1	8.9	7.8	6.5	7.5	8.2	9.9	10.2	9.9
Clear-Sky Solar Irradiance	taub		0.254	0.285	0.338	0.477	0.539	0.496	0.466	0.412	0.366	0.340	0.289	0.260
	taud		2.136	2.096	2.017	1.824	1.796	2.015	2.162	2.301	2.365	2.271	2.144	2.067
	Ebn at Noon		711	801	825	741	718	762	781	807	804	731	645	603
	Edh at Noon		67	97	132	185	201	163	139	114	95	83	66	59
All-Sky Solar Radiation	RadAvg		1.25	2.41	4.12	5.24	5.25	6.05	5.25	4.62	3.52	2.27	1.36	0.94
	RadStd		0.05	0.06	0.16	0.40	0.37	0.54	0.49	0.44	0.29	0.13	0.07	0.05

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page