

AGINSKOE, Russian Federation

WMO: 308590

Lat: 51.100N

Lon: 114.517E

Elev: 681

StdP: 93.40

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.2	-32.8	-37.9	0.1	-34.5	-35.7	0.1	-32.3	9.1	-15.5	8.0	-15.9	0.6	270	0.658

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	30.7	17.6	28.5	17.1	26.6	16.6	19.9	26.7	18.9	24.9	18.0	23.7	3.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	14.0	22.3	16.9	13.1	21.3	15.9	12.3	20.5	60.5	26.9	56.9	24.9	53.7	23.7	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	6.9	DB	-38.7	34.6	3.6	2.7	-41.2	36.5	-43.3	38.1	-45.3	39.6	-47.9	41.6	(4)
(5)			WB	-38.7	22.3	3.4	1.7	-41.1	23.5	-43.1	24.5	-45.0	25.4	-47.5	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.5	-21.7	-17.9	-8.8	1.6	9.4	16.7	19.1	16.6	9.6	0.2	-12.0	-19.8	(6)	
	DBStd	15.21	5.18	5.43	6.34	4.72	4.11	3.62	2.64	3.21	3.96	4.70	6.56	5.66	(7)	
	HDD10.0	4612	981	780	584	256	62	2	0	1	54	306	662	924	(8)	
	HDD18.3	6961	1239	1013	842	503	279	71	21	72	262	563	912	1183	(9)	
	CDD10.0	777	0	0	0	2	42	202	282	205	43	1	0	0	(10)	
	CDD18.3	84	0	0	0	0	1	21	45	18	0	0	0	0	(11)	
	CDH23.3	1399	0	0	0	1	50	436	618	265	29	0	0	0	(12)	
	CDH26.7	424	0	0	0	0	11	136	201	72	4	0	0	0	(13)	
	WSAvg	2.7	2.1	2.3	2.8	3.7	3.9	2.8	2.5	2.5	2.8	2.9	2.3	2.0	(14)	
(15) Precipitation	PrecAvg	371	2	3	4	11	26	59	113	80	47	10	5	5	(15)	
	PrecMax	622	9	15	20	35	89	187	306	169	192	28	13	14	(16)	
	PrecMin	232	0	0	0	0	0	2	25	19	2	0	0	0	(17)	
	PrecStd	94	2	4	4	9	26	41	55	40	36	8	4	3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.7	0.2	11.7	21.1	28.5	34.0	34.3	31.6	26.9	18.0	6.8	-2.9	(19)	
		MCWB	-6.8	-3.7	4.0	9.7	14.0	18.3	19.2	18.6	15.0	9.2	1.7	-5.1	(20)	
	2%	DB	-8.7	-2.9	7.8	17.1	24.6	30.0	31.0	28.7	23.3	13.9	3.1	-6.1	(21)	
		MCWB	-10.3	-5.6	1.7	7.5	12.7	17.2	18.1	17.7	13.7	6.4	-0.5	-7.8	(22)	
	5%	DB	-11.3	-5.8	4.5	14.2	21.7	27.8	28.7	26.2	20.6	10.9	0.5	-8.8	(23)	
		MCWB	-12.5	-7.9	-0.5	5.8	11.2	16.3	17.8	17.0	12.5	4.6	-2.4	-10.1	(24)	
	10%	DB	-13.5	-8.3	1.6	11.2	19.1	25.7	26.7	24.1	18.0	8.2	-2.2	-11.3	(25)	
		MCWB	-14.5	-9.9	-2.4	4.1	9.8	15.7	17.5	16.4	11.3	3.0	-4.4	-12.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.9	-3.5	4.3	10.1	15.0	20.6	21.9	20.5	16.6	9.3	2.0	-5.0	(27)	
		MCDB	-4.9	0.0	11.5	20.0	25.7	30.4	29.2	27.3	23.7	17.8	6.2	-2.8	(28)	
	2%	WB	-10.3	-5.6	1.7	7.9	13.3	18.7	20.4	19.2	14.8	6.6	-0.4	-7.7	(29)	
		MCDB	-8.8	-2.8	7.4	16.1	22.7	26.5	26.6	24.8	20.6	13.1	2.8	-6.2	(30)	
	5%	WB	-12.5	-7.9	-0.4	6.0	12.0	17.5	19.4	18.2	13.5	5.0	-2.4	-10.1	(31)	
		MCDB	-11.4	-5.9	4.1	13.3	20.3	24.9	25.5	23.6	18.6	10.1	0.3	-8.9	(32)	
	10%	WB	-14.5	-9.9	-2.3	4.4	10.4	16.6	18.5	17.3	12.1	3.4	-4.4	-12.3	(33)	
		MCDB	-13.6	-8.4	1.5	11.0	18.3	23.5	24.1	22.6	17.4	7.7	-2.3	-11.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	14.4	14.5	13.9	14.4	14.6	13.0	12.7	13.4	12.2	12.0	11.3	(35)	
		MCDBR	13.4	16.2	17.0	20.0	20.4	19.5	18.2	17.6	18.8	16.9	13.7	12.7	(36)	
		MCWBR	12.1	13.8	11.6	11.8	10.4	8.2	7.3	8.0	9.6	10.2	10.3	11.2	(37)	
	5% WB	MCDBR	13.3	16.1	16.5	18.7	18.7	15.8	13.7	13.5	15.4	15.8	13.5	12.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.251	0.278	0.320	0.413	0.490	0.465	0.424	0.387	0.341	0.304	0.275	0.257	(40)	
		taud	2.234	2.198	2.175	2.034	1.870	2.059	2.246	2.333	2.401	2.413	2.300	2.192	(41)	
	Ebn at Noon		779	849	873	819	769	796	827	842	847	816	738	695	(42)	
		Edh at Noon	68	93	117	153	189	158	129	113	94	76	64	60	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.56	2.73	4.29	5.30	6.00	6.31	5.80	5.07	4.03	2.71	1.58	1.17	(44)	
	RadStd		0.06	0.11	0.20	0.35	0.35	0.50	0.41	0.33	0.29	0.15	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page