

KRASNY CHIKOY, Russian FederationWMO: **309350**Lat: **50.367N**Lon: **108.750E**Elev: **2528**StdP: **13.40**Time Zone: **9.00 (E09)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.2	-31.4	-39.4	0.6	-35.0	-35.3	0.8	-31.3	12.2	5.0	10.4	4.3	0.2	70	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	86.2	64.4	82.5	62.6	78.8	61.3	67.1	79.8	65.3	76.7	63.7	74.3	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.2	95.2	70.9	61.4	89.3	69.6	59.9	84.6	68.3	33.2	79.7	31.7	76.9	30.5	74.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	12.3	10.1	DB	-40.0	94.2	4.4	3.9	-43.2	97.0	-45.7	99.3	-48.2	101.5	-51.4	104.3	(4)
(5)			WB	-39.5	70.8	4.5	2.6	-42.8	72.7	-45.4	74.3	-48.0	75.7	-51.3	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	30.5	-11.0	-1.2	18.1	36.4	48.7	60.8	66.1	61.3	48.5	31.8	10.3	-6.4	(6)
(7)		DBStd	28.08	10.62	10.82	11.75	7.82	7.71	6.59	5.06	5.87	7.23	8.32	11.50	12.03	(7)
(8)		HDD50	8463	1890	1433	988	412	118	4	0	2	113	564	1191	1748	(8)
(9)		HDD65	12750	2355	1853	1453	859	506	156	46	142	497	1029	1641	2213	(9)
(10)		CDD50	1327	0	0	0	3	78	329	498	353	66	0	0	0	(10)
(11)		CDD65	139	0	0	0	0	1	30	79	28	1	0	0	0	(11)
(12)		CDH74	2077	0	0	0	4	149	642	915	337	30	0	0	0	(12)
(13)		CDH80	616	0	0	0	0	34	189	304	86	3	0	0	0	(13)
(14)	Wind	WSAvg	3.2	1.8	2.3	3.7	4.9	5.2	4.0	3.3	3.1	3.2	2.9	2.5	1.9	(14)
(15)	Precipitation	PrecAvg	13.4	0.2	0.1	0.1	0.4	1.0	2.0	3.5	3.5	1.5	0.4	0.3	0.3	(15)
(16)		PrecMax	20.3	0.4	0.3	0.4	0.9	2.9	4.2	7.3	7.1	2.8	1.3	1.0	0.7	(16)
(17)		PrecMin	9.6	0.0	0.0	0.0	0.0	0.1	0.4	1.4	1.5	0.5	0.0	0.0	0.1	(17)
(18)		PrecStd	2.6	0.1	0.1	0.1	0.3	0.6	1.0	1.5	1.3	0.6	0.3	0.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	31.8	53.7	70.6	84.1	90.4	92.7	87.3	78.1	62.9	40.1	25.7	(19)
(20)			MCWB	20.5	26.0	41.1	49.8	57.7	64.3	69.1	66.2	59.8	48.1	33.0	22.8	(20)
(21)		2%	DB	15.2	26.2	46.2	63.6	78.2	85.0	87.1	81.7	71.8	56.3	34.3	20.5	(21)
(22)			MCWB	13.1	22.1	36.5	45.9	55.2	62.1	65.9	63.9	56.0	43.4	29.4	18.3	(22)
(23)		5%	DB	9.8	21.2	40.9	58.0	72.9	81.1	83.0	77.4	66.7	50.7	30.6	16.1	(23)
(24)			MCWB	8.2	18.2	32.5	42.8	52.6	60.8	64.6	62.7	53.7	40.3	26.8	14.4	(24)
(25)		10%	DB	5.7	16.7	35.8	52.7	67.5	77.3	78.9	73.3	61.8	45.4	27.0	12.3	(25)
(26)			MCWB	4.5	14.2	29.5	40.0	49.9	59.3	63.2	61.4	51.3	37.6	24.1	10.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	26.2	41.3	50.5	59.2	66.4	70.7	68.6	61.2	48.2	33.7	23.0	(27)
(28)			MCDWB	22.4	31.3	52.4	69.3	79.6	83.3	87.8	81.6	72.5	62.1	39.1	25.5	(28)
(29)		2%	WB	12.9	22.0	36.7	46.5	56.2	64.2	68.0	66.0	58.2	43.7	29.8	18.3	(29)
(30)			MCDWB	15.0	26.0	45.9	61.6	76.0	79.6	81.9	76.8	68.3	54.7	33.9	20.3	(30)
(31)		5%	WB	8.2	18.3	33.0	43.4	53.5	62.5	66.3	64.2	55.3	40.9	27.0	14.5	(31)
(32)			MCDWB	9.6	21.2	39.9	56.5	70.0	76.8	78.0	73.6	64.4	49.8	30.4	16.0	(32)
(33)		10%	WB	4.5	14.2	29.8	40.6	50.8	60.8	64.7	62.6	52.6	37.9	24.1	10.9	(33)
(34)			MCDWB	5.6	16.5	35.6	52.4	65.9	73.6	75.3	71.1	60.2	44.7	26.9	12.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	20.5	27.7	27.2	25.1	28.6	26.5	22.6	21.5	23.9	22.9	19.6	17.3	(35)
(36)			MCDBR	21.0	29.7	31.1	37.1	41.1	35.7	31.7	30.1	33.7	33.6	21.2	17.8	(36)
(37)			MCWBR	19.2	25.6	21.0	21.0	20.4	14.9	12.8	13.4	17.7	20.7	16.7	16.1	(37)
(38)		5% WB	MCDBR	21.0	29.2	29.4	34.4	37.2	29.4	25.2	24.5	29.3	31.6	20.9	17.7	(38)
(39)			MCWBR	19.2	25.1	20.0	19.8	18.8	12.8	11.1	12.0	15.8	19.6	16.6	16.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.263	0.286	0.322	0.374	0.438	0.430	0.406	0.379	0.334	0.304	0.284	0.266	(40)	
(41)		taud	2.222	2.205	2.231	2.222	2.068	2.206	2.332	2.385	2.458	2.468	2.326	2.199	(41)	
(42)		Ebn at Noon	244	268	278	274	260	263	268	271	273	263	235	221	(42)	
(43)		Edh at Noon	23	30	36	40	49	43	38	34	29	23	20	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	495	850	1271	1562	1790	1884	1754	1509	1185	790	475	365	(44)	
(45)		RadStd	23	36	68	108	124	108	125	95	106	53	36	30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page