

PRIARGUNSK, Russian Federation

WMO: 309750

Lat: 50.333N

Lon: 119.067E

Elev: 1710

StdP: 13.81

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.6	(c) -36.9	(d) -45.6	(e) 0.4	(f) -40.8	(g) -41.3	(h) 0.5	(i) -36.5	(j) 26.0	(k) -4.9	(l) 21.5	(m) -2.3	(n) 1.1	(o) 20	(p) 0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.8	(c) 88.6	(d) 65.0	(e) 84.8	(f) 64.3	(g) 81.4	(h) 63.7	(i) 69.6	(j) 81.2	(k) 68.0	(l) 78.8	(m) 66.4	(n) 76.4	(o) 9.7	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	103.2	73.7	64.6	97.0	72.3	62.9	91.3	71.1	34.9	80.6	33.4	78.5	32.2	76.5	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.8	18.6	-47.2	95.4	5.5	5.1	-51.2	99.0	-54.4	102.0	-57.5	104.9	-61.5	108.6
			-46.7	73.1	4.7	2.4	-50.1	74.9	-52.9	76.3	-55.5	77.6	-59.0	79.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.4	-18.3	-8.7	12.9	37.0	52.0	64.2	69.0	64.3	51.6	33.2	6.8	-13.4		
	DBStd	32.21	10.58	10.78	12.83	8.95	7.42	6.70	4.83	5.95	7.74	8.95	12.76	10.65		
	HDD50	9230	2118	1643	1150	400	64	1	0	1	71	522	1296	1964		
	HDD65	13267	2583	2063	1615	841	406	93	16	84	405	986	1746	2429		
	CDD50	1715	0	0	0	9	127	426	589	444	119	1	0	0		
	CDD65	279	0	0	0	0	5	68	140	62	4	0	0	0		
	CDH74	3258	0	0	0	5	169	973	1327	679	104	1	0	0		
	CDH80	1054	0	0	0	1	43	348	444	196	22	0	0	0		
(14) Wind	WSAvg	6.7	3.7	4.4	7.2	9.8	10.1	7.6	6.7	6.7	7.5	7.5	5.3	3.9		
(15) Precipitation	PrecAvg	13.4	0.2	0.2	0.2	0.4	0.9	2.2	3.7	2.8	1.3	0.7	0.2	0.2		
	PrecMax	22.8	0.8	0.3	0.8	1.2	4.3	5.8	7.5	8.2	3.4	2.2	0.7	0.5		
	PrecMin	6.0	0.0	0.0	0.0	0.0	0.0	0.1	0.7	0.7	0.0	0.0	0.0	0.0		
	PrecStd	3.9	0.2	0.1	0.2	0.4	0.9	1.3	1.8	2.0	0.9	0.6	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	26.6	51.8	72.2	85.6	95.3	93.7	91.3	83.3	65.3	42.0	19.8		
		MCWB	11.4	21.3	38.3	49.6	58.2	64.4	67.1	67.4	60.5	49.0	34.6	17.1		
	2%	DB	6.7	19.3	43.0	65.3	78.7	88.0	88.8	85.3	76.5	58.3	34.8	11.3		
		MCWB	5.4	16.3	33.4	46.3	55.2	62.5	66.4	65.8	58.6	44.7	29.5	9.8		
	5%	DB	2.2	13.9	37.4	59.2	73.7	83.6	84.7	81.2	71.4	53.2	29.3	7.1		
		MCWB	1.0	11.9	30.0	43.2	53.3	61.7	66.4	64.6	55.8	41.7	25.3	5.9		
	10%	DB	-2.1	9.1	32.5	53.9	69.2	79.5	81.2	77.4	66.8	48.4	25.0	2.8		
		MCWB	-3.1	7.5	27.2	40.3	50.8	61.1	66.1	63.0	54.0	39.2	21.9	1.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	21.9	38.7	51.1	60.3	68.8	72.5	71.1	63.2	49.3	35.0	17.2		
		MCDB	13.9	26.1	50.7	70.0	79.6	84.6	83.0	82.9	75.6	64.2	41.6	19.7		
	2%	WB	5.4	16.5	33.7	47.0	57.0	66.6	70.6	68.4	60.5	45.5	29.4	9.9		
		MCDB	6.7	19.3	42.1	63.2	74.5	80.3	81.7	79.5	71.9	56.0	34.3	11.1		
	5%	WB	1.1	11.9	30.4	43.5	54.6	64.7	69.0	66.7	58.0	42.6	25.8	5.9		
		MCDB	2.2	13.7	37.0	58.3	71.3	77.4	79.7	76.8	68.1	52.3	29.2	7.1		
	10%	WB	-3.0	7.7	27.2	40.5	52.0	63.0	67.5	65.0	55.2	39.7	22.0	1.8		
		MCDB	-2.1	9.2	32.5	53.0	67.1	75.2	77.4	74.5	65.1	47.7	24.9	2.8		
(35) Mean Daily Temperature Range	MDBR		20.3	24.4	24.4	24.5	25.9	24.1	20.8	22.4	25.0	23.0	20.8	19.2		
	5% DB	MCDBR	23.0	27.5	26.8	34.6	35.8	32.6	28.9	29.8	32.9	30.5	24.2	20.8		
		MCWBR	21.5	24.9	18.8	19.9	17.7	13.2	11.6	13.2	16.8	18.9	19.3	19.4		
	5% WB	MCDBR	22.8	27.2	26.2	32.8	31.3	24.8	22.6	23.4	26.7	28.3	23.5	20.5		
		MCWBR	21.3	24.7	18.9	19.5	16.3	11.6	11.0	11.3	14.4	18.2	18.8	19.2		
(40) Clear-Sky Solar Irradiance	taub		0.257	0.282	0.334	0.428	0.498	0.475	0.429	0.400	0.352	0.325	0.287	0.265		
	taud		2.197	2.154	2.086	1.990	1.863	2.045	2.252	2.294	2.364	2.329	2.256	2.159		
	Ebn at Noon		246	269	272	256	243	250	262	264	266	251	231	220		
	Edh at Noon		23	31	41	51	61	51	41	37	31	27	22	21		
(44) All-Sky Solar Radiation	RadAvg		511	892	1389	1682	1893	1986	1833	1656	1299	872	514	378		
	RadStd		32	54	76	95	134	173	121	138	85	51	25	31		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		N/A	N/A	-4.68	N/A	N/A	N/A	+428	+443	N/A	N/A	

Nomenclature: See separate page