

ALDAN, Russian Federation

WMO: 310040

Lat: 58.617N

Lon: 125.367E

Elev: 679

StdP: 93.43

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.2	-38.2	-42.1	0.1	-39.9	-40.4	0.1	-38.2	6.4	-16.5	5.5	-17.9	0.4	200	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	27.9	17.4	25.8	16.8	23.8	15.9	18.9	25.0	17.9	23.7	16.9	22.4	2.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	13.1	21.1	15.7	12.1	20.1	14.7	11.3	19.7	56.9	24.9	53.5	23.6	50.2	22.5	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.7	4.2	DB	-41.9	30.6	2.5	1.6	-43.7	31.8	-45.2	32.7	-46.6	33.6	-48.4	34.8	(4)
(5)			WB	-41.9	20.3	2.5	1.0	-43.7	21.0	-45.2	21.5	-46.6	22.1	-48.4	22.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.4	-26.5	-23.2	-15.1	-4.3	5.3	14.1	16.8	13.7	5.0	-6.3	-19.0	-26.2	(6)	
	DBStd	16.67	7.08	6.28	6.77	5.36	4.52	4.44	3.93	4.28	4.57	5.88	7.64	7.06	(7)	
	HDD10.0	6115	1131	931	779	429	157	14	2	16	160	506	869	1122	(8)	
	HDD18.3	8706	1389	1164	1037	679	404	139	77	153	400	764	1119	1380	(9)	
	CDD10.0	498	0	0	0	0	12	136	212	129	10	0	0	0	(10)	
	CDD18.3	48	0	0	0	0	0	11	28	9	0	0	0	0	(11)	
	CDH23.3	522	0	0	0	0	2	154	283	83	0	0	0	0	(12)	
	CDH26.7	109	0	0	0	0	0	32	65	12	0	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.5	1.6	1.8	2.0	2.0	1.7	1.5	1.5	1.7	1.7	1.7	1.4	(14)	
(15) Precipitation	PrecAvg	679	25	22	27	37	67	84	97	106	88	63	37	29	(15)	
	PrecMax	910	51	53	53	69	157	156	247	269	167	154	98	64	(16)	
	PrecMin	467	5	6	8	12	20	5	1	15	21	21	13	10	(17)	
	PrecStd	119	11	9	9	15	31	36	56	55	32	23	15	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.3	-5.5	2.9	11.7	22.6	29.8	30.9	28.3	21.0	9.4	0.8	-6.0	(19)	
		MCWB	-10.2	-7.1	-1.5	4.5	11.5	17.2	18.9	17.7	13.2	4.3	-1.5	-6.6	(20)	
	2%	DB	-11.9	-8.5	-0.8	8.2	18.6	27.2	28.4	25.8	17.6	5.6	-2.2	-10.8	(21)	
		MCWB	-12.7	-9.6	-3.6	2.7	9.7	16.2	18.1	17.1	11.2	2.5	-3.5	-11.5	(22)	
	5%	DB	-14.1	-11.0	-2.9	5.8	16.0	24.9	26.5	23.4	14.9	3.2	-4.7	-13.0	(23)	
		MCWB	-14.6	-11.7	-5.0	1.2	8.3	15.1	17.8	16.2	9.5	1.0	-5.7	-13.6	(24)	
	10%	DB	-16.2	-13.5	-4.9	3.7	13.5	22.8	24.5	21.4	12.5	1.1	-7.5	-15.4	(25)	
		MCWB	-16.7	-14.2	-6.4	-0.2	7.1	14.0	17.0	15.4	8.5	-0.6	-8.5	-15.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.1	-7.1	-1.0	4.9	12.4	18.6	20.2	19.7	14.0	4.9	-1.0	-7.0	(27)	
		MCDB	-9.6	-5.6	1.8	10.3	21.0	26.5	26.7	24.7	18.9	7.9	0.5	-5.4	(28)	
	2%	WB	-12.6	-9.8	-3.3	3.1	10.4	17.0	19.3	18.1	11.9	2.9	-3.5	-11.4	(29)	
		MCDB	-11.9	-8.9	-1.0	7.8	17.2	24.9	25.6	23.2	15.8	5.2	-2.2	-10.8	(30)	
	5%	WB	-14.6	-11.8	-4.9	1.5	8.9	15.9	18.6	17.0	10.4	1.1	-5.7	-13.5	(31)	
		MCDB	-14.1	-11.0	-3.1	5.1	14.8	23.3	24.6	22.2	13.8	3.0	-4.8	-13.0	(32)	
	10%	WB	-16.6	-14.2	-6.5	0.1	7.5	14.9	17.7	15.9	8.9	-0.4	-8.5	-15.8	(33)	
		MCDB	-16.1	-13.5	-4.9	3.4	12.7	21.0	23.2	20.6	12.0	0.9	-7.5	-15.4	(34)	
(35) Mean Daily Temperature Range	MDBR		7.5	9.1	10.5	9.9	9.2	11.4	10.3	9.8	7.8	6.6	7.2	6.8	(35)	
	5% DB	MCDBR	8.1	9.5	10.6	10.9	14.0	15.0	13.8	13.4	12.7	8.3	7.7	7.0	(36)	
		MCWBR	7.7	8.8	8.6	6.9	7.2	6.6	5.9	6.2	7.1	5.7	6.9	6.7	(37)	
	5% WB	MCDBR	8.1	9.3	9.7	10.0	12.6	12.9	11.3	11.4	10.8	7.5	7.5	6.8	(38)	
		MCWBR	7.7	8.6	8.1	6.5	6.7	6.3	5.5	5.8	6.6	5.4	6.8	6.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.234	0.265	0.295	0.364	0.436	0.409	0.454	0.405	0.331	0.285	0.239	0.216	(40)	
	taud		2.021	2.066	2.070	1.967	2.009	2.270	2.146	2.278	2.440	2.273	2.042	1.950	(41)	
	Ebn at Noon		581	751	837	827	790	827	772	788	809	730	562	459	(42)	
	Edh at Noon		52	84	113	151	156	123	136	111	80	68	50	39	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.65	1.72	3.46	5.17	5.01	5.53	5.02	3.93	2.53	1.33	0.82	0.41	(44)	
	RadStd		0.04	0.07	0.14	0.24	0.41	0.40	0.50	0.30	0.20	0.12	0.07	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.84	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A

Nomenclature: See separate page