

OKHOTSK, Russian Federation

WMO: 310880

Lat: 59.364N

Lon: 143.208E

Elev: 6

StdP: 101.26

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.2	-28.6	-35.2	0.1	-29.5	-33.6	0.2	-27.8	12.5	-5.9	9.6	-11.5	3.9	0	0.803

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	19.0	14.5	17.5	14.6	16.4	14.2	16.1	17.8	15.3	16.7	14.6	15.9	3.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	10.9	16.8	14.6	10.3	16.0	13.9	9.9	15.3	45.2	17.9	42.9	16.9	41.0	16.0	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	8.6	7.1	-32.3	24.4	2.4	2.8	-34.0	26.4	-35.4	28.0	-36.8	29.6	-38.5	31.7
			-32.5	17.6	2.3	1.3	-34.2	18.6	-35.5	19.4	-36.8	20.1	-38.5	21.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.3	-19.8	-18.6	-11.7	-4.1	2.6	8.2	12.9	13.8	8.8	-1.3	-12.6	-18.9
	DBStd	12.94	5.90	5.32	5.04	4.05	2.68	2.80	2.02	1.80	3.26	4.85	5.94	5.72
	HDD10.0	5103	926	801	672	424	229	67	1	1	59	349	677	896
	HDD18.3	7898	1184	1034	931	674	488	304	168	142	285	608	927	1154
	CDD10.0	247	0	0	0	0	0	13	92	118	24	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	8	0	0	0	0	0	0	2	6	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	3.5	4.0	3.4	3.0	3.2	3.2	3.3	3.2	3.0	3.3	3.6	4.1	4.3
Precipitation	PrecAvg	506	12	9	13	25	43	53	80	88	83	59	28	14
	PrecMax	813	80	94	64	67	144	156	226	268	265	223	165	84
	PrecMin	251	0	0	0	0	2	1	5	13	19	4	0	0
	PrecStd	124	15	14	14	18	24	35	54	61	51	41	29	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.0	-1.8	1.3	6.7	14.4	18.0	21.4	23.5	18.8	10.0	3.1	-0.7
		MCWB	-2.5	-3.0	-1.9	1.9	7.1	11.7	16.2	15.7	11.1	7.1	1.7	-2.1
	2%	DB	-4.2	-4.5	-0.8	4.2	10.5	15.1	18.7	19.5	16.1	8.1	1.4	-3.9
		MCWB	-5.3	-5.6	-2.6	1.1	6.1	12.3	15.7	14.7	11.9	5.2	0.4	-5.2
	5%	DB	-7.4	-8.1	-2.1	2.3	8.2	13.7	17.3	17.8	14.7	6.5	-0.6	-7.2
		MCWB	-8.2	-9.5	-3.6	0.0	5.1	11.6	14.9	14.9	12.1	4.3	-1.4	-8.2
	10%	DB	-10.7	-10.9	-3.7	0.9	6.5	12.3	16.1	16.7	13.8	5.2	-3.1	-10.7
		MCWB	-11.5	-11.9	-5.3	-0.7	4.4	10.7	14.3	14.6	11.8	3.2	-4.1	-11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.0	-2.7	-0.9	2.6	8.2	13.9	17.4	17.2	14.7	8.4	2.2	-2.3
		MCDB	-1.4	-2.0	0.1	5.6	12.1	15.9	19.5	20.0	15.4	9.2	2.8	-1.2
	2%	WB	-5.3	-5.6	-2.2	1.3	6.6	12.8	16.2	16.2	13.7	6.1	0.5	-5.2
		MCDB	-4.5	-4.5	-1.0	3.4	9.7	14.4	18.1	18.0	14.6	7.1	1.2	-4.2
	5%	WB	-8.2	-9.3	-3.6	0.4	5.5	11.7	15.2	15.6	13.0	4.8	-1.4	-8.2
		MCDB	-7.3	-8.3	-2.1	1.9	7.7	13.2	16.8	17.0	14.0	6.0	-0.7	-7.2
	10%	WB	-11.5	-11.9	-5.2	-0.4	4.6	10.9	14.4	14.9	12.1	3.5	-4.0	-11.6
		MCDB	-10.7	-11.0	-3.8	0.7	6.3	12.1	15.8	16.2	13.4	4.9	-3.1	-10.8
Mean Daily Temperature Range	5% DB	MDBR	4.8	7.0	10.0	7.1	4.8	4.1	3.7	5.0	6.7	6.3	4.7	4.1
		MCDBR	7.5	7.2	9.2	8.3	9.2	7.5	7.1	8.3	8.1	7.5	4.8	7.3
		MCWBR	7.0	6.6	7.6	5.8	5.4	4.6	4.5	4.9	5.3	5.4	4.3	6.9
	5% WB	MCDBR	7.5	6.9	8.4	6.9	8.0	6.1	6.1	6.4	5.2	6.6	4.4	7.3
		MCWBR	7.1	6.3	7.1	5.0	5.0	4.2	4.2	4.4	4.1	5.5	4.1	7.0
Clear-Sky Solar Irradiance	taub	0.228	0.266	0.322	0.430	0.453	0.425	0.479	0.425	0.348	0.318	0.258	0.214	
	taud	2.095	2.134	2.016	1.791	1.961	2.231	2.105	2.266	2.448	2.296	2.141	2.027	
	Ebn at Noon	582	746	791	747	770	808	746	765	783	675	523	446	
	Edh at Noon	45	76	118	179	163	127	141	112	79	66	44	33	
All-Sky Solar Radiation	RadAvg	0.53	1.58	3.35	4.83	4.91	5.17	4.44	3.74	2.75	1.61	0.68	0.28	
	RadStd	0.04	0.07	0.16	0.45	0.54	0.47	0.75	0.46	0.38	0.17	0.08	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page