

AYAN, Russian Federation

WMO: 311680

Lat: 56.4606N

Lon: 138.1700E

Elev: 26

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.5	-35.1	0.8	-15.3	-31.1	1.0	-12.1	32.9	21.2	23.5	20.0	4.0	230	0.768

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.8	70.4	58.1	66.5	56.7	63.3	56.3	60.6	66.4	59.0	63.4	57.7	61.3	5.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.5	73.3	61.7	57.1	69.7	60.0	55.9	66.6	58.9	26.9	66.6	25.8	63.6	25.0	61.5	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	17.6	14.2	DB	-22.2	80.2	5.4	4.7	-26.1	83.6	-29.3	86.3	-32.4	88.9	-36.3	92.3	(4)
(5)			WB	-22.6	64.5	5.3	2.2	-26.4	66.1	-29.6	67.4	-32.6	68.7	-36.4	70.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	1.0	3.1	13.9	26.5	36.1	46.0	54.7	57.1	49.1	33.7	13.9	2.8	(6)
(7)		DBStd	21.31	8.78	7.93	8.02	6.46	5.30	6.67	4.42	3.88	5.52	7.31	10.57	9.48	(7)
(8)		HDD50	8388	1518	1314	1120	705	433	156	8	1	81	505	1083	1464	(8)
(9)		HDD65	13400	1983	1734	1585	1155	897	570	320	247	477	970	1533	1929	(9)
(10)		CDD50	470	0	0	0	0	2	37	155	222	54	0	0	0	(10)
(11)		CDD65	6	0	0	0	0	0	1	2	3	0	0	0	0	(11)
(12)		CDH74	44	0	0	0	0	0	12	12	18	2	0	0	0	(12)
(13)		CDH80	6	0	0	0	0	0	3	1	2	0	0	0	0	(13)
(14)	Wind	WSAvg	5.9	4.6	4.4	5.5	6.7	7.8	7.7	7.0	6.0	5.3	5.5	5.0	4.8	(14)
(15)	Precipitation	PrecAvg	35.9	0.9	0.6	1.0	2.0	3.3	3.4	5.9	6.4	5.9	3.5	1.8	1.2	(15)
(16)		PrecMax	68.0	4.0	2.2	4.0	7.0	8.6	9.2	22.5	26.3	19.2	16.1	9.1	7.8	(16)
(17)		PrecMin	20.0	0.0	0.0	0.0	0.0	0.2	0.4	0.4	0.1	0.5	0.0	0.0	0.0	(17)
(18)		PrecStd	9.5	1.0	0.6	1.1	1.5	2.0	2.5	5.0	4.8	4.2	3.1	1.8	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	27.6	37.7	50.9	59.8	72.9	75.2	76.1	68.4	53.3	40.2	29.9	(19)
MCWB			26.4	23.4	30.2	39.0	45.5	56.0	61.0	61.6	55.3	44.4	34.3	29.2	(20)	
2%		DB	22.5	23.4	32.7	42.9	53.7	65.5	68.7	71.1	63.5	49.6	34.8	26.6	(21)	
		MCWB	21.4	20.4	27.0	34.3	43.5	53.7	58.3	58.7	53.3	43.0	31.4	25.0	(22)	
5%		DB	17.6	18.8	29.3	38.5	48.8	60.2	65.0	67.2	60.1	46.7	32.1	21.2	(23)	
		MCWB	15.5	16.0	24.9	31.7	40.7	51.6	57.8	57.4	52.6	41.1	30.2	19.1	(24)	
10%		DB	13.8	15.3	26.5	35.0	44.5	55.6	61.5	63.8	57.8	44.1	29.5	16.6	(25)	
		MCWB	11.5	12.8	23.0	30.2	38.7	50.1	56.8	57.3	52.3	39.0	27.0	14.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	24.9	30.5	39.7	47.3	59.4	63.5	63.6	58.5	47.8	35.4	29.4	(27)
MCDB			27.0	26.8	35.8	50.7	57.8	70.8	70.8	72.3	62.4	50.2	39.0	30.1	(28)	
2%		WB	21.4	20.3	28.0	34.8	43.8	55.0	60.5	61.1	56.5	44.6	32.4	24.6	(29)	
		MCDB	22.3	23.2	31.6	41.1	52.5	63.4	66.0	66.6	59.9	48.2	34.1	26.9	(30)	
5%		WB	15.7	16.3	25.4	32.5	41.3	52.7	58.5	59.4	54.9	42.2	30.4	19.1	(31)	
		MCDB	17.2	18.7	28.7	36.8	47.7	58.3	63.1	63.8	58.2	45.4	32.3	21.1	(32)	
10%		WB	11.5	12.8	23.2	31.1	39.2	50.5	57.1	58.4	53.5	40.3	27.4	14.3	(33)	
		MCDB	13.7	15.3	26.2	34.0	43.3	55.2	60.5	62.1	56.6	43.2	29.5	16.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.0	12.6	14.3	10.8	8.9	9.8	8.1	9.8	12.4	11.0	10.1	9.9	(35)
MCDBR			12.3	15.6	16.8	17.4	19.9	20.7	17.5	18.8	17.0	14.6	12.0	11.4	(36)	
MCWBR			11.6	13.2	12.9	10.6	11.0	10.9	9.1	9.0	9.9	10.1	9.6	10.3	(37)	
5% WB		MCDBR	12.2	15.2	15.8	15.0	17.9	17.1	14.1	13.4	12.5	11.5	10.8	11.0	(38)	
		MCWBR	11.7	13.0	12.6	9.6	10.6	9.7	8.2	7.6	8.5	9.1	9.1	10.4	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.252	0.279	0.337	0.439	0.499	0.474	0.512	0.438	0.369	0.344	0.292	0.250	(40)	
taud		2.084	2.102	1.966	1.750	1.792	2.075	2.015	2.242	2.385	2.236	2.119	2.052	(41)		
Ebn at Noon		200	244	253	240	234	245	231	243	247	216	178	164	(42)		
Edh at Noon		19	28	42	61	63	48	50	37	28	25	18	15	(43)		
(44)	All-Sky Solar Radiation	RadAvg	266	618	1143	1605	1574	1643	1432	1233	948	548	276	161	(44)	
(45)		RadStd	16	30	59	97	211	170	184	168	80	60	29	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (2 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page