

AYAN, Russian Federation

WMO: 311680

Lat: 56.4606N

Lon: 138.1700E

Elev: 8

StdP: 101.23

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.0	-25.8	-37.3	0.1	-26.3	-35.1	0.1	-24.5	14.7	-6.0	10.5	-6.7	1.8	230	0.768

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	21.3	14.5	19.1	13.7	17.4	13.5	15.9	19.1	15.0	17.4	14.3	16.3	2.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.7	10.5	16.5	14.0	10.0	15.6	13.3	9.5	14.9	44.8	19.2	42.1	17.6	40.2	16.4	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	7.9	6.4	-30.1	26.8	3.0	2.6	-32.3	28.6	-34.1	30.2	-35.8	31.6	-38.0	33.5
			-30.3	18.1	3.0	1.2	-32.5	19.0	-34.2	19.7	-35.9	20.4	-38.0	21.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.1	-17.2	-16.1	-10.1	-3.1	2.3	7.8	12.6	14.0	9.5	1.0	-10.0	-16.2	(6)
(7)		DBStd	11.84	4.88	4.41	4.46	3.59	2.94	3.71	2.45	2.16	3.07	4.06	5.87	5.27	(7)
(8)		HDD10.0	4660	843	730	622	392	241	87	4	45	281	602	813		(8)
(9)		HDD18.3	7444	1102	963	881	642	498	317	178	137	265	539	852	1072	(9)
(10)		CDD10.0	261	0	0	0	0	1	21	86	123	30	0	0	0	(10)
(11)		CDD18.3	3	0	0	0	0	0	1	1	2	0	0	0	0	(11)
(12)		CDH23.3	24	0	0	0	0	0	7	7	10	1	0	0	0	(12)
(13)		CDH26.7	3	0	0	0	0	0	2	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.0	2.0	2.4	3.0	3.5	3.4	3.1	2.7	2.4	2.5	2.2	2.1	(14)
(15)	Precipitation	PrecAvg	911	22	14	26	50	85	86	150	162	150	90	45	31	(15)
(16)		PrecMax	1728	102	56	101	178	218	233	571	668	488	408	230	199	(16)
(17)		PrecMin	507	0	0	0	0	5	9	10	3	12	0	0	0	(17)
(18)		PrecStd	242	25	14	27	37	51	63	127	122	106	80	46	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.8	-2.5	3.2	10.5	15.4	22.7	24.0	24.5	20.2	11.8	4.6	-1.1	(19)
(20)		MCWB	-3.1	-4.8	-1.0	3.9	7.5	13.3	16.1	16.4	13.0	6.9	1.3	-1.6	(20)	
(21)		2%	DB	-5.3	-4.8	0.4	6.0	12.1	18.6	20.4	21.7	17.5	9.8	1.6	-3.0	(21)
(22)		MCWB	-5.9	-6.4	-2.8	1.3	6.4	12.1	14.6	14.8	11.8	6.1	-0.3	-3.9	(22)	
(23)		5%	DB	-8.0	-7.3	-1.5	3.6	9.3	15.6	18.3	19.6	15.6	8.2	0.0	-6.0	(23)
(24)		MCWB	-9.2	-8.9	-3.9	-0.2	4.8	10.9	14.3	14.1	11.5	5.1	-1.0	-7.2	(24)	
(25)		10%	DB	-10.1	-9.3	-3.1	1.7	7.0	13.1	16.4	17.7	14.3	6.7	-1.4	-8.6	(25)
(26)		MCWB	-11.4	-10.7	-5.0	-1.0	3.7	10.1	13.8	14.0	11.3	3.9	-2.8	-9.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.0	-3.9	-0.8	4.3	8.5	15.2	17.5	17.5	14.7	8.8	1.9	-1.5	(27)
(28)		MCDWB	-2.8	-2.9	2.1	10.4	14.3	21.6	21.5	22.4	16.9	10.1	3.9	-1.0	(28)	
(29)		2%	WB	-5.9	-6.5	-2.2	1.6	6.5	12.8	15.8	16.1	13.6	7.0	0.2	-4.1	(29)
(30)		MCDWB	-5.4	-4.9	-0.2	5.1	11.4	17.4	18.9	19.2	15.5	9.0	1.2	-2.8	(30)	
(31)		5%	WB	-9.0	-8.7	-3.7	0.3	5.2	11.5	14.7	15.2	12.7	5.7	-0.9	-7.2	(31)
(32)		MCDWB	-8.2	-7.4	-1.8	2.7	8.7	14.6	17.3	17.6	14.6	7.4	0.2	-6.1	(32)	
(33)		10%	WB	-11.4	-10.7	-4.9	-0.5	4.0	10.3	13.9	14.7	11.9	4.6	-2.6	-9.8	(33)
(34)		MCDWB	-10.2	-9.3	-3.2	1.1	6.3	12.9	15.8	16.7	13.6	6.2	-1.4	-8.7	(34)	
(35)	Mean Daily Temperature Range		MDBR	6.1	7.0	8.0	6.0	4.9	5.4	4.5	5.5	6.9	6.1	5.6	5.5	(35)
(36)		5% DB	MCDBR	6.8	8.7	9.3	9.7	11.0	11.5	9.7	10.5	9.5	8.1	6.7	6.4	(36)
(37)			MCWBR	6.5	7.3	7.1	5.9	6.1	6.1	5.1	5.0	5.5	5.6	5.3	5.7	(37)
(38)			MCDBR	6.8	8.5	8.8	8.4	9.9	9.5	7.8	7.5	7.0	6.4	6.0	6.1	(38)
(39)		5% WB	MCWBR	6.5	7.2	7.0	5.3	5.9	5.4	4.5	4.2	4.7	5.1	5.0	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.252	0.279	0.337	0.439	0.499	0.474	0.512	0.438	0.369	0.344	0.292	0.250	(40)	
(41)		taud	2.084	2.102	1.966	1.750	1.792	2.075	2.015	2.242	2.385	2.236	2.119	2.052	(41)	
(42)		Ebn at Noon	631	770	797	756	739	772	729	767	780	680	560	516	(42)	
(43)		Edh at Noon	59	88	132	193	198	151	158	118	89	78	57	47	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.84	1.95	3.60	5.06	4.96	5.18	4.51	3.89	2.99	1.73	0.87	0.51	(44)	
(45)		RadStd	0.05	0.09	0.18	0.30	0.66	0.54	0.58	0.53	0.25	0.19	0.09	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page