

BOMNAK, Russian Federation

WMO: 312530

Lat: 54.7118N

Lon: 128.8560E

Elev: 364

StdP: 97.02

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-39.9	-38.0	-42.4	0.1	-39.5	-40.6	0.1	-37.8	6.8	-10.5	5.7	-13.7	0.2	0	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	28.4	19.3	26.5	18.3	24.7	17.5	20.6	26.0	19.5	24.7	18.5	23.2	1.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	14.3	22.7	17.7	13.3	21.8	16.6	12.4	21.1	61.4	26.1	57.5	24.6	54.3	23.3	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.0	5.1	DB	-42.0	31.3	1.8	2.0	-43.3	32.7	-44.3	33.9	-45.4	35.0	-46.7	36.4	(4)
(5)			WB	-41.9	22.3	1.8	1.5	-43.2	23.4	-44.3	24.3	-45.3	25.1	-46.7	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.4	-28.2	-23.0	-11.9	0.1	9.0	16.2	18.9	16.6	9.0	-1.8	-18.5	-28.7	(6)
(7)		DBStd	17.98	5.81	5.62	6.09	4.87	3.97	3.65	3.18	3.26	4.14	5.37	8.37	6.17	(7)
(8)		HDD10.0	5643	1186	923	679	299	67	2	0	1	67	365	854	1200	(8)
(9)		HDD18.3	8024	1444	1156	938	547	288	82	31	72	281	623	1104	1458	(9)
(10)		CDD10.0	747	0	0	0	2	37	189	276	206	37	1	0	0	(10)
(11)		CDD18.3	87	0	0	0	0	1	18	48	19	1	0	0	0	(11)
(12)		CDH23.3	703	0	0	0	0	13	179	371	137	3	0	0	0	(12)
(13)		CDH26.7	152	0	0	0	0	1	32	98	22	0	0	0	0	(13)
(14)	Wind	WSAvg	1.5	0.7	0.9	1.5	2.1	2.4	1.9	1.7	1.5	1.7	1.8	1.0	0.6	(14)
(15)	Precipitation	PrecAvg	572	5	6	11	33	52	78	125	109	76	38	20	9	(15)
(16)		PrecMax	785	19	30	40	102	136	179	337	292	160	118	56	28	(16)
(17)		PrecMin	365	0	0	0	2	9	20	10	7	18	4	4	0	(17)
(18)		PrecStd	108	4	6	9	22	28	38	64	55	37	26	12	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.3	-6.4	4.7	18.1	25.1	29.9	31.7	28.8	22.9	13.7	-1.0	-5.2	(19)
(20)			MCWB	-10.5	-8.4	0.1	9.2	14.0	19.5	20.3	20.1	16.3	8.0	-3.2	-7.6	(20)
(21)		2%	DB	-13.1	-9.1	1.6	13.3	21.7	27.2	29.2	26.7	20.1	10.0	-2.7	-11.3	(21)
(22)			MCWB	-14.2	-10.7	-2.1	6.2	12.3	17.7	19.7	18.8	14.4	5.4	-3.8	-12.6	(22)
(23)		5%	DB	-16.1	-11.8	-0.6	10.1	19.3	25.4	27.2	24.7	17.8	7.5	-4.2	-15.9	(23)
(24)			MCWB	-16.8	-13.0	-3.6	4.3	11.0	16.7	19.2	17.9	12.7	4.0	-5.5	-16.6	(24)
(25)		10%	DB	-19.3	-14.0	-2.7	7.5	16.9	23.5	25.2	22.7	15.8	5.5	-6.4	-19.8	(25)
(26)			MCWB	-19.8	-15.0	-5.2	2.5	9.5	15.9	18.4	17.1	11.6	2.2	-7.6	-20.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.4	-8.5	0.6	10.2	14.9	20.9	22.7	21.4	17.3	8.2	-2.4	-7.6	(27)
(28)			MCDWB	-9.4	-6.5	4.6	17.8	23.2	26.2	27.7	27.2	21.8	13.1	-1.6	-5.4	(28)
(29)		2%	WB	-14.3	-10.7	-1.8	6.6	12.9	19.2	21.1	19.9	15.2	6.0	-3.6	-12.5	(29)
(30)			MCDWB	-13.2	-9.2	1.1	12.7	20.0	25.4	26.4	24.6	19.0	9.2	-2.6	-11.4	(30)
(31)		5%	WB	-16.8	-13.0	-3.4	4.6	11.6	17.9	20.1	18.9	13.7	4.3	-5.5	-16.7	(31)
(32)			MCDWB	-16.1	-11.9	-0.7	9.7	18.2	23.5	25.5	23.1	16.6	7.3	-4.2	-16.0	(32)
(33)		10%	WB	-19.8	-15.0	-5.2	2.8	10.2	16.7	19.1	17.8	12.4	2.5	-7.5	-20.3	(33)
(34)			MCDWB	-19.3	-14.0	-2.8	7.3	15.8	22.0	24.0	21.8	15.1	5.0	-6.4	-19.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	10.7	11.2	9.8	11.0	11.4	9.7	10.0	9.8	8.0	8.5	7.3	(35)
(36)			MCDBR	9.7	10.4	11.2	12.9	14.9	14.2	13.0	13.2	12.4	9.7	7.6	8.2	(36)
(37)			MCWBR	8.8	9.1	8.5	7.9	7.8	6.6	5.9	6.4	7.4	6.5	6.5	7.5	(37)
(38)		5% WB	MCDBR	9.7	10.2	10.7	12.3	13.7	12.2	11.2	11.1	10.3	9.2	7.3	7.9	(38)
(39)			MCWBR	8.8	8.9	8.3	7.8	7.6	6.5	6.0	6.0	6.6	6.3	6.6	7.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.239	0.272	0.319	0.448	0.493	0.487	0.486	0.409	0.359	0.338	0.270	0.234	(40)	
(41)		taud	2.143	2.113	2.039	1.860	1.923	2.042	2.085	2.310	2.385	2.228	2.119	2.085	(41)	
(42)		Ebn at Noon	711	806	839	762	754	767	758	805	803	713	641	616	(42)	
(43)		Edh at Noon	61	92	126	176	176	158	149	112	91	83	63	52	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.12	2.30	4.09	5.38	5.22	5.99	5.21	4.43	3.22	2.04	1.19	0.81	(44)	
(45)		RadStd	0.04	0.09	0.17	0.36	0.36	0.41	0.54	0.35	0.28	0.17	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page