

UDSKOYE, Russian Federation

WMO: 312850

Lat: 54.507N

Lon: 134.408E

Elev: 203

StdP: 14.59

Time Zone: 10.00 (E10)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.2	-30.5	-39.4	0.6	-34.4	-34.9	0.8	-29.8	9.1	1.6	7.2	-0.8	1.0	250	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.3	83.5	67.0	79.3	65.2	74.8	62.8	68.9	79.9	66.5	76.8	64.1	73.4	2.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	92.3	75.2	62.3	84.8	71.8	60.2	78.4	68.0	33.3	79.9	31.3	76.9	29.5	73.9	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	7.7	7.0	-42.2	91.3	6.0	4.8	-46.5	94.7	-50.1	97.5	-53.5	100.2	-57.8	103.6		
(5)			-42.3	73.6	5.6	2.1	-46.3	75.1	-49.6	76.3	-52.7	77.5	-56.8	79.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	-13.0	-5.2	11.4	29.6	41.3	53.0	58.9	59.6	49.6	31.2	6.3	-10.5		
	DBStd	27.64	8.56	9.93	10.97	7.92	7.24	8.43	6.35	5.41	7.17	8.87	13.22	10.73		
	HDD50	9533	1954	1546	1197	612	288	64	3	3	96	583	1310	1877		
	HDD65	14218	2419	1966	1662	1061	733	371	211	183	463	1047	1760	2342		
	CDD50	835	0	0	0	0	19	153	278	300	84	1	0	0		
	CDD65	48	0	0	0	0	0	11	21	15	1	0	0	0		
	CDH74	964	0	0	0	0	23	307	378	243	13	0	0	0		
	CDH80	247	0	0	0	0	3	83	117	44	0	0	0	0		
	WSAvg	3.0	2.2	2.4	2.7	3.4	3.9	3.5	3.5	3.1	3.0	2.9	2.7	2.7		
	PrecAvg	26.7	0.7	0.4	0.7	1.6	3.0	2.8	4.0	4.1	3.7	3.1	1.5	1.0		
(15) Precipitation	PrecMax	34.6	2.3	2.2	2.8	3.5	6.0	5.4	9.3	7.2	9.8	6.3	4.4	3.3		
	PrecMin	19.1	0.0	0.0	0.0	0.5	0.6	0.7	1.1	1.6	1.1	0.6	0.4	0.2		
	PrecStd	4.1	0.7	0.4	0.7	0.8	1.4	1.1	2.2	1.5	1.9	1.6	1.0	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	25.9	44.8	61.1	77.6	87.9	90.8	84.5	75.7	59.5	37.9	28.9		
		MCWB	16.4	21.5	34.6	46.0	55.7	66.5	69.8	69.4	63.0	47.2	32.0	27.8		
	2%	DB	9.6	20.7	39.2	52.9	71.7	82.7	84.7	80.3	70.0	51.1	33.0	22.1		
		MCWB	8.6	17.4	31.7	41.6	53.5	64.2	68.5	66.9	59.1	42.4	29.4	21.5		
	5%	DB	3.8	15.4	34.5	47.9	65.5	77.9	79.1	76.1	65.2	46.7	30.5	12.1		
		MCWB	2.7	13.2	28.3	38.2	50.5	62.3	66.7	65.2	56.6	40.8	28.1	11.2		
	10%	DB	-0.3	10.8	30.1	43.1	58.5	72.0	73.4	71.4	61.2	43.7	27.3	5.6		
		MCWB	-1.2	9.1	25.3	35.1	46.6	59.2	64.5	63.0	54.2	39.2	25.2	4.6		
	0.4%	WB	12.6	22.1	35.8	47.1	57.4	69.0	71.8	71.5	64.2	48.0	34.2	28.1		
		MCDB	13.4	25.3	44.6	59.4	76.3	80.8	85.7	80.8	74.7	56.9	37.3	29.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	7.5	17.7	32.1	42.1	53.8	65.6	69.5	68.5	61.0	44.6	30.3	21.6		
		MCDB	8.5	20.7	38.7	52.1	68.8	79.3	81.2	78.2	67.8	47.9	31.9	22.4		
	5%	WB	2.4	13.0	28.6	39.0	50.8	63.0	67.3	65.9	58.0	42.2	28.1	11.0		
		MCDB	3.3	15.3	33.8	47.0	64.7	76.6	78.2	74.2	63.7	46.1	30.6	12.0		
	10%	WB	-1.5	9.3	25.8	35.6	47.1	60.2	64.6	63.5	55.2	39.6	24.9	4.5		
		MCDB	-0.8	10.9	30.1	42.1	57.5	70.4	73.8	70.5	60.2	43.0	27.2	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	24.1	27.9	18.4	18.0	23.1	17.1	19.3	19.1	16.6	15.4	13.4		
		MCDBR	19.1	26.1	31.3	28.5	37.8	39.7	34.0	31.9	26.6	22.8	10.6	15.3		
		MCWBR	18.0	22.8	24.3	18.1	21.3	22.6	19.5	18.8	15.7	14.3	8.8	14.6		
		MCDBR	18.8	25.8	28.2	26.5	35.9	36.5	31.1	27.9	24.3	19.1	10.3	15.2		
	5% WB	MCWBR	18.0	22.5	21.8	17.0	20.9	21.5	18.8	17.6	14.8	12.6	8.9	14.8		
(40) Clear-Sky Solar Irradiance	taub		0.252	0.285	0.344	0.461	0.515	0.504	0.504	0.440	0.376	0.358	0.288	0.249		
	taud		2.113	2.079	1.959	1.749	1.847	2.007	2.054	2.241	2.354	2.180	2.083	2.057		
	Ebn at Noon		218	249	256	237	233	239	236	246	249	218	194	187		
	Edh at Noon		20	30	44	63	60	52	49	38	30	28	21	17		
(44) All-Sky Solar Radiation	RadAvg		357	726	1245	1632	1504	1681	1457	1251	962	594	367	256		
	RadStd		14	28	59	91	203	171	197	156	105	59	40	10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page