

UDSKOYE, Russian Federation

WMO: 312850

Lat: 54.507N

Lon: 134.408E

Elev: 62

StdP: 100.58

Time Zone: 10.00 (E10)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -37.3	(c) -34.7	(d) -39.6	(e) 0.1	(f) -36.9	(g) -37.1	(h) 0.1	(i) -34.3	(j) 4.1	(k) -16.9	(l) 3.2	(m) -18.2	(n) 0.4	(o) 250	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.7	(c) 28.6	(d) 19.4	(e) 26.3	(f) 18.5	(g) 23.8	(h) 17.1	(i) 20.5	(j) 26.6	(k) 19.2	(l) 24.9	(m) 17.8	(n) 23.0	(o) 1.2	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	24.0	16.9	12.1	22.1	15.7	11.2	20.0	59.6	26.6	55.0	24.9	50.7	23.3	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.3	3.5	3.1	-41.2	32.9	3.3	2.6	-43.6	34.8	-45.6	36.4	-47.5	37.9	-49.9	39.8		
			-41.3	23.1	3.1	1.2	-43.5	23.9	-45.3	24.6	-47.1	25.3	-49.3	26.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.2	-25.0	-20.7	-11.4	-1.3	5.2	11.7	14.9	15.3	9.8	-0.4	-14.3	-23.6		
	DBStd	15.36	4.75	5.51	6.10	4.40	4.02	4.68	3.53	3.01	3.98	4.93	7.34	5.96		
	HDD10.0	5296	1086	859	665	340	160	36	2	2	53	324	728	1043		
	HDD18.3	7899	1344	1092	923	589	407	206	117	102	257	582	978	1301		
	CDD10.0	464	0	0	0	0	11	85	154	167	47	1	0	0		
	CDD18.3	27	0	0	0	0	0	6	12	8	1	0	0	0		
	CDH23.3	536	0	0	0	0	13	171	210	135	7	0	0	0		
	CDH26.7	137	0	0	0	0	2	46	65	24	0	0	0	0		
	WSAvg	1.3	1.0	1.1	1.2	1.5	1.7	1.6	1.6	1.4	1.3	1.3	1.2	1.2		
(15) Precipitation	PrecAvg	677	17	11	19	40	77	71	101	103	94	79	38	26		
	PrecMax	879	59	56	70	89	152	138	237	182	250	161	113	83		
	PrecMin	484	0	1	1	13	16	17	27	40	28	15	9	5		
	PrecStd	103	8	11	17	20	36	29	56	39	49	40	26	22		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.1	-3.4	7.1	16.1	25.3	31.0	32.7	29.2	24.3	15.3	3.3	-1.7		
		MCWB	-8.7	-5.8	1.5	7.8	13.2	19.2	21.0	20.8	17.2	8.4	0.0	-2.3		
	2%	DB	-12.5	-6.3	4.0	11.6	22.0	28.2	29.3	26.9	21.1	10.6	0.5	-5.5		
		MCWB	-13.0	-8.1	-0.2	5.3	12.0	17.9	20.3	19.4	15.0	5.8	-1.5	-5.8		
	5%	DB	-15.7	-9.2	1.4	8.8	18.6	25.5	26.2	24.5	18.5	8.1	-0.8	-11.0		
		MCWB	-16.3	-10.5	-2.0	3.4	10.3	16.9	19.3	18.5	13.7	4.9	-2.2	-11.6		
	10%	DB	-17.9	-11.8	-1.0	6.2	14.7	22.2	23.0	21.9	16.2	6.5	-2.6	-14.7		
		MCWB	-18.4	-12.7	-3.7	1.7	8.1	15.1	18.1	17.2	12.3	4.0	-3.8	-15.2		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.8	-5.5	2.1	8.4	14.1	20.6	22.1	22.0	17.9	8.9	1.2	-2.2		
		MCDB	-10.3	-3.7	7.0	15.2	24.6	27.1	29.8	27.1	23.7	13.8	2.9	-1.6		
	2%	WB	-13.6	-8.0	0.1	5.6	12.1	18.6	20.8	20.3	16.1	7.0	-0.9	-5.8		
		MCDB	-13.1	-6.3	3.7	11.1	20.4	26.3	27.4	25.7	19.9	8.9	0.0	-5.4		
	5%	WB	-16.4	-10.5	-1.9	3.9	10.5	17.2	19.6	18.8	14.4	5.7	-2.2	-11.7		
		MCDB	-15.9	-9.3	1.0	8.3	18.2	24.8	25.7	23.4	17.6	7.8	-0.8	-11.1		
	10%	WB	-18.6	-12.6	-3.5	2.0	8.4	15.6	18.1	17.5	12.9	4.2	-3.9	-15.3		
		MCDB	-18.2	-11.7	-1.1	5.6	14.2	21.3	23.2	21.4	15.7	6.1	-2.7	-14.7		
(35) Mean Daily Temperature Range	MDBR		9.5	13.4	15.5	10.2	10.0	12.8	9.5	10.7	10.6	9.2	8.6	7.4		
	5% DB	MCDBR	10.6	14.5	17.4	15.8	21.0	22.0	18.9	17.7	14.8	12.7	5.9	8.5		
		MCWBR	10.0	12.7	13.5	10.1	11.8	12.6	10.8	10.4	8.7	7.9	4.9	8.1		
	5% WB	MCDBR	10.4	14.3	15.7	14.7	19.9	20.3	17.3	15.5	13.5	10.6	5.7	8.4		
		MCWBR	10.0	12.5	12.1	9.5	11.6	11.9	10.4	9.8	8.2	7.0	5.0	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.252	0.285	0.344	0.461	0.515	0.504	0.504	0.440	0.376	0.358	0.288	0.249		
	taud		2.113	2.079	1.959	1.749	1.847	2.007	2.054	2.241	2.354	2.180	2.083	2.057		
	Ebn at Noon		688	786	807	747	735	752	744	774	784	686	612	588		
	Edh at Noon		64	96	138	198	190	164	154	121	94	88	66	55		
(44) All-Sky Solar Radiation	RadAvg		1.12	2.29	3.92	5.15	4.74	5.30	4.59	3.94	3.03	1.87	1.16	0.81		
	RadStd		0.04	0.09	0.19	0.29	0.64	0.54	0.62	0.49	0.33	0.18	0.12	0.03		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page