

SELEMDZA, Russian Federation

WMO: 313380

Lat: 53.133N

Lon: 133.967E

Elev: 682

StdP: 93.40

Time Zone: 9.00 (E09)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -49.3	(c) -47.4	(d) -50.8	(e) 0.0	(f) -49.4	(g) -49.1	(h) 0.0	(i) -47.5	(j) 5.6	(k) -16.8	(l) 3.0	(m) -12.7	(n) 0.0	(o) N/A	(p) 0.707

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	27.0	17.1	25.2	16.6	23.3	15.7	19.0	24.2	18.0	22.8	17.0	21.3	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	13.5	20.8	16.2	12.5	19.7	15.3	11.8	18.9	57.3	24.2	53.9	22.8	50.6	21.4	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.4	3.3	-50.8	29.8	3.0	1.4	-53.0	30.8	-54.7	31.6	-56.4	32.4	-58.6	33.4
			-50.8	22.2	3.0	1.7	-53.0	23.5	-54.7	24.5	-56.4	25.4	-58.6	26.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.1	-34.3	-26.7	-16.7	-3.8	4.8	12.2	15.8	13.5	6.1	-4.7	-20.9	-31.8		
	DBStd	18.25	6.33	6.22	5.88	5.58	4.15	3.68	2.92	2.83	3.93	5.56	6.76	6.42		
	HDD10.0	6645	1373	1027	828	416	169	19	2	3	131	456	927	1296		
	HDD18.3	9299	1632	1261	1086	666	419	184	87	152	368	714	1177	1554		
	CDD10.0	398	0	0	0	0	8	86	180	111	13	0	0	0		
	CDD18.3	9	0	0	0	0	0	2	7	1	0	0	0	0		
	CDH23.3	384	0	0	0	0	8	133	192	51	0	0	0	0		
	CDH26.7	57	0	0	0	0	1	23	28	4	0	0	0	0		
(14) Wind	WSAvg	0.6	0.1	0.4	0.7	1.1	1.1	0.9	0.6	0.6	0.7	0.7	0.4	0.1		
(15) Precipitation	PrecAvg	747	19	13	24	40	77	91	126	122	91	74	43	28		
	PrecMax	898	47	47	63	75	127	163	236	237	152	132	85	75		
	PrecMin	556	3	0	4	12	31	33	39	49	27	24	15	7		
	PrecStd	90	13	10	14	16	29	26	52	40	31	29	21	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.5	-3.5	5.9	14.2	24.4	29.2	29.3	26.8	21.4	11.8	-1.4	-9.4		
		MCWB	-9.7	-5.4	1.4	7.3	13.4	17.7	18.8	17.7	13.7	5.8	-2.7	-10.5		
	2%	DB	-15.7	-7.9	1.4	10.6	21.3	27.0	27.4	24.6	18.8	8.4	-4.6	-13.2		
		MCWB	-16.3	-9.5	-1.9	4.2	11.2	16.2	17.8	17.2	12.7	3.8	-6.0	-13.7		
	5%	DB	-20.4	-11.9	-1.6	8.1	17.9	24.8	25.7	22.5	16.4	5.6	-6.6	-17.1		
		MCWB	-20.8	-13.1	-4.2	2.7	9.8	15.3	17.1	16.1	11.7	2.2	-7.8	-17.4		
	10%	DB	-23.8	-15.1	-4.1	5.7	14.6	22.3	23.9	20.6	14.1	3.5	-9.1	-20.7		
		MCWB	-24.1	-16.0	-6.3	1.3	8.1	13.8	16.8	15.4	10.4	1.3	-10.1	-21.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.7	-5.3	1.5	7.8	14.0	19.5	20.8	20.1	15.2	6.5	-2.6	-10.8		
		MCDB	-8.4	-3.4	5.4	13.0	23.3	26.9	25.2	23.9	18.5	11.0	-1.5	-10.0		
	2%	WB	-16.2	-9.4	-1.8	4.8	12.3	17.5	19.4	18.5	13.9	4.3	-5.7	-13.9		
		MCDB	-15.6	-7.8	1.0	9.4	18.8	24.2	24.7	22.3	17.1	7.2	-4.7	-13.2		
	5%	WB	-20.8	-13.2	-4.1	3.1	10.5	16.2	18.5	17.2	12.4	2.9	-7.9	-17.5		
		MCDB	-20.4	-12.0	-1.6	7.4	16.6	21.8	23.7	20.8	16.0	5.1	-6.7	-17.1		
	10%	WB	-24.1	-15.9	-6.3	1.6	8.7	15.0	17.7	16.1	10.6	1.4	-10.0	-21.1		
		MCDB	-23.8	-15.1	-4.0	5.4	14.1	20.4	22.2	19.5	13.5	3.3	-9.1	-20.8		
(35) Mean Daily Temperature Range	MDBR		16.9	21.3	21.9	15.7	14.7	16.7	14.4	13.5	13.5	13.6	15.6	14.7		
	5% DB	MCDBR	15.2	20.6	21.9	18.3	22.9	22.6	19.4	18.3	17.4	16.8	14.5	13.8		
		MCWBR	14.7	18.9	18.2	12.3	13.5	12.3	10.7	11.2	11.1	12.3	13.3	13.6		
	5% WB	MCDBR	15.0	20.3	20.8	17.0	20.0	17.4	15.3	14.8	13.8	16.2	13.7	13.8		
		MCWBR	14.5	18.7	17.2	11.6	12.1	10.3	9.3	9.7	9.1	12.0	12.6	13.4		
(40) Clear-Sky Solar Irradiance	taub		0.237	0.270	0.327	0.438	0.487	0.455	0.445	0.392	0.351	0.344	0.276	0.234		
	taud		2.164	2.106	1.968	1.779	1.896	2.115	2.194	2.350	2.395	2.158	2.083	2.104		
	Ebn at Noon		754	828	838	778	764	800	801	830	823	718	662	668		
	Edh at Noon		65	96	139	194	182	148	135	109	92	93	71	57		
(44) All-Sky Solar Radiation	RadAvg		1.33	2.50	4.16	5.29	4.95	5.39	4.90	4.13	3.10	1.95	1.33	1.00		
	RadStd		0.04	0.08	0.17	0.35	0.56	0.54	0.46	0.41	0.31	0.18	0.11	0.04		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page