

POYARKOVO, Russian Federation

WMO: 315870

Lat: 49.617N

Lon: 128.650E

Elev: 376

StdP: 14.50

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.3	-28.4	-36.7	0.7	-31.9	-32.8	0.9	-27.8	14.0	5.5	12.2	2.3	0.8	290	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	87.5	69.9	84.3	69.2	81.5	68.2	74.0	82.4	72.2	80.6	70.6	78.4	5.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	117.5	78.6	69.6	110.2	76.5	67.9	104.0	75.0	38.0	82.6	36.3	80.7	34.9	78.2	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.1	11.3	DB	-37.3	93.2	4.5	3.3	-40.5	95.6	-43.2	97.5	-45.7	99.4	-48.9	101.8	(4)
(5)			WB	-37.4	76.9	4.4	2.1	-40.6	78.4	-43.2	79.6	-45.7	80.8	-48.9	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.8	-10.4	-1.3	17.6	40.0	55.0	66.0	71.2	67.4	55.3	37.8	13.1	-7.6
	DBStd	30.25	8.54	9.40	11.84	8.18	7.41	6.12	4.40	5.26	7.08	8.70	12.07	8.96
	HDD50	7971	1872	1437	1004	317	33	0	0	0	29	387	1108	1784
	HDD65	11781	2337	1857	1469	751	322	59	5	34	298	842	1558	2249
	CDD50	2078	0	0	0	17	187	479	657	539	189	10	0	0
	CDD65	412	0	0	0	0	11	88	197	108	8	0	0	0
	CDH74	3421	0	0	0	15	253	879	1425	746	100	3	0	0
	CDH80	938	0	0	0	2	65	295	409	154	13	0	0	0
Wind	WSAvg	4.1	3.0	3.4	4.6	5.7	5.2	4.3	3.6	3.3	4.0	4.5	4.1	3.2
Precipitation	PrecAvg	21.3	0.4	0.3	0.5	1.0	2.0	3.1	5.0	4.3	2.4	1.1	0.6	0.5
	PrecMax	35.3	1.3	1.1	1.6	4.4	4.6	6.5	8.9	15.8	5.0	2.5	1.2	1.6
	PrecMin	15.7	0.0	0.0	0.0	0.0	0.5	0.7	1.9	1.1	0.3	0.2	0.1	0.1
	PrecStd	4.2	0.3	0.2	0.4	0.9	1.1	1.5	2.1	3.0	1.3	0.7	0.3	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	31.6	51.1	76.0	86.4	92.8	91.8	87.1	81.8	69.5	47.1	22.5
		MCWB	14.3	26.7	38.9	52.5	59.8	68.8	72.3	73.1	65.2	52.5	38.9	20.4
	2%	DB	10.4	25.3	45.2	66.3	81.0	87.5	87.9	84.0	76.7	61.8	39.6	14.4
		MCWB	8.5	21.7	35.8	47.8	58.4	67.4	72.5	71.5	62.1	48.6	33.4	12.7
	5%	DB	6.6	19.7	40.1	60.5	75.6	82.9	84.6	81.3	73.1	56.3	34.7	10.2
		MCWB	5.1	16.8	32.5	45.0	55.8	66.2	71.6	69.7	60.6	45.4	30.3	8.8
	10%	DB	3.1	14.5	35.6	55.5	70.6	78.9	81.6	78.3	68.9	51.8	30.9	6.2
		MCWB	1.9	12.2	30.3	42.1	53.9	64.9	70.5	68.1	58.3	42.9	27.6	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	27.5	40.0	53.9	62.8	73.3	77.1	76.1	68.7	54.3	39.6	20.4
		MCDB	16.3	31.8	49.5	73.0	78.3	85.0	85.7	83.4	76.7	66.9	46.9	22.6
	2%	WB	8.7	22.0	36.3	48.8	60.2	70.4	74.7	73.6	64.7	50.3	33.9	12.7
		MCDB	10.4	25.2	43.7	64.0	74.7	81.5	82.9	81.5	73.0	58.5	38.7	14.1
	5%	WB	5.2	16.9	33.2	45.8	58.1	68.4	73.0	71.5	62.6	47.0	30.7	8.8
		MCDB	6.5	19.6	39.0	58.3	71.6	78.7	81.5	78.4	70.2	54.8	34.3	10.2
	10%	WB	2.0	12.3	30.4	43.1	55.8	66.5	71.6	69.6	60.1	43.9	27.5	5.0
		MCDB	3.1	14.4	35.6	54.0	68.4	76.1	79.7	76.1	66.7	50.9	31.0	6.1
Mean Daily Temperature Range	5% DB	MDBR	20.4	23.9	22.3	21.5	22.6	20.2	17.5	18.0	21.8	19.9	18.5	18.3
		MCDBR	21.8	27.1	23.7	31.1	32.3	27.9	23.2	22.6	28.4	28.5	21.3	19.7
		MCWBR	20.3	23.5	15.3	16.2	14.0	11.4	9.8	11.1	14.5	16.3	15.6	18.0
	5% WB	MCDBR	21.7	26.7	22.0	28.0	26.9	22.5	19.3	19.1	23.4	24.7	19.8	19.3
		MCWBR	20.2	23.2	14.5	15.3	12.8	10.6	9.7	10.3	12.9	15.3	14.8	17.7
Clear-Sky Solar Irradiance	taub	0.283	0.312	0.389	0.525	0.578	0.515	0.496	0.444	0.408	0.410	0.338	0.289	
	taud	2.118	2.041	1.897	1.749	1.711	1.967	2.071	2.200	2.209	2.040	2.096	2.085	
	Ebn at Noon	234	256	251	228	222	240	243	251	246	214	206	209	
	Edh at Noon	26	36	50	66	71	56	49	42	37	36	27	23	
All-Sky Solar Radiation	RadAvg	561	953	1423	1556	1714	1844	1723	1528	1227	804	527	436	
	RadStd	15	21	89	165	138	227	129	105	113	51	36	24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page