

DALNERECHENSK, Russian FederationWMO: **318730**Lat: **45.8796N**Lon: **133.7245E**Elev: **343**StdP: **14.51**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-14.8	-24.8	1.4	-16.1	-21.8	1.7	-12.9	16.2	7.3	14.4	7.0	4.1	260	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	84.4	72.2	82.0	70.7	79.7	69.2	74.7	81.2	73.0	79.1	71.5	77.2	6.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.7	122.8	78.4	71.0	115.8	76.8	69.4	109.4	75.4	38.7	81.5	37.0	79.4	35.6	77.4	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.0	14.5	12.7	DB	-22.9	89.1	4.8	3.7	-26.4	91.8	-29.3	94.0	-32.0	96.1	-35.5	98.8	(4)
(5)			WB	-23.2	77.5	4.8	2.1	-26.7	79.0	-29.5	80.3	-32.2	81.5	-35.7	83.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.8	-0.7	7.7	23.6	42.7	56.2	65.3	71.3	69.3	58.5	43.4	22.3	3.7
	DBStd	26.54	8.06	8.99	10.18	7.99	6.64	5.69	4.29	4.86	6.29	8.48	11.71	9.08
	HDD50	6355	1572	1185	819	247	18	0	0	0	8	237	833	1436
	HDD65	10025	2037	1605	1284	670	281	65	5	17	209	669	1282	1901
	CDD50	2253	0	0	0	27	212	458	661	599	263	33	0	0
	CDD65	448	0	0	0	0	9	73	201	151	14	0	0	0
	CDH74	2560	0	0	0	6	102	478	1145	755	73	1	0	0
	CDH80	459	0	0	0	0	12	86	244	112	5	0	0	0
Wind	WSAvg	5.9	5.5	6.0	6.6	7.2	6.7	5.4	4.9	4.7	5.1	6.4	6.4	5.6
Precipitation	PrecAvg	25.1	0.5	0.4	0.7	1.7	2.2	3.3	4.4	4.7	3.2	2.0	1.1	0.7
	PrecMax	35.7	1.3	1.6	1.9	5.2	5.1	7.5	10.7	10.5	7.5	4.6	2.5	1.5
	PrecMin	14.5	0.0	0.0	0.0	0.4	0.1	0.3	0.8	0.7	0.5	0.0	0.3	0.1
	PrecStd	4.4	0.3	0.4	0.5	0.9	1.2	1.7	2.3	2.6	1.6	1.3	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.3	37.8	52.2	73.3	82.0	86.3	88.5	85.7	80.0	70.7	55.4	36.2
		MCWB	25.0	32.0	41.0	55.1	63.0	70.6	75.0	75.0	67.8	56.7	46.8	33.6
	2%	DB	19.8	32.8	46.3	67.3	76.9	82.3	85.2	83.1	75.9	65.5	48.6	28.4
		MCWB	17.5	28.3	37.4	51.3	60.2	67.9	73.3	72.7	65.2	53.6	42.0	26.0
	5%	DB	15.0	27.4	42.1	61.5	73.1	79.4	82.6	80.7	72.8	60.8	43.5	22.8
		MCWB	13.0	23.7	34.7	47.9	57.9	66.9	72.0	71.0	63.1	50.7	38.3	20.7
	10%	DB	11.2	22.0	38.1	56.7	69.2	76.2	80.2	78.3	69.8	57.0	38.7	17.0
		MCWB	9.5	19.0	32.3	45.1	55.8	65.3	70.6	69.4	61.4	49.3	34.5	15.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.4	33.2	42.3	55.8	64.7	73.2	78.0	77.1	70.5	59.0	47.8	34.0
		MCDB	27.6	36.6	50.1	71.5	78.6	83.2	85.4	82.9	76.4	67.8	54.4	36.1
	2%	WB	17.8	28.4	38.0	52.3	61.7	70.6	75.3	74.7	67.7	55.5	42.7	26.4
		MCDB	19.9	32.7	45.0	65.1	74.5	79.3	82.0	80.4	73.3	61.7	47.5	28.2
	5%	WB	13.1	23.6	35.3	48.9	59.3	68.5	73.6	72.8	65.1	53.0	38.4	20.7
		MCDB	15.0	27.3	40.9	59.6	70.2	76.7	80.1	78.0	70.6	59.6	42.8	22.9
	10%	WB	9.6	19.1	32.8	46.1	57.0	66.4	72.0	71.3	62.7	50.0	34.7	15.2
		MCDB	11.2	22.0	37.5	55.5	66.8	74.2	78.0	76.2	68.4	56.3	38.4	17.0
Mean Daily Temperature Range	5% DB	MDBR	16.0	17.9	16.9	18.2	18.2	16.7	14.4	14.8	19.0	19.1	15.8	15.2
		MCDBR	19.4	20.5	19.2	26.2	24.8	21.2	18.1	17.8	22.3	24.3	19.4	18.6
		MCWBR	17.4	17.2	12.2	14.7	12.2	10.6	8.5	8.7	11.9	14.3	14.0	17.3
	5% WB	MCDBR	19.5	20.0	17.7	24.2	21.9	18.6	15.8	14.4	18.2	21.7	18.9	18.8
		MCWBR	17.7	17.1	12.1	14.3	11.8	10.6	8.5	8.0	10.9	14.1	14.5	17.6
Clear-Sky Solar Irradiance	taub		0.310	0.357	0.439	0.550	0.570	0.545	0.508	0.470	0.426	0.449	0.389	0.328
	taud		2.063	1.919	1.801	1.722	1.749	1.896	2.045	2.146	2.177	1.959	2.014	2.026
	Ebn at Noon		239	247	242	226	228	235	243	248	247	213	203	213
	Edh at Noon		31	44	58	69	70	61	52	45	40	43	33	30
All-Sky Solar Radiation	RadAvg		664	1023	1383	1479	1655	1765	1614	1477	1278	890	607	514
	RadStd		36	46	95	152	135	209	157	102	110	67	47	30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page