

TERNEY, Russian Federation

WMO: 319090

Lat: 45.0571N

Lon: 136.6073E

Elev: 203

StdP: 14.59

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-1.8	-22.0	1.6	-2.5	-19.1	1.9	0.1	33.0	7.2	30.4	3.2	17.2	290	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	80.8	68.0	76.8	66.4	73.4	65.2	70.9	76.9	68.9	74.0	67.0	71.5	6.2	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	107.0	73.9	66.9	99.8	71.7	65.3	94.2	69.6	35.0	77.1	33.3	74.1	31.8	71.9	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.1	23.2	20.3	-8.9	88.9	4.6	4.3	-12.2	92.0	-14.9	94.5	-17.5	96.9	-20.8	100.0		
			-9.9	74.3	4.3	2.3	-13.0	76.0	-15.5	77.3	-17.9	78.6	-21.1	80.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.0	11.9	17.9	28.4	39.6	47.6	54.8	62.8	66.5	59.2	46.2	29.3	14.8		
	DBStd	19.55	7.34	7.37	7.00	5.43	6.29	5.44	5.29	4.81	5.31	6.18	9.19	7.78		
	HDD50	5062	1182	898	670	315	125	11	0	0	3	148	620	1090		
	HDD65	9249	1647	1318	1134	761	541	312	106	37	185	583	1070	1555		
	CDD50	1425	0	0	0	4	49	154	398	511	279	30	0	0		
	CDD65	139	0	0	0	0	1	5	38	84	11	0	0	0		
	CDH74	684	0	0	0	0	22	57	184	366	53	2	0	0		
	CDH80	152	0	0	0	0	3	15	48	81	5	0	0	0		
	WSAvg	7.6	13.2	11.1	8.8	6.5	5.4	3.8	3.2	3.6	5.2	7.6	10.6	12.8		
	PrecAvg	32.6	0.8	0.7	1.1	2.4	3.2	3.7	4.4	5.0	5.3	2.8	2.0	0.9		
	PrecMax	45.3	2.5	2.9	3.1	7.4	6.1	13.5	8.6	11.9	11.2	8.0	6.9	2.4		
	PrecMin	20.7	0.0	0.0	0.0	0.1	0.4	0.7	0.9	0.7	1.1	0.1	0.0	0.0		
	PrecStd	7.7	0.7	0.7	0.8	1.9	1.5	2.8	2.0	3.0	3.0	2.0	1.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	41.6	53.5	67.3	77.2	81.1	85.8	86.9	80.1	69.0	55.4	38.3		
		MCWB	27.0	32.4	40.6	49.7	56.0	65.7	71.0	70.9	64.9	54.1	43.7	33.4		
	2%	DB	29.1	35.9	46.8	58.9	69.3	72.8	79.0	81.8	74.6	63.5	50.3	33.9		
		MCWB	25.4	29.2	36.6	44.8	52.8	62.0	69.4	69.2	62.1	52.4	42.2	29.6		
	5%	DB	26.3	32.4	42.5	53.9	63.4	66.9	74.1	77.8	71.3	60.1	45.9	30.5		
		MCWB	22.3	27.2	34.0	42.2	50.6	59.3	67.0	68.2	61.1	50.7	39.3	26.5		
	10%	DB	23.2	29.4	38.8	49.7	58.2	62.9	70.3	74.4	68.6	56.9	42.5	26.7		
		MCWB	19.4	24.7	31.7	40.0	48.7	57.5	65.4	67.4	60.2	48.9	37.1	22.7		
	0.4%	WB	28.9	33.7	41.0	50.6	58.4	67.2	73.2	74.2	68.4	58.0	47.0	34.6		
		MCDB	31.0	39.1	51.9	65.1	70.7	75.6	83.2	82.0	73.6	64.2	51.9	37.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	25.7	30.4	37.2	45.8	54.5	63.4	70.0	71.7	65.5	55.2	43.4	30.0		
		MCDB	28.9	34.9	44.9	56.7	66.0	70.9	77.0	77.5	70.2	60.1	48.3	33.4		
	5%	WB	22.4	27.5	34.7	43.1	52.1	60.3	67.6	70.0	63.8	52.8	40.5	26.2		
		MCDB	26.0	32.2	40.8	51.7	61.1	65.8	72.6	74.9	68.3	57.5	45.5	30.5		
	10%	WB	19.5	24.8	32.7	41.1	49.6	57.7	65.9	68.3	62.1	50.5	37.1	22.8		
		MCDB	23.3	29.2	37.2	47.6	56.1	62.0	69.6	72.9	66.9	55.2	42.2	26.7		
	5% DB	MDBR	14.5	16.8	16.1	15.8	14.3	11.8	10.0	12.3	17.4	18.0	15.0	13.4		
		MCDBR	17.3	19.2	20.4	24.4	25.3	21.0	18.0	18.9	20.9	23.2	19.6	17.3		
		MCWBR	14.5	15.0	13.0	13.5	12.2	11.8	10.0	9.0	11.0	14.4	14.1	14.4		
		MCWBR	17.3	18.7	18.5	21.8	22.3	19.0	15.4	15.3	15.9	19.9	18.7	17.0		
	5% WB	MCWBR	14.8	15.0	12.6	12.9	12.0	11.5	9.3	8.5	10.0	14.1	14.4	14.7		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.365	0.438	0.529	0.555	0.538	0.494	0.459	0.410	0.412	0.364	0.321		
	taud		2.218	2.030	1.891	1.778	1.804	1.943	2.136	2.243	2.292	2.120	2.162	2.164		
	Ebn at Noon		250	249	245	233	233	238	248	252	255	231	221	226		
	Edh at Noon		28	41	54	66	66	58	47	41	36	37	30	27		
(44) All-Sky Solar Radiation	RadAvg		624	942	1286	1479	1544	1562	1465	1437	1301	949	643	505		
	RadStd		42	59	101	142	157	215	149	98	112	82	58	39		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page