

TERNEY, Russian Federation

WMO: 319090

Lat: 45.0571N

Lon: 136.6073E

Elev: 62

StdP: 100.58

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.4	-18.8	-30.0	0.2	-19.2	-28.4	0.3	-17.7	14.8	-13.8	13.6	-16.0	7.7	290	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	27.1	20.0	24.9	19.1	23.0	18.4	21.6	24.9	20.5	23.3	19.5	21.9	2.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.3	23.3	19.4	14.3	22.0	18.5	13.5	20.9	63.5	25.1	59.5	23.4	56.0	22.1	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.1	10.4	9.1	-22.7	31.6	2.6	2.4	-24.6	33.3	-26.1	34.7	-27.5	36.1	-29.3	37.8		
			-23.3	23.5	2.4	1.3	-25.0	24.4	-26.4	25.2	-27.7	25.9	-29.5	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-11.2	-7.8	-2.0	4.2	8.6	12.6	17.1	19.2	15.1	7.9	-1.5	-9.5
	DBStd	10.86	4.08	4.10	3.89	3.02	3.49	3.02	2.94	2.67	2.95	3.43	5.10	4.32
	HDD10.0	2812	657	499	372	175	69	6	0	0	2	82	344	606
	HDD18.3	5138	915	732	630	423	301	173	59	21	103	324	594	864
	CDD10.0	792	0	0	0	2	27	86	221	284	155	17	0	0
	CDD18.3	77	0	0	0	0	1	3	21	47	6	0	0	0
	CDH23.3	380	0	0	0	0	12	32	102	203	29	1	0	0
	CDH26.7	84	0	0	0	0	2	8	27	45	3	0	0	0
Wind	WSAvg	3.4	5.9	5.0	3.9	2.9	2.4	1.7	1.4	1.6	2.3	3.4	4.7	5.7
Precipitation	PrecAvg	828	20	18	29	62	81	95	113	127	135	71	50	24
	PrecMax	1151	64	74	80	187	155	344	218	303	285	203	175	62
	PrecMin	526	0	0	1	2	9	17	24	18	27	3	1	0
	PrecStd	196	17	18	20	49	39	70	52	77	76	51	47	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.3	5.3	11.9	19.6	25.1	27.3	29.9	30.5	26.7	20.5	13.0	3.5
		MCWB	-2.8	0.2	4.8	9.8	13.3	18.7	21.7	21.6	18.3	12.3	6.5	0.8
	2%	DB	-1.6	2.2	8.2	15.0	20.7	22.7	26.1	27.7	23.6	17.5	10.2	1.1
		MCWB	-3.7	-1.5	2.5	7.1	11.5	16.7	20.8	20.7	16.7	11.3	5.7	-1.4
	5%	DB	-3.2	0.2	5.8	12.2	17.4	19.4	23.4	25.5	21.8	15.6	7.7	-0.8
		MCWB	-5.4	-2.6	1.1	5.6	10.4	15.2	19.5	20.1	16.2	10.4	4.1	-3.1
	10%	DB	-4.9	-1.4	3.8	9.8	14.5	17.2	21.3	23.6	20.3	13.8	5.8	-3.0
		MCWB	-7.0	-4.1	-0.1	4.5	9.3	14.2	18.6	19.7	15.6	9.4	2.8	-5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.7	0.9	5.0	10.3	14.7	19.6	22.9	23.4	20.2	14.4	8.3	1.4
		MCDB	-0.6	4.0	11.0	18.4	21.5	24.2	28.4	27.8	23.1	17.9	11.1	2.8
	2%	WB	-3.5	-0.9	2.9	7.6	12.5	17.5	21.1	22.0	18.6	12.9	6.4	-1.1
		MCDB	-1.7	1.6	7.2	13.7	18.9	21.6	25.0	25.3	21.2	15.6	9.0	0.8
	5%	WB	-5.3	-2.5	1.5	6.2	11.1	15.7	19.8	21.1	17.6	11.6	4.7	-3.2
		MCDB	-3.3	0.1	4.9	10.9	16.2	18.8	22.5	23.8	20.1	14.2	7.5	-0.8
	10%	WB	-7.0	-4.0	0.4	5.1	9.8	14.3	18.8	20.2	16.7	10.3	2.9	-5.1
		MCDB	-4.8	-1.5	2.9	8.7	13.4	16.7	20.9	22.7	19.4	12.9	5.7	-3.0
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.3	8.9	8.8	8.0	6.5	5.6	6.8	9.7	10.0	8.4	7.4
		MCDBR	9.6	10.7	11.3	13.5	14.1	11.6	10.0	10.5	11.6	12.9	10.9	9.6
		MCWBR	8.1	8.3	7.2	7.5	6.8	6.5	5.5	5.0	6.1	8.0	7.8	8.0
	5% WB	MCDBR	9.6	10.4	10.3	12.1	12.4	10.6	8.6	8.5	8.9	11.1	10.4	9.5
		MCWBR	8.2	8.4	7.0	7.2	6.6	6.4	5.2	4.7	5.6	7.8	8.0	8.2
Clear-Sky Solar Irradiance	taub	0.305	0.365	0.438	0.529	0.555	0.538	0.494	0.459	0.410	0.412	0.364	0.321	
	taud	2.218	2.030	1.891	1.778	1.804	1.943	2.136	2.243	2.292	2.120	2.162	2.164	
	Ebn at Noon	787	786	773	736	734	750	781	795	804	727	697	712	
	Edh at Noon	87	128	170	208	209	183	149	129	113	117	93	84	
All-Sky Solar Radiation	RadAvg	1.97	2.97	4.05	4.66	4.87	4.92	4.62	4.53	4.10	2.99	2.03	1.59	
	RadStd	0.13	0.18	0.32	0.45	0.49	0.68	0.47	0.31	0.35	0.26	0.18	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page