

POLTAVKA PRIMORSKY, Russian Federation

WMO: 319170

Lat: 44.0262N

Lon: 131.3248E

Elev: 358

StdP: 14.51

Time Zone: 10.00 (E10)

Period: 82-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-11.7	-22.1	1.6	-13.3	-18.9	2.0	-8.2	22.7	6.8	18.6	7.0	1.2	70	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.6	87.2	72.5	84.0	70.3	81.1	68.4	75.7	83.4	73.8	81.0	71.7	77.4	6.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	126.1	80.4	71.3	117.0	77.9	69.5	110.0	76.4	39.6	83.6	37.7	81.6	35.8	77.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.0	13.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.0	5.4	13.7	27.5	44.5	55.8	62.8	69.0	71.0	58.8	44.9	26.6	10.8		
	DBStd	23.53	8.04	7.88	8.05	6.63	6.12	5.46	4.93	4.87	6.33	7.99	8.28	8.27		
	HDD50	5426	1384	1017	697	188	18	0	0	0	8	197	703	1214		
	HDD65	9137	1849	1437	1162	617	288	105	18	6	199	624	1153	1679		
	CDD50	2157	0	0	0	22	198	384	590	652	273	38	0	0		
	CDD65	393	0	0	0	1	4	38	143	193	14	0	0	0		
	CDH74	3185	0	0	0	30	205	483	896	1445	116	10	0	0		
	CDH80	858	0	0	0	3	33	131	247	433	10	1	0	0		
(14) Wind	WSAvg	4.6	4.2	4.9	5.3	6.4	5.6	4.4	4.1	3.5	3.9	4.5	4.9	4.0		
(15) Precipitation	PrecAvg	20.7	0.3	0.2	0.4	0.9	2.4	3.0	4.4	4.1	2.4	1.7	0.6	0.4		
	PrecMax	30.2	1.6	1.1	1.1	2.0	4.8	6.6	8.9	8.2	7.0	4.0	1.5	1.6		
	PrecMin	10.7	0.0	0.0	0.0	0.1	0.4	1.1	0.9	0.6	0.2	0.2	0.1	0.0		
	PrecStd	5.0	0.4	0.3	0.4	0.6	1.1	1.3	2.2	2.0	2.0	0.9	0.4	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	41.4	58.6	78.2	83.2	89.8	91.0	92.0	81.9	74.5	54.5	37.2		
		MCWB	27.9	32.9	43.7	53.1	57.2	64.9	75.7	75.9	67.4	57.3	42.5	31.6		
	2%	DB	27.4	35.7	51.4	70.8	79.6	83.7	86.1	87.5	77.6	68.9	49.0	32.6		
		MCWB	22.6	29.7	39.0	50.5	57.6	64.8	72.8	74.5	65.8	54.1	39.2	28.9		
	5%	DB	22.3	31.9	46.0	64.7	75.5	79.8	82.6	84.7	73.9	65.0	44.3	28.6		
		MCWB	18.5	27.2	35.7	47.0	56.2	64.7	71.5	72.6	62.8	51.6	35.7	24.9		
	10%	DB	18.3	28.3	41.8	60.1	71.4	75.6	79.0	81.9	70.9	60.3	39.6	24.0		
		MCWB	15.1	23.9	33.3	45.0	53.9	62.8	70.7	71.1	60.8	49.2	32.9	20.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	34.0	44.5	54.6	63.4	69.7	78.6	78.1	71.0	59.7	44.1	32.8		
		MCDB	32.7	38.8	57.0	74.4	76.8	80.8	83.8	87.5	79.0	71.5	51.2	34.7		
	2%	WB	22.7	30.6	39.7	51.0	59.6	67.5	75.7	76.3	67.1	55.7	39.9	29.0		
		MCDB	27.1	34.7	49.3	67.3	72.2	78.3	81.9	85.4	73.7	64.8	48.2	33.2		
	5%	WB	18.6	27.6	36.7	48.3	57.7	65.8	73.7	74.5	64.9	53.2	36.5	24.8		
		MCDB	22.1	32.1	44.7	62.1	72.1	76.5	80.2	82.5	71.8	62.3	43.1	28.5		
	10%	WB	15.1	23.7	33.6	45.7	55.7	64.1	71.5	72.7	63.0	50.6	33.7	21.0		
		MCDB	18.2	28.3	41.4	58.2	68.8	73.7	77.0	79.7	68.6	58.9	39.3	24.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.4	23.0	23.2	26.0	25.0	19.7	15.9	18.6	22.4	24.9	21.0	20.7		
		MCDBR	25.9	27.3	29.3	38.0	33.9	29.2	23.3	23.0	25.5	32.9	28.7	24.1		
		MCWBR	21.7	21.6	18.5	20.4	15.4	13.1	11.1	10.4	13.7	18.0	19.7	20.1		
	5% WB	MCDBR	25.8	27.1	27.9	35.0	28.9	24.0	18.2	20.4	21.1	30.0	27.4	23.3		
		MCWBR	21.8	21.5	17.9	19.5	14.6	12.6	10.2	10.6	12.0	18.0	19.9	19.8		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.385	0.475	0.583	0.602	0.579	0.542	0.496	0.447	0.465	0.397	0.346		
	taud		2.073	1.940	1.802	1.649	1.673	1.805	1.960	2.079	2.118	1.934	2.016	2.047		
	Ebn at Noon		238	243	235	220	222	228	236	242	244	213	208	216		
	Edh at Noon		33	45	60	75	76	67	56	49	43	45	35	31		
(44) All-Sky Solar Radiation	RadAvg		722	1063	1373	1455	1591	1665	1505	1453	1338	984	678	591		
	RadStd		50	54	105	129	156	195	168	134	111	72	54	33		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page