

POLTAVKA PRIMORSKY, Russian Federation

WMO: 319170

Lat: 44.0262N

Lon: 131.3248E

Elev: 109

StdP: 100.02

Time Zone: 10.00 (E10)

Period: 82-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.5	(c) -24.3	(d) -30.1	(e) 0.2	(f) -25.1	(g) -28.3	(h) 0.3	(i) -22.3	(j) 10.1	(k) -14.0	(l) 8.3	(m) -13.9	(n) 0.5	(o) 70	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.3	(c) 30.6	(d) 22.5	(e) 28.9	(f) 21.3	(g) 27.3	(h) 20.2	(i) 24.3	(j) 28.6	(k) 23.2	(l) 27.2	(m) 22.0	(n) 25.2	(o) 3.0	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	18.0	26.9	21.8	16.7	25.5	20.8	15.7	24.7	74.2	28.6	69.9	27.6	65.5	25.2	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.4	(b) 7.1	(c) 6.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 8.4	(b) 7.1	(c) 6.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-14.8	-10.2	-2.5	6.9	13.2	17.1	20.6	21.7	14.9	7.1	-3.0	-11.8		
	DBStd	13.07	4.47	4.38	4.47	3.68	3.40	3.03	2.74	2.71	3.51	4.44	4.60	4.60		
	HDD10.0	3014	769	565	387	104	10	0	0	0	4	109	391	674		
	HDD18.3	5076	1027	798	646	343	160	58	10	3	111	347	641	933		
	CDD10.0	1198	0	0	0	12	110	213	328	362	152	21	0	0		
	CDD18.3	218	0	0	0	1	2	21	79	107	8	0	0	0		
	CDH23.3	1769	0	0	0	17	114	268	498	803	64	6	0	0		
	CDH26.7	477	0	0	0	2	18	73	137	241	6	1	0	0		
	WSAvg	2.1	1.9	2.2	2.4	2.9	2.5	2.0	1.8	1.5	1.7	2.0	2.2	1.8		
	PrecAvg	525	8	6	10	22	61	76	111	104	60	43	14	10		
(15) Precipitation	PrecMax	767	41	28	28	51	121	167	227	209	177	102	39	41		
	PrecMin	272	0	0	0	2	11	27	24	14	6	6	2	0		
	PrecStd	126	11	7	9	14	28	32	56	52	50	24	10	11		
	PrecStd	126	11	7	9	14	28	32	56	52	50	24	10	11		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	5.2	14.8	25.7	28.5	32.1	32.8	33.3	27.7	23.6	12.5	2.9		
		MCWB	-2.3	0.5	6.5	11.7	14.0	18.3	24.3	24.4	19.7	14.1	5.8	-0.2		
	2%	DB	-2.6	2.0	10.8	21.5	26.4	28.7	30.1	30.8	25.3	20.5	9.4	0.4		
		MCWB	-5.2	-1.3	3.9	10.3	14.2	18.2	22.6	23.6	18.8	12.3	4.0	-1.7		
	5%	DB	-5.4	-0.1	7.8	18.2	24.2	26.5	28.1	29.3	23.3	18.3	6.9	-1.9		
		MCWB	-7.5	-2.6	2.0	8.3	13.4	18.2	21.9	22.5	17.1	10.9	2.1	-4.0		
	10%	DB	-7.6	-2.0	5.5	15.6	21.9	24.2	26.1	27.7	21.6	15.7	4.2	-4.4		
		MCWB	-9.4	-4.5	0.7	7.2	12.2	17.1	21.5	21.7	16.0	9.6	0.5	-6.2		
	0.4%	WB	-2.3	1.1	6.9	12.5	17.4	20.9	25.9	25.6	21.7	15.4	6.7	0.4		
		MCDB	0.4	3.8	13.9	23.6	24.9	27.1	28.8	30.8	26.1	21.9	10.7	1.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-5.2	-0.8	4.3	10.6	15.3	19.7	24.3	24.6	19.5	13.2	4.4	-1.7		
		MCDB	-2.7	1.5	9.6	19.6	22.4	25.7	27.7	29.7	23.2	18.2	9.0	0.7		
	5%	WB	-7.4	-2.4	2.6	9.1	14.3	18.8	23.1	23.6	18.3	11.8	2.5	-4.0		
		MCDB	-5.5	0.0	7.1	16.7	22.3	24.7	26.8	28.1	22.1	16.8	6.2	-1.9		
	10%	WB	-9.4	-4.6	0.9	7.6	13.2	17.8	21.9	22.6	17.2	10.3	1.0	-6.1		
		MCDB	-7.7	-2.0	5.2	14.6	20.4	23.2	25.0	26.5	20.4	14.9	4.1	-4.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.8	12.9	14.5	13.9	11.0	8.8	10.3	12.4	13.8	11.7	11.5		
		MCDBR	14.4	15.2	16.3	21.1	18.8	16.2	12.9	12.8	14.2	18.3	16.0	13.4		
		MCWBR	12.1	12.0	10.3	11.4	8.5	7.3	6.2	5.8	7.6	10.0	10.9	11.2		
		MCDBR	14.3	15.1	15.5	19.5	16.1	13.3	10.1	11.3	11.7	16.7	15.2	13.0		
	5% WB	MCWBR	12.1	11.9	9.9	10.9	8.1	7.0	5.6	5.9	6.7	10.0	11.1	11.0		
		MCWBR	12.1	11.9	9.9	10.9	8.1	7.0	5.6	5.9	6.7	10.0	11.1	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.385	0.475	0.583	0.602	0.579	0.542	0.496	0.447	0.465	0.397	0.346		
	taud		2.073	1.940	1.802	1.649	1.673	1.805	1.960	2.079	2.118	1.934	2.016	2.047		
	Ebn at Noon		751	767	741	695	700	720	743	764	769	671	657	682		
	Edh at Noon		104	143	188	238	239	210	178	153	136	143	111	97		
(44) All-Sky Solar Radiation	RadAvg		2.28	3.35	4.33	4.59	5.02	5.25	4.75	4.58	4.22	3.10	2.14	1.86		
	RadStd		0.16	0.17	0.33	0.41	0.49	0.61	0.53	0.42	0.35	0.23	0.17	0.10		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page