

ZHURAVLEVKA, Russian Federation

WMO: 319420

Lat: **44.750N**Lon: **134.467E**Elev: **558**StdP: **14.40**Time Zone: **10.00 (E10)**Period: **82-97**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.0	-27.7	-36.4	0.7	-31.8	-31.9	0.9	-27.6	14.1	2.4	12.2	3.8	0.1	50	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	86.8	71.6	83.5	69.7	80.5	68.1	74.7	83.6	72.7	80.1	70.8	77.4	4.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	120.3	79.0	70.1	113.1	77.3	68.5	106.7	75.2	38.7	83.9	36.8	80.0	35.2	77.6	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	11.9	9.5	DB	-38.7	92.3	5.8	3.5	-42.8	94.7	-46.3	96.8	-49.5	98.7	-53.8	101.2	(4)
(5)			WB	-38.1	78.6	5.6	3.5	-42.2	81.1	-45.4	83.1	-48.5	85.1	-52.6	87.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.1	-6.3	3.3	20.6	41.5	53.5	62.4	69.7	69.6	56.5	40.7	19.7	0.3
	DBStd	27.62	8.80	9.95	9.90	7.02	6.53	5.37	4.65	5.12	6.52	7.86	10.82	10.74
	HDD50	7038	1744	1308	911	267	39	0	0	0	19	300	910	1540
	HDD65	10893	2209	1728	1376	704	359	113	11	12	262	754	1360	2005
	CDD50	1974	0	0	0	13	147	371	610	607	214	12	0	0
	CDD65	352	0	0	0	0	3	33	156	153	7	0	0	0
	CDH74	2947	0	0	0	14	140	450	1167	1124	49	3	0	0
	CDH80	776	0	0	0	2	21	96	332	321	4	0	0	0
	WSAvg	2.7	1.8	2.3	3.1	4.1	3.8	2.8	2.5	2.3	2.3	3.2	2.8	1.8
(15) Precipitation	PrecAvg	33.3	1.1	1.1	1.9	1.7	3.1	3.3	4.9	5.2	3.8	2.9	2.4	1.9
	PrecMax	43.3	2.6	2.9	3.7	4.1	5.6	5.6	11.5	10.7	10.9	5.9	4.1	4.0
	PrecMin	19.9	0.1	0.1	0.2	0.3	0.4	1.5	2.0	1.1	0.8	0.8	0.7	0.5
	PrecStd	5.4	0.6	0.8	0.9	0.9	1.2	1.2	1.8	2.2	2.3	1.3	1.0	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	37.0	54.4	74.9	82.7	86.5	91.2	92.0	78.6	69.9	51.3	35.2
		MCWB	23.2	31.9	41.4	52.2	60.5	68.0	71.2	74.0	66.5	54.7	41.6	33.6
	2%	DB	18.0	31.2	45.2	68.1	78.0	83.2	86.9	87.3	74.5	64.4	44.0	28.3
		MCWB	15.5	27.5	35.9	49.8	57.7	66.4	72.0	73.9	63.7	52.4	37.4	26.0
	5%	DB	13.3	26.2	41.2	62.7	73.1	79.6	83.4	83.2	71.3	59.5	39.1	23.3
		MCWB	11.4	23.0	33.3	46.5	55.4	65.0	70.4	72.0	61.5	48.8	33.8	21.6
	10%	DB	9.4	21.4	37.2	57.4	68.7	75.9	80.3	80.0	68.4	55.4	34.8	18.3
		MCWB	7.6	18.2	30.9	44.2	53.9	63.5	69.1	70.0	60.2	46.7	30.8	16.5
	0.4%	WB	24.4	32.2	41.9	53.7	63.4	73.7	77.2	77.2	70.3	57.1	44.0	33.6
		MCDB	25.8	35.8	52.5	71.6	76.7	81.0	85.4	86.5	75.6	67.9	49.8	34.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	15.7	27.6	36.7	50.5	59.8	68.7	74.4	75.2	66.2	53.5	38.5	26.2
		MCDB	17.8	31.0	44.1	65.6	71.8	79.3	82.4	85.1	71.3	61.5	43.1	28.1
	5%	WB	11.4	23.1	33.8	47.5	57.4	66.1	72.5	73.3	63.5	50.6	34.5	21.6
		MCDB	13.2	26.4	39.9	60.5	69.4	76.8	79.7	81.5	69.2	57.9	38.2	23.2
	10%	WB	7.7	18.4	31.5	44.7	55.3	64.1	70.8	71.5	61.3	47.5	31.3	16.5
		MCDB	9.3	21.4	36.4	56.1	65.5	73.8	77.5	78.2	66.9	53.9	34.6	18.1
	5% DB	MDBR	27.5	31.0	26.3	24.5	24.2	21.4	18.9	18.4	21.0	23.5	21.9	24.4
		MCDBR	28.6	33.1	29.5	37.2	34.6	29.8	25.0	22.9	25.7	32.7	26.1	22.5
		MCWBR	26.4	28.3	19.9	19.8	16.1	14.7	11.7	10.9	14.6	19.6	19.2	20.5
		MCWBR	28.3	30.2	25.4	33.9	28.4	26.5	20.0	21.8	21.5	28.8	24.3	22.0
(40) Clear-Sky Solar Irradiance	taub		0.308	0.367	0.442	0.540	0.549	0.529	0.488	0.456	0.414	0.422	0.373	0.328
		taud	2.090	1.915	1.802	1.743	1.802	1.946	2.128	2.222	2.253	2.074	2.092	2.054
	Ebn at Noon		246	247	243	231	234	240	249	253	254	227	216	220
		Edh at Noon	31	46	59	68	66	58	48	42	37	39	32	30
(44) All-Sky Solar Radiation	RadAvg		680	996	1292	1434	1591	1706	1563	1438	1267	901	613	526
	RadStd		45	53	95	136	138	187	151	117	109	95	62	33

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page