

TIMIRYAZEVSIIY, Russian Federation

WMO: 319610

Lat: 43.8571N

Lon: 131.9530E

Elev: 36

StdP: 100.89

Time Zone: 10.00 (E10)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.3	-27.7	-33.3	0.2	-28.8	-30.9	0.2	-26.8	8.9	-13.0	8.1	-10.0	1.0	50	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.7	(c) 29.7	(d) 22.6	(e) 28.0	(f) 21.8	(g) 26.3	(h) 21.0	(i) 24.1	(j) 27.8	(k) 23.1	(l) 26.1	(m) 22.2	(n) 25.0	(o) 2.4	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.9	17.8	25.9	22.1	16.8	25.2	21.2	15.9	24.0	72.9	27.8	69.1	26.2	65.5	25.1	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.5	6.6	-32.2	33.0	3.5	1.5	-34.7	34.0	-36.8	34.9	-38.8	35.7	-41.3	36.8		
(5)			-32.3	25.4	3.5	0.7	-34.8	25.9	-36.9	26.3	-38.8	26.7	-41.3	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-16.7	-11.7	-1.9	6.4	13.2	17.2	21.5	21.7	16.1	7.7	-3.2	-13.9		
	DBStd	14.04	5.11	5.56	5.75	3.64	3.24	3.04	2.68	2.68	3.58	4.35	6.46	5.65		
	HDD10.0	3170	828	607	371	117	9	0	0	0	3	98	396	742		
	HDD18.3	5198	1087	841	628	357	160	56	6	6	83	329	646	1000		
	CDD10.0	1267	0	0	1	10	109	215	356	364	186	27	1	0		
	CDD18.3	253	0	0	0	0	2	21	103	111	16	0	0	0		
	CDH23.3	1301	0	0	0	2	44	137	511	547	61	0	0	0		
	CDH26.7	293	0	0	0	0	7	36	134	112	5	0	0	0		
(14) Wind	WSAvg	3.0	2.1	2.6	3.3	3.8	3.9	3.6	3.2	2.6	2.4	2.9	2.8	2.3		
(15) Precipitation	PrecAvg	641	7	12	15	41	54	84	85	126	114	55	29	13		
	PrecMax	1010	26	58	61	121	106	315	188	360	267	169	86	52		
	PrecMin	422	0	0	0	7	3	24	7	1	9	7	0	0		
	PrecStd	161	7	12	13	29	27	54	43	74	66	38	21	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.2	4.8	15.5	22.1	26.9	30.2	31.9	31.2	27.3	20.9	14.1	4.2		
		MCWB	-1.7	-0.1	7.4	11.2	16.7	21.3	24.4	23.5	19.2	15.0	9.7	2.3		
	2%	DB	-2.6	2.7	11.4	18.2	24.4	27.0	29.8	29.4	25.0	19.0	11.3	0.7		
		MCWB	-4.2	0.7	4.7	9.1	14.6	19.6	23.1	22.6	18.7	13.1	7.6	-1.0		
	5%	DB	-5.4	0.9	8.4	15.8	22.2	24.4	28.1	27.8	23.4	17.2	9.0	-1.8		
		MCWB	-7.5	-1.0	3.0	7.8	13.5	18.4	22.6	22.0	18.1	12.5	6.0	-3.5		
	10%	DB	-8.0	-1.9	6.0	13.4	19.9	22.3	26.2	26.3	22.0	15.6	6.6	-4.4		
		MCWB	-9.5	-4.4	1.9	6.6	12.8	17.8	21.7	21.4	17.5	11.6	4.1	-6.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.0	2.5	7.8	11.9	17.4	22.4	25.6	24.7	22.0	17.5	10.6	2.5		
		MCDB	-0.2	3.2	14.8	20.2	25.7	28.5	29.9	28.5	23.9	19.6	12.2	3.7		
	2%	WB	-4.0	1.0	5.4	10.0	15.6	20.5	24.3	24.1	20.5	15.2	8.3	-0.7		
		MCDB	-2.7	2.0	10.1	16.7	22.3	25.5	28.5	27.5	23.0	17.4	10.4	0.6		
	5%	WB	-7.4	-1.4	3.7	8.7	14.5	19.1	23.2	23.3	19.3	13.9	6.3	-3.5		
		MCDB	-5.6	1.3	7.8	13.6	20.1	23.1	26.7	26.1	22.2	16.4	8.7	-1.9		
	10%	WB	-9.6	-4.2	2.1	7.4	13.5	18.1	22.2	22.5	18.4	12.2	4.2	-5.9		
		MCDB	-8.0	-2.2	5.5	12.2	18.5	21.5	25.3	25.1	21.2	14.6	6.4	-4.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	13.3	10.8	10.9	10.2	7.8	7.2	7.7	10.8	12.0	10.1	11.7		
		MCDBR	14.3	12.2	14.0	15.8	15.3	12.3	10.7	9.9	11.5	13.6	12.2	11.8		
		MCWBR	12.8	9.7	8.1	8.2	6.7	5.9	4.9	4.1	5.6	8.2	8.6	10.3		
		MCDBR	14.2	11.3	12.4	13.4	12.5	10.4	9.4	7.7	8.5	9.3	10.7	11.7		
	5% WB	MCWBR	12.9	9.2	7.4	7.5	6.2	5.3	4.7	3.9	4.7	6.7	8.6	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.385	0.474	0.580	0.594	0.568	0.534	0.488	0.440	0.457	0.398	0.345		
	taud		2.077	1.920	1.807	1.663	1.699	1.840	1.989	2.113	2.155	1.966	2.024	2.053		
	Ebn at Noon		757	766	743	699	707	729	750	772	778	682	660	686		
	Edh at Noon		104	146	188	235	233	203	173	148	131	139	110	97		
(44) All-Sky Solar Radiation	RadAvg		2.22	3.25	4.26	4.60	5.06	5.27	4.73	4.56	4.20	3.09	2.14	1.82		
	RadStd		0.14	0.18	0.30	0.42	0.45	0.64	0.56	0.43	0.35	0.24	0.17	0.10		

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page