

ANUCHINO, Russian Federation

WMO: 319810

Lat: 43.967N

Lon: 133.067E

Elev: 188

StdP: 99.09

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.7	-28.7	-33.3	0.2	-30.1	-31.3	0.2	-28.1	5.5	-14.6	4.5	-15.2	2.2	250	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	30.9	21.9	29.2	21.0	27.6	20.5	23.5	28.6	22.6	27.1	21.7	25.7	2.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.9	26.2	21.1	16.2	25.3	20.4	15.4	24.2	71.5	28.7	68.1	27.0	64.6	25.7	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.4	3.9	-33.2	33.5	2.7	1.6	-35.1	34.7	-36.7	35.7	-38.3	36.6	-40.2	37.8		
(5)			-33.3	25.2	2.7	1.3	-35.2	26.2	-36.8	27.0	-38.3	27.7	-40.3	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-17.8	-12.7	-3.7	6.1	13.2	18.2	21.9	21.1	15.0	6.8	-4.4	-14.9		
	DBStd	14.51	4.86	5.63	5.75	4.36	3.62	3.06	2.61	2.71	3.53	4.46	6.64	5.59		
	HDD10.0	3389	861	636	424	132	11	0	0	0	4	117	432	771		
	HDD18.3	5428	1119	869	683	368	162	39	3	7	109	357	682	1029		
	CDD10.0	1259	0	0	0	15	111	247	368	346	154	19	0	0		
	CDD18.3	255	0	0	0	0	4	36	113	94	9	0	0	0		
	CDH23.3	2019	0	0	0	15	122	381	827	598	74	2	0	0		
	CDH26.7	552	0	0	0	2	27	104	266	146	8	0	0	0		
(14) Wind	WSAvg	1.8	1.8	1.9	2.0	2.2	1.9	1.6	1.4	1.4	1.6	1.8	1.8	1.7		
(15) Precipitation	PrecAvg	711	12	15	26	42	73	78	121	126	91	67	35	24		
	PrecMax	1024	31	42	55	101	137	167	234	325	259	158	68	51		
	PrecMin	411	1	1	1	7	5	31	38	19	20	16	9	3		
	PrecStd	128	8	12	15	23	31	35	46	65	67	32	16	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.7	6.3	14.6	25.6	29.9	31.7	33.7	32.2	27.6	22.8	14.8	5.1		
		MCWB	-1.2	1.8	6.5	12.6	16.3	20.3	23.7	23.4	19.4	14.2	8.2	2.6		
	2%	DB	-3.5	3.1	10.2	21.2	26.5	29.5	31.3	29.9	25.4	19.6	11.1	0.4		
		MCWB	-5.3	-0.3	3.6	10.2	14.8	19.5	22.6	22.6	18.1	12.0	6.2	-1.6		
	5%	DB	-7.0	0.2	7.3	17.8	24.1	27.5	29.5	28.2	23.6	17.0	7.9	-3.1		
		MCWB	-8.5	-2.2	2.1	8.7	13.7	18.8	21.8	21.8	17.1	10.8	4.4	-4.6		
	10%	DB	-9.5	-2.7	4.8	15.0	21.6	25.4	27.8	26.7	21.8	14.8	4.7	-6.0		
		MCWB	-10.7	-4.9	0.8	7.3	12.6	17.9	21.4	21.1	16.1	9.9	1.9	-7.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.2	2.4	6.9	13.5	17.4	22.1	25.0	24.6	21.7	15.2	9.0	2.7		
		MCDB	0.6	5.3	13.9	23.3	25.9	28.3	31.5	30.1	25.7	20.4	13.7	5.2		
	2%	WB	-5.2	0.1	4.4	10.9	15.7	20.8	23.7	23.6	19.6	13.4	6.9	-1.5		
		MCDB	-3.5	2.7	9.1	19.7	24.2	26.9	29.0	28.4	22.9	17.7	10.4	0.1		
	5%	WB	-8.4	-2.4	2.6	9.2	14.6	19.7	22.8	22.8	18.2	12.0	4.4	-4.5		
		MCDB	-7.1	0.2	6.6	16.7	22.4	25.6	27.8	27.0	21.9	15.7	7.6	-3.1		
	10%	WB	-10.6	-4.9	1.2	7.6	13.5	18.5	21.9	21.8	17.1	10.5	2.1	-7.3		
		MCDB	-9.5	-2.7	4.4	14.0	20.0	24.2	26.3	25.2	20.6	14.2	4.5	-6.0		
(35) Mean Daily Temperature Range	MDBR		14.2	15.0	12.2	12.6	12.8	11.6	9.7	9.5	12.4	13.0	11.8	12.9		
	5% DB	MCDBR	15.8	16.4	14.8	18.6	18.2	15.8	13.3	11.9	14.5	17.0	15.0	14.0		
		MCWBR	13.9	12.9	9.1	9.6	7.9	7.1	5.5	5.2	7.2	9.6	10.1	12.1		
	5% WB	MCDBR	15.5	15.9	13.5	17.2	15.7	13.7	11.0	9.9	11.5	14.7	14.5	13.8		
		MCWBR	13.8	12.8	8.6	9.3	7.3	6.7	5.0	4.8	6.3	9.0	10.1	12.1		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.387	0.472	0.572	0.580	0.552	0.516	0.475	0.429	0.445	0.390	0.344		
	taud		2.066	1.893	1.788	1.674	1.718	1.870	2.033	2.148	2.186	1.997	2.035	2.028		
	Ebn at Noon		759	761	743	704	717	741	764	783	788	695	668	682		
	Edh at Noon		104	150	191	232	229	197	166	143	127	134	109	99		
(44) All-Sky Solar Radiation	RadAvg		2.14	3.14	4.15	4.58	5.10	5.41	4.84	4.58	4.13	3.00	2.07	1.73		
	RadStd		0.13	0.17	0.29	0.44	0.42	0.59	0.54	0.42	0.35	0.26	0.18	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page