

PREOBRAZHENIYE, Russian Federation

WMO: 319890

Lat: 42.9005N

Lon: 133.8921E

Elev: 140

StdP: 14.62

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.7	5.5	-21.7	1.7	7.0	-18.4	2.0	9.3	22.8	20.7	18.3	14.0	7.5	0	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	76.8	70.1	74.6	69.2	72.7	68.1	72.1	74.8	70.7	73.4	69.2	72.0	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	115.5	73.8	69.7	109.7	72.5	68.1	103.8	71.2	36.1	75.1	34.8	74.0	33.5	72.1	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	14.5	13.3	DB	-2.8	81.9	4.0	1.6	-5.7	83.1	-8.0	84.0	-10.3	84.9	-13.2	86.0	
			WB	-4.5	74.4	3.5	1.7	-7.1	75.6	-9.1	76.6	-11.1	77.6	-13.7	78.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	18.8	22.9	31.6	41.0	49.1	55.1	64.0	68.1	61.4	49.4	34.5	22.1
	DBStd	17.52	6.62	6.76	5.73	4.70	5.15	4.25	4.59	3.87	4.40	6.01	8.39	7.93
	HDD50	4069	968	759	570	272	81	5	0	0	0	83	467	864
	HDD65	8097	1433	1179	1035	720	492	297	74	14	123	485	916	1329
	CDD50	1615	0	0	0	2	54	159	433	562	341	63	1	0
	CDD65	168	0	0	0	0	0	1	42	111	14	0	0	0
	CDH74	255	0	0	0	0	0	1	45	198	11	0	0	0
	CDH80	11	0	0	0	0	0	0	1	10	0	0	0	0
Wind	WSAvg	5.9	6.4	5.8	5.7	5.9	5.7	5.5	4.9	5.5	6.4	6.1	6.2	6.4
Precipitation	PrecAvg	30.7	0.5	0.8	1.2	1.7	3.1	3.0	5.6	5.3	4.4	2.3	1.8	1.1
	PrecMax	44.5	1.3	2.8	2.6	5.2	6.9	6.2	16.8	11.1	13.8	5.0	6.1	5.4
	PrecMin	15.6	0.1	0.0	0.0	0.3	0.1	0.7	1.7	0.1	0.5	0.8	0.4	0.0
	PrecStd	6.7	0.3	0.9	0.7	1.1	1.7	1.8	2.9	2.5	3.0	1.1	1.4	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	41.8	51.5	61.1	67.4	71.7	78.1	81.3	75.4	66.0	55.5	44.3
		MCWB	32.6	33.0	39.6	45.5	53.5	61.7	68.6	71.5	66.6	55.9	48.0	40.0
	2%	DB	34.2	37.8	46.6	55.2	64.1	66.7	74.7	78.4	72.5	63.4	52.4	40.3
		MCWB	29.2	31.8	37.9	44.0	51.5	60.4	68.5	70.3	64.9	55.9	46.9	36.2
	5%	DB	31.8	35.2	43.0	51.5	60.8	63.8	72.1	76.1	70.5	61.1	49.8	37.0
		MCWB	27.3	30.2	34.7	41.4	50.6	59.5	67.6	70.5	63.7	54.7	44.8	32.5
	10%	DB	29.5	32.9	40.1	48.8	57.4	61.6	70.3	74.3	68.8	58.8	47.0	34.1
		MCWB	25.0	28.5	33.6	40.3	49.8	58.0	66.8	69.8	62.8	52.9	41.9	29.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.9	35.7	41.5	48.0	56.5	64.2	71.8	74.7	70.9	61.0	50.8	41.5
		MCDB	36.1	38.6	49.3	56.3	62.6	66.8	74.9	76.8	73.7	62.5	53.0	43.1
	2%	WB	30.4	33.4	38.3	45.3	54.4	61.8	70.1	73.2	67.9	58.7	48.5	36.8
		MCDB	33.0	36.0	44.1	51.7	60.1	64.9	72.8	75.8	70.0	61.6	51.1	39.3
	5%	WB	27.7	31.1	36.2	43.5	52.5	60.2	68.7	71.9	66.1	56.6	45.6	33.2
		MCDB	31.4	34.3	41.1	49.1	57.8	63.2	71.0	74.5	68.6	59.6	49.0	36.4
	10%	WB	25.2	28.8	34.5	42.0	50.9	58.4	67.4	70.7	64.5	54.0	42.5	30.2
		MCDB	29.6	32.8	38.7	47.1	55.8	61.1	69.7	73.5	67.6	57.3	46.5	33.7
Mean Daily Temperature Range	5% DB	MDBR	13.7	13.5	12.0	11.7	10.7	8.5	7.9	8.8	12.9	13.6	12.6	13.1
		MCDBR	15.8	13.7	15.6	16.4	16.7	12.8	11.1	10.7	13.1	15.3	13.4	14.3
		MCWBR	13.7	11.3	9.6	9.0	8.2	7.8	7.1	6.9	8.8	11.6	11.9	12.6
	5% WB	MCDBR	15.1	13.1	14.0	14.0	13.5	11.3	9.1	8.8	9.8	12.3	12.0	14.1
		MCWBR	14.4	11.8	9.8	8.9	8.1	7.6	6.7	6.5	8.0	11.4	12.2	13.6
Clear-Sky Solar Irradiance	taub	0.321	0.383	0.464	0.554	0.576	0.551	0.522	0.477	0.421	0.422	0.382	0.340	
	taud	2.225	2.043	1.877	1.735	1.768	1.917	2.068	2.201	2.277	2.119	2.133	2.144	
	Ebn at Noon	251	249	241	230	229	236	242	249	255	233	222	227	
	Edh at Noon	29	42	56	70	69	60	51	43	37	38	32	29	
All-Sky Solar Radiation	RadAvg	702	1002	1358	1522	1582	1602	1423	1460	1351	1023	693	573	
	RadStd	43	69	86	138	160	192	169	121	123	77	64	42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page