

POGIBI, Russian Federation

WMO: 320270

Lat: 52.2250N

Lon: 141.6470E

Elev: 20

StdP: 14.69

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-20.2	-27.8	1.2	-23.7	-23.5	1.5	-19.8	39.5	8.4	36.4	4.8	3.6	0	0.808

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	69.7	64.6	67.5	63.5	65.9	62.4	66.0	68.5	64.3	66.7	62.9	65.3	9.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	92.1	67.6	63.3	87.0	66.0	61.8	82.5	64.7	30.9	68.6	29.6	66.7	28.5	65.5	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.9	28.7	23.5	-31.4	75.1	5.0	2.8	-35.0	77.1	-37.9	78.7	-40.7	80.3	-44.4	82.4		
(5)			-31.5	68.1	5.0	2.1	-35.1	69.6	-38.0	70.8	-40.7	72.0	-44.3	73.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.1	-2.0	-1.4	11.2	26.7	37.9	50.5	58.6	61.0	54.3	39.3	19.7	3.4		
	DBStd	23.72	10.06	9.22	9.38	6.31	4.77	4.33	3.47	3.50	5.42	6.47	10.09	9.78		
	HDD50	8085	1613	1438	1204	700	375	45	0	0	23	335	909	1443		
	HDD65	12747	2078	1858	1669	1150	840	436	198	132	322	797	1359	1908		
	CDD50	821	0	0	0	0	0	59	268	340	151	3	0	0		
	CDD65	8	0	0	0	0	0	0	1	6	1	0	0	0		
	CDH74	4	0	0	0	0	0	0	2	1	1	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	9.9	9.6	8.5	8.3	9.2	9.2	11.1	10.8	10.5	10.4	10.8	9.9	10.1		
	PrecAvg	22.4	1.2	1.0	1.1	1.3	2.0	1.9	2.4	3.0	3.0	2.7	1.2	1.5		
(15) Precipitation	PrecMax	34.4	3.7	3.0	4.1	2.9	4.1	7.2	6.9	6.9	7.6	8.3	3.5	3.9		
	PrecMin	10.8	0.0	0.0	0.1	0.3	0.5	0.2	0.0	0.8	0.4	0.3	0.1	0.4		
	PrecStd	4.6	1.0	0.9	0.8	0.7	0.9	1.3	1.8	1.4	1.4	1.5	0.7	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	27.0	34.7	42.8	54.9	67.0	72.5	72.6	69.2	57.8	41.6	32.2		
		MCWB	27.8	26.1	33.1	40.3	49.4	60.7	65.6	66.2	64.0	54.0	39.7	31.6		
	2%	DB	22.7	22.1	31.3	39.0	50.4	61.9	68.3	70.5	66.0	53.5	37.7	27.9		
		MCWB	22.4	21.2	29.8	36.6	46.9	57.1	63.1	65.4	61.7	50.4	35.6	27.2		
	5%	DB	17.4	17.3	28.6	36.6	47.8	59.4	66.2	68.5	64.2	50.9	35.4	23.5		
		MCWB	16.8	16.5	27.4	34.6	44.9	55.6	62.0	64.5	60.7	48.0	33.7	22.7		
	10%	DB	12.5	13.1	26.0	34.6	45.4	57.4	64.4	67.0	62.6	48.7	33.0	18.1		
		MCWB	11.9	12.2	24.9	33.1	43.1	54.4	61.2	63.6	59.5	46.2	31.5	17.2		
	0.4%	WB	28.0	26.3	33.6	41.2	50.5	61.9	66.5	68.4	65.6	54.4	40.2	31.7		
		MCDB	28.6	26.8	34.4	42.5	53.2	65.8	70.4	70.5	68.4	56.6	41.5	32.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	22.3	21.4	30.0	36.9	47.6	57.8	64.1	67.0	62.7	51.0	36.0	27.4		
		MCDB	22.6	22.2	31.1	38.4	50.1	60.9	66.9	69.1	64.9	52.9	37.2	27.9		
	5%	WB	16.8	16.8	27.6	34.8	45.3	56.1	62.8	65.5	61.4	48.6	33.9	22.9		
		MCDB	17.4	17.5	28.5	36.1	47.3	58.8	65.3	67.7	63.7	50.5	35.1	23.5		
	10%	WB	11.9	12.4	25.0	33.3	43.4	54.7	61.6	64.1	59.9	46.4	31.7	17.4		
		MCDB	12.5	13.1	26.0	34.4	45.0	57.0	63.9	66.3	62.3	48.4	33.1	18.1		
	5% DB	MDBR	14.0	17.5	18.2	12.7	8.9	9.7	8.9	9.4	10.6	9.4	10.2	12.7		
		MCDBR	14.3	18.5	18.7	14.8	13.2	14.1	13.4	12.0	12.0	12.5	9.6	14.4		
		MCWBR	14.3	17.9	17.8	13.5	9.9	10.5	9.5	8.5	9.1	10.1	8.4	13.8		
		MCWBR	14.5	18.0	18.0	14.1	12.1	12.0	11.2	10.1	10.8	11.7	9.4	14.1		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.307	0.376	0.481	0.527	0.491	0.490	0.438	0.384	0.386	0.337	0.288		
		taud	2.042	2.004	1.852	1.712	1.798	2.023	2.097	2.272	2.358	2.144	2.082	2.027		
	Ebn at Noon		216	247	248	235	233	244	242	250	251	216	189	186		
		Edh at Noon	25	35	51	67	64	52	47	38	31	31	24	22		
(44) All-Sky Solar Radiation	RadAvg		391	761	1197	1448	1528	1699	1522	1281	1034	630	371	281		
	RadStd		34	43	85	128	162	184	185	121	90	55	44	35		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	N/A

Nomenclature: See separate page