

NOGLIKI, Russian Federation

WMO: 320530

Lat: 51.7837N

Lon: 143.1385E

Elev: 112

StdP: 14.64

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.9	-16.0	-25.0	1.4	-19.1	-21.5	1.7	-14.8	28.1	20.3	24.4	21.0	5.4	240	0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.9	78.2	64.1	74.3	62.6	70.6	60.7	66.4	74.5	64.3	71.6	62.3	68.7	8.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	88.1	69.6	61.3	81.5	67.6	59.3	75.6	65.8	31.2	74.7	29.6	71.7	28.1	68.7	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.1	18.7	16.2	DB	-26.9	85.3	4.5	3.2	-30.1	87.6	-32.8	89.5	-35.3	91.3	-38.6	93.6	(4)
			WB	-27.1	70.4	4.5	2.3	-30.3	72.0	-32.9	73.4	-35.4	74.7	-38.7	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.6	2.2	4.4	15.9	29.3	39.8	50.6	56.9	59.6	53.3	39.1	20.4	6.0
	DBStd	22.05	10.37	9.13	8.63	6.75	7.36	8.20	6.85	5.79	6.26	6.73	10.42	10.89
	HDD50	7501	1481	1276	1057	620	333	93	11	0	35	342	889	1364
	HDD65	12236	1946	1696	1522	1070	783	438	269	188	353	803	1339	1829
	CDD50	790	0	0	0	0	16	111	226	299	134	4	0	0
	CDD65	48	0	0	0	0	0	5	19	22	2	0	0	0
	CDH74	364	0	0	0	0	6	62	153	130	13	0	0	0
	CDH80	56	0	0	0	0	1	6	34	15	0	0	0	0
Wind	WSAvg	7.7	8.3	8.0	8.1	8.4	7.9	7.2	6.5	6.5	7.0	7.9	8.3	8.5
Precipitation	PrecAvg	27.3	1.2	1.1	1.4	1.7	2.7	2.0	2.6	3.5	3.8	3.7	1.7	1.7
	PrecMax	36.1	3.3	2.6	3.1	4.1	4.8	5.4	7.8	8.1	9.9	9.1	3.7	5.5
	PrecMin	21.0	0.1	0.0	0.2	0.4	0.5	0.0	0.0	0.2	0.6	0.9	0.4	0.0
	PrecStd	3.6	0.8	0.7	0.8	0.8	1.1	1.2	1.7	2.0	1.7	1.9	0.7	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.5	28.8	38.2	56.4	71.7	80.1	84.5	82.1	76.0	62.3	43.7	32.6
		MCWB	29.7	26.8	31.2	43.1	53.8	61.8	67.6	67.3	62.4	51.2	39.9	31.9
	2%	DB	28.1	25.9	33.0	48.4	63.6	74.8	78.3	77.5	71.1	55.7	39.7	30.7
		MCWB	27.4	24.5	28.6	39.1	50.2	59.6	65.0	65.3	59.9	47.6	37.3	30.0
	5%	DB	25.0	22.7	30.4	42.8	58.0	70.0	72.9	73.9	67.1	51.6	36.7	27.9
		MCWB	24.2	21.2	27.9	35.7	47.2	57.8	62.7	64.0	57.9	45.7	34.3	27.1
	10%	DB	18.6	19.2	28.2	38.5	52.3	65.3	68.5	70.1	63.5	48.7	34.4	23.9
		MCWB	17.6	17.6	26.2	33.5	44.5	55.4	60.7	62.3	56.3	44.6	32.5	22.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.0	27.5	32.3	44.1	55.2	63.7	68.9	69.9	64.2	52.7	41.1	32.3
		MCDB	30.3	28.4	35.6	54.2	69.3	77.6	80.7	77.8	71.8	59.4	42.2	32.5
	2%	WB	27.6	24.5	30.1	39.5	51.3	60.7	65.8	67.4	61.3	49.6	37.7	30.2
		MCDB	28.1	25.5	32.0	47.7	61.3	71.9	75.2	74.3	68.2	52.9	39.6	30.6
	5%	WB	24.2	21.2	28.3	36.4	48.2	58.4	63.9	65.2	59.3	47.5	35.0	27.2
		MCDB	25.1	22.5	29.8	41.8	56.7	68.3	71.4	71.6	65.4	50.2	36.2	27.9
	10%	WB	17.7	17.5	26.4	33.8	45.1	56.0	61.6	63.2	57.3	45.5	32.6	22.9
		MCDB	18.4	19.1	28.3	37.8	51.5	64.5	67.9	69.0	62.2	48.1	34.1	23.9
Mean Daily Temperature Range	5% DB	MDBR	13.8	16.1	16.0	11.8	13.3	15.9	14.1	13.9	15.2	12.9	12.1	12.6
		MCDBR	12.2	14.0	15.4	19.7	25.6	26.0	22.7	21.4	21.0	18.3	12.1	10.4
		MCWBR	12.1	12.7	12.3	11.7	14.1	13.5	11.8	10.9	11.3	11.5	10.2	10.5
	5% WB	MCDBR	12.3	12.8	12.5	17.8	23.7	23.5	20.4	18.5	18.2	15.0	11.0	10.0
		MCWBR	12.4	12.0	10.5	11.1	13.9	13.1	11.5	11.0	10.6	10.5	9.9	10.2
Clear-Sky Solar Irradiance	taub	0.287	0.311	0.376	0.473	0.508	0.473	0.464	0.427	0.379	0.389	0.343	0.296	
	taud	2.040	1.999	1.849	1.697	1.850	2.097	2.181	2.309	2.382	2.152	2.093	2.037	
	Ebn at Noon	215	247	249	238	238	250	250	254	254	216	190	187	
	Edh at Noon	26	36	51	68	61	48	44	36	30	31	25	22	
All-Sky Solar Radiation	RadAvg	384	749	1160	1438	1509	1690	1515	1254	1030	622	357	276	
	RadStd	36	49	90	164	147	191	178	113	82	53	46	34	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	+85	N/A

Nomenclature: See separate page