

NOGLIKI, Russian Federation

WMO: 320530

Lat: 51.7837N

Lon: 143.1385E

Elev: 34

StdP: 100.92

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.8	(c) -26.7	(d) -31.7	(e) 0.2	(f) -28.4	(g) -29.7	(h) 0.2	(i) -26.0	(j) 12.6	(k) -6.5	(l) 10.9	(m) -6.1	(n) 2.4	(o) 240	(p) 0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.7	(c) 25.7	(d) 17.9	(e) 23.5	(f) 17.0	(g) 21.5	(h) 15.9	(i) 19.1	(j) 23.6	(k) 17.9	(l) 22.0	(m) 16.8	(n) 20.4	(o) 3.9	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	20.9	16.3	11.6	19.8	15.2	10.8	18.8	54.7	23.7	51.0	22.1	47.5	20.4	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.4	7.2	-32.7	29.6	2.5	1.8	-34.5	30.9	-36.0	31.9	-37.4	32.9	-39.2	34.2
			-32.8	21.3	2.5	1.3	-34.6	22.2	-36.1	23.0	-37.5	23.7	-39.3	24.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.2	-16.5	-15.3	-8.9	-1.5	4.3	10.3	13.9	15.4	11.8	3.9	-6.5	-14.4		
	DBStd	12.25	5.76	5.07	4.80	3.75	4.09	4.56	3.81	3.22	3.48	3.74	5.79	6.05		
	HDD10.0	4167	823	709	587	344	185	52	6	0	19	190	494	758		
	HDD18.3	6798	1081	942	846	594	435	243	149	104	196	446	744	1016		
	CDD10.0	439	0	0	0	0	9	62	126	166	74	2	0	0		
	CDD18.3	27	0	0	0	0	0	3	11	12	1	0	0	0		
	CDH23.3	202	0	0	0	0	3	34	85	72	7	0	0	0		
	CDH26.7	31	0	0	0	0	1	3	19	8	0	0	0	0		
(14) Wind	WSAvg	3.4	3.7	3.6	3.6	3.7	3.5	3.2	2.9	2.9	3.1	3.5	3.7	3.8		
(15) Precipitation	PrecAvg	693	31	29	35	43	68	50	67	89	97	93	44	42		
	PrecMax	918	84	66	80	104	121	137	197	205	251	230	95	139		
	PrecMin	533	2	1	5	10	13	1	0	6	15	22	10	0		
	PrecStd	92	21	19	21	21	29	31	44	50	44	49	19	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.8	-1.8	3.5	13.5	22.1	26.7	29.2	27.8	24.4	16.8	6.5	0.3		
		MCWB	-1.3	-2.9	-0.5	6.2	12.1	16.6	19.8	19.6	16.9	10.7	4.4	0.0		
	2%	DB	-2.2	-3.4	0.6	9.1	17.6	23.8	25.7	25.3	21.7	13.2	4.3	-0.7		
		MCWB	-2.5	-4.2	-1.9	3.9	10.1	15.3	18.3	18.5	15.5	8.7	2.9	-1.1		
	5%	DB	-3.9	-5.2	-0.9	6.0	14.4	21.1	22.7	23.3	19.5	10.9	2.6	-2.3		
		MCWB	-4.3	-6.0	-2.3	2.0	8.5	14.3	17.1	17.8	14.4	7.6	1.3	-2.7		
	10%	DB	-7.4	-7.1	-2.1	3.6	11.3	18.5	20.3	21.2	17.5	9.3	1.3	-4.5		
		MCWB	-8.0	-8.0	-3.2	0.8	7.0	13.0	15.9	16.8	13.5	7.0	0.3	-5.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.1	-2.5	0.2	6.7	12.9	17.6	20.5	21.1	17.9	11.5	5.1	0.2		
		MCDB	-0.9	-2.0	2.0	12.3	20.7	25.3	27.0	25.5	22.1	15.2	5.7	0.3		
	2%	WB	-2.5	-4.2	-1.0	4.2	10.7	16.0	18.8	19.6	16.3	9.8	3.2	-1.0		
		MCDB	-2.2	-3.6	0.0	8.7	16.3	22.2	24.0	23.5	20.1	11.6	4.2	-0.8		
	5%	WB	-4.3	-6.0	-2.1	2.4	9.0	14.7	17.7	18.4	15.1	8.6	1.7	-2.7		
		MCDB	-3.9	-5.3	-1.2	5.5	13.7	20.2	21.9	22.0	18.5	10.1	2.3	-2.3		
	10%	WB	-7.9	-8.0	-3.1	1.0	7.3	13.4	16.4	17.4	14.0	7.5	0.3	-5.1		
		MCDB	-7.5	-7.2	-2.0	3.2	10.8	18.1	19.9	20.6	16.8	8.9	1.1	-4.5		
(35) Mean Daily Temperature Range	MDBR		7.7	8.9	8.9	6.5	7.4	8.8	7.8	7.7	8.4	7.1	6.7	7.0		
	5% DB	MCDBR	6.8	7.8	8.6	10.9	14.2	14.4	12.6	11.9	11.6	10.2	6.7	5.8		
		MCWBR	6.7	7.1	6.8	6.5	7.8	7.5	6.6	6.1	6.3	6.4	5.7	5.8		
	5% WB	MCDBR	6.8	7.1	6.9	9.9	13.1	13.1	11.3	10.3	10.1	8.3	6.1	5.5		
		MCWBR	6.9	6.7	5.8	6.2	7.7	7.3	6.4	6.1	5.9	5.8	5.5	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.287	0.311	0.376	0.473	0.508	0.473	0.464	0.427	0.379	0.389	0.343	0.296		
	taud		2.040	1.999	1.849	1.697	1.850	2.097	2.181	2.309	2.382	2.152	2.093	2.037		
	Ebn at Noon		679	778	786	751	751	788	801	801	682	599	589	589		
	Edh at Noon		81	113	161	214	193	152	138	115	96	98	78	69		
(44) All-Sky Solar Radiation	RadAvg		1.21	2.36	3.66	4.53	4.76	5.33	4.78	3.95	3.25	1.96	1.13	0.87		
	RadStd		0.12	0.15	0.28	0.52	0.46	0.60	0.56	0.35	0.26	0.17	0.14	0.11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+47	N/A

Nomenclature: See separate page