

PORONAYSK, Russian Federation

WMO: 320980

Lat: 49.217N

Lon: 143.100E

Elev: 8

StdP: 101.23

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.5	(c) -26.0	(d) -31.4	(e) 0.2	(f) -27.9	(g) -29.1	(h) 0.3	(i) -25.3	(j) 11.2	(k) -5.8	(l) 10.2	(m) -7.0	(n) 2.1	(o) 320	(p) 0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	22.4	18.0	20.5	17.4	19.1	16.9	19.2	21.2	18.2	19.8	17.3	18.6	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	20.1	17.5	12.6	19.1	16.6	11.9	18.2	55.1	21.0	51.8	19.9	48.9	18.8	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.4	(b) 8.1	(c) 7.1	(e) -32.9	(f) 28.2	(g) 2.6	(h) 2.0	(i) -34.8	(j) 29.7	(k) -36.4	(l) 30.9	(m) -37.9	(n) 32.0	(o) -39.8	(p) 33.5		
(a) 9.4	(b) 8.1	(c) 7.1	(e) -33.1	(f) 21.0	(g) 2.6	(h) 1.6	(i) -34.9	(j) 22.1	(k) -36.5	(l) 23.0	(m) -37.9	(n) 23.9	(o) -39.8	(p) 25.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-15.0	-13.8	-7.2	0.0	5.1	10.1	14.1	16.0	12.2	5.1	-4.0	-12.9	(6)	
(7)		DBStd	11.57	5.87	5.27	4.50	2.84	3.07	2.88	2.47	2.48	3.11	3.44	5.46	5.73	(7)	
(8)		HDD10.0	3763	776	667	533	300	156	32	1	0	13	154	421	710	(8)	
(9)		HDD18.3	6379	1034	901	792	550	409	248	133	80	184	409	671	968	(9)	
(10)		CDD10.0	438	0	0	0	0	4	34	129	187	80	3	0	0	(10)	
(11)		CDD18.3	12	0	0	0	0	0	1	2	8	1	0	0	0	(11)	
(12)		CDH23.3	45	0	0	0	0	1	7	10	23	4	0	0	0	(12)	
(13)		CDH26.7	7	0	0	0	0	0	1	2	3	1	0	0	0	(13)	
(14)	Wind	WSAvg	3.2	3.3	3.1	3.3	3.3	3.2	2.8	2.8	3.0	3.2	3.4	3.3	3.2	(14)	
(15)	Precipitation	PrecAvg	750	22	26	38	54	69	59	78	94	119	95	52	37	(15)	
(16)		PrecMax	1153	85	107	111	131	182	151	189	368	272	220	127	123	(16)	
(17)		PrecMin	448	0	1	4	13	10	5	4	8	22	16	0	7	(17)	
(18)		PrecStd	166	19	23	26	30	38	35	44	76	62	48	36	26	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.4	0.3	3.4	11.5	18.4	23.6	24.0	26.0	23.2	16.3	9.7	1.7	(19)	
(20)		MCWB	-1.2	-1.4	0.4	5.3	10.8	15.9	19.7	19.3	16.2	10.4	6.6	0.8		(20)	
(21)		2%	DB	-1.7	-1.8	1.5	7.3	14.3	18.4	20.8	22.9	20.3	13.9	7.0	0.1	(21)	
(22)		MCWB	-2.9	-3.0	-0.7	3.8	9.7	14.8	17.8	18.8	15.6	10.2	5.2	-0.8		(22)	
(23)		5%	DB	-3.3	-3.4	0.2	5.3	11.6	16.1	18.7	21.1	18.6	12.4	5.4	-1.7	(23)	
(24)		MCWB	-4.6	-4.8	-1.3	2.8	8.4	13.7	17.0	18.3	15.3	9.5	3.7	-2.8		(24)	
(25)		10%	DB	-5.6	-5.3	-0.6	3.9	9.8	14.3	17.6	19.8	17.3	11.1	3.6	-3.7	(25)	
(26)		MCWB	-6.8	-6.6	-1.9	1.9	7.5	12.5	16.2	17.8	14.8	8.7	1.7	-4.8		(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	-1.0	1.1	6.1	11.8	17.1	20.0	21.1	18.4	12.9	7.4	1.1	(27)	
(28)		MADB	-0.7	-0.1	2.9	9.9	16.0	21.3	23.8	23.7	21.0	14.9	8.9	1.6		(28)	
(29)		2%	WB	-2.9	-2.9	-0.2	4.3	10.2	15.3	18.3	19.9	17.0	11.4	5.7	-0.6	(29)	
(30)		MADB	-1.9	-1.8	0.7	6.5	13.3	17.8	20.1	21.6	18.6	12.8	6.8	0.1		(30)	
(31)		5%	WB	-4.6	-4.8	-1.0	3.2	8.8	13.9	17.2	18.9	16.2	10.4	3.8	-2.7	(31)	
(32)		MADB	-3.4	-3.6	0.0	5.0	10.9	15.9	18.5	20.6	17.8	11.8	5.2	-1.7		(32)	
(33)		10%	WB	-6.8	-6.6	-1.7	2.1	7.7	12.6	16.4	18.1	15.2	9.1	1.9	-4.7	(33)	
(34)		MADB	-5.6	-5.4	-0.6	3.5	9.6	14.2	17.4	19.5	16.8	10.7	3.3	-3.6		(34)	
(35)	Mean Daily Temperature Range	MDBR	9.2	10.7	8.8	5.5	5.7	5.5	4.3	5.4	8.3	8.4	7.9	9.0		(35)	
(36)		5% DB	MADB	6.0	8.2	7.9	8.2	10.5	10.5	6.9	8.3	10.3	10.7	8.6	7.0		(36)
(37)		MCWBR	5.9	7.5	6.5	5.4	6.3	6.4	4.5	5.0	6.5	7.6	7.1	6.8		(37)	
(38)		5% WB	MADB	5.9	8.0	7.3	7.6	9.4	9.2	6.2	6.8	8.1	8.8	8.0	6.9		(38)
(39)		MCWBR	5.9	7.4	6.3	5.4	6.1	5.9	4.2	4.5	6.0	7.4	7.3	6.9		(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.324	0.392	0.481	0.520	0.486	0.455	0.428	0.385	0.393	0.351	0.305		(40)	
(41)		taud	2.099	1.986	1.890	1.847	1.871	2.078	2.245	2.333	2.388	2.174	2.102	2.091		(41)	
(42)		Ebn at Noon	732	789	791	760	750	784	805	810	812	710	641	645		(42)	
(43)		Edh at Noon	85	122	161	188	191	157	131	115	98	102	86	75		(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.38	2.46	3.56	4.30	4.79	5.21	4.51	4.14	3.52	2.25	1.28	1.00		(44)	
(45)		RadStd	0.13	0.16	0.34	0.48	0.53	0.47	0.51	0.41	0.31	0.16	0.13	0.10		(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
											(47)

Nomenclature: See separate page