

MYS TERPENIYA, Russian Federation

WMO: 320990

Lat: 48.6471N

Lon: 144.7435E

Elev: 20

StdP: 14.69

Time Zone: 11.00 (E11)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.1	0.4	-9.7	3.3	-0.9	-6.8	3.8	1.2	52.7	17.8	49.9	16.7	11.7	320	0.950

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	63.4	61.1	61.4	59.4	59.5	57.7	61.7	63.1	59.7	61.1	58.0	59.3	13.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	80.5	62.7	59.0	74.6	60.6	57.3	70.1	59.0	27.7	63.4	26.3	61.2	25.2	59.5	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.4	38.6	32.5	-6.8	67.2	2.6	5.0	-8.7	70.8	-10.2	73.7	-11.7	76.5	-13.6	80.1
			-7.3	63.4	2.6	3.0	-9.1	65.5	-10.7	67.3	-12.1	69.0	-14.0	71.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	12.6	12.3	21.1	29.9	35.0	42.5	50.4	54.5	52.6	43.7	31.5	20.9
	DBStd	15.35	7.26	7.36	5.97	3.52	4.07	4.59	4.32	3.91	3.52	5.10	6.49	6.59
	HDD50	6133	1159	1056	896	603	464	231	49	4	13	201	555	902
	HDD65	11304	1624	1476	1361	1053	929	675	452	327	373	662	1005	1367
	CDD50	305	0	0	0	0	0	6	62	143	90	4	0	0
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH74	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.5	18.2	15.8	14.9	14.7	14.0	13.0	11.6	11.9	13.8	17.5	19.7	20.8
Precipitation	PrecAvg	23.8	1.5	1.3	1.3	1.4	1.6	1.8	2.3	2.6	2.8	3.1	2.2	1.9
	PrecMax	45.4	3.5	4.6	3.1	3.9	3.9	3.9	7.3	7.6	5.6	7.8	6.7	5.0
	PrecMin	13.5	0.3	0.2	0.2	0.1	0.4	0.2	0.3	0.4	0.8	0.3	0.4	0.4
	PrecStd	8.5	0.8	1.0	0.9	1.0	0.9	1.1	1.5	1.8	1.3	2.2	1.5	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.2	33.4	41.0	48.1	59.2	62.7	67.8	66.5	55.1	46.3	37.4
		MCWB	30.3	30.5	31.5	36.6	43.6	55.2	58.9	65.1	63.2	52.2	44.6	36.2
	2%	DB	29.2	28.4	31.7	37.9	45.9	54.8	60.2	64.5	62.0	53.0	44.5	33.8
		MCWB	28.6	27.6	30.4	34.6	42.5	51.2	58.0	62.3	59.3	50.8	43.0	32.2
	5%	DB	27.1	26.0	30.5	36.1	43.8	51.8	58.5	62.7	59.4	51.6	42.7	31.9
		MCWB	26.5	25.1	29.4	33.5	41.1	49.2	56.8	60.9	57.0	49.6	40.6	30.7
	10%	DB	24.2	23.1	29.3	34.6	41.6	49.0	56.8	60.9	57.5	50.2	41.0	30.4
		MCWB	23.4	21.9	28.2	32.5	39.5	47.2	55.5	59.3	55.4	48.0	38.9	29.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.6	30.6	32.0	37.1	44.6	55.7	60.2	65.6	63.3	53.1	45.2	37.0
		MCDB	30.7	31.0	32.7	39.8	47.0	59.0	61.5	67.6	66.0	54.0	45.9	37.5
	2%	WB	28.7	27.7	30.6	35.0	42.8	52.0	58.4	63.0	59.7	51.5	43.3	32.9
		MCDB	29.1	28.3	31.3	37.1	45.3	54.2	59.7	64.1	61.7	52.6	44.1	33.6
	5%	WB	26.4	25.2	29.6	33.9	41.3	49.5	57.0	61.2	57.6	50.0	41.0	31.1
		MCDB	26.9	25.8	30.3	35.7	43.6	51.3	58.3	62.4	59.0	51.3	42.1	31.8
	10%	WB	23.4	21.9	28.4	32.8	39.7	47.3	55.5	59.4	56.0	48.4	39.2	29.1
		MCDB	24.1	22.9	29.3	34.3	41.5	49.0	56.6	60.6	57.2	49.9	40.5	30.3
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.1	7.9	5.8	5.9	6.8	6.4	7.0	6.5	5.6	5.8	5.9
		MCDBR	9.3	10.4	7.1	7.7	10.1	11.4	10.3	10.3	8.9	6.2	6.8	7.2
		MCWBR	9.4	10.4	6.8	6.0	7.6	8.6	8.0	8.1	7.2	5.9	7.7	7.7
	5% WB	MCDBR	8.7	10.2	6.8	7.0	9.5	11.0	9.5	9.9	8.7	6.1	6.7	7.4
		MCWBR	9.1	10.4	6.8	5.6	7.3	8.7	7.9	8.2	7.3	6.4	7.7	8.2
Clear-Sky Solar Irradiance	taub		0.304	0.335	0.400	0.485	0.517	0.481	0.456	0.436	0.392	0.399	0.376	0.338
	taud		2.057	1.912	1.803	1.750	1.856	2.092	2.245	2.313	2.367	2.162	2.113	2.101
	Ebn at Noon		227	246	248	240	239	250	255	255	256	225	197	195
	Edh at Noon		29	42	56	66	62	49	42	37	32	33	28	25
All-Sky Solar Radiation	RadAvg		436	798	1189	1389	1469	1538	1351	1289	1167	769	390	284
	RadStd		49	67	86	153	173	164	161	141	109	53	36	31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page