

MYS TERPENIYA, Russian Federation

WMO: 320990

Lat: 48.6471N

Lon: 144.7435E

Elev: 6

StdP: 101.25

Time Zone: 11.00 (E11)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.9	-17.5	-23.1	0.5	-18.3	-21.6	0.5	-17.1	23.6	-7.9	22.3	-8.5	5.2	320	0.950

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	17.5	16.2	16.4	15.2	15.3	14.3	16.5	17.3	15.4	16.1	14.5	15.2	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.5	17.1	15.0	10.7	15.9	14.1	10.0	15.0	46.6	17.4	43.3	16.2	40.6	15.3	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 20.3	17.3	14.5	DB	-21.5	19.5	1.5	2.8	-22.6	21.5	-23.4	23.2	-24.3	24.7	-25.3	26.7	(4)
(5)			WB	-21.8	17.4	1.4	1.7	-22.9	18.6	-23.7	19.6	-24.5	20.6	-25.6	21.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-10.8	-11.0	-6.1	-1.2	1.7	5.8	10.2	12.5	11.4	6.5	-0.3	-6.2
	DBStd	8.53	4.03	4.09	3.32	1.96	2.26	2.55	2.40	2.17	1.96	2.83	3.60	3.66
	HDD10.0	3407	644	587	498	335	258	128	27	2	7	112	308	501
	HDD18.3	6280	902	820	756	585	516	375	251	182	207	368	558	759
	CDD10.0	169	0	0	0	0	0	3	34	79	50	2	0	0
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.9	8.1	7.1	6.7	6.6	6.3	5.8	5.2	5.3	6.2	7.8	8.8	9.3
Precipitation	PrecAvg	605	39	33	33	36	41	45	59	67	72	80	57	47
	PrecMax	1154	88	117	78	99	98	98	185	194	143	199	169	128
	PrecMin	342	8	5	6	3	9	4	7	11	20	7	10	10
	PrecStd	216	21	26	22	26	23	29	38	45	34	55	38	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.6	-0.4	0.8	5.0	9.0	15.1	17.1	19.9	19.2	12.8	7.9	3.0
		MCWB	-0.9	-0.9	-0.3	2.6	6.5	12.9	15.0	18.4	17.3	11.2	7.0	2.3
	2%	DB	-1.6	-2.0	-0.2	3.3	7.7	12.7	15.7	18.0	16.7	11.7	6.9	1.0
		MCWB	-1.9	-2.5	-0.9	1.5	5.8	10.6	14.4	16.9	15.2	10.4	6.1	0.1
	5%	DB	-2.7	-3.3	-0.8	2.3	6.6	11.0	14.7	17.0	15.2	10.9	5.9	0.0
		MCWB	-3.1	-3.8	-1.5	0.9	5.1	9.6	13.8	16.1	13.9	9.8	4.8	-0.7
	10%	DB	-4.4	-4.9	-1.5	1.4	5.3	9.5	13.8	16.1	14.2	10.1	5.0	-0.9
		MCWB	-4.8	-5.6	-2.1	0.3	4.2	8.4	13.1	15.2	13.0	8.9	3.8	-1.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	-0.8	0.0	2.8	7.0	13.2	15.6	18.6	17.4	11.7	7.3	2.8
		MCDB	-0.7	-0.6	0.4	4.4	8.3	15.0	16.4	19.8	18.9	12.2	7.7	3.1
	2%	WB	-1.9	-2.4	-0.8	1.7	6.0	11.1	14.7	17.2	15.4	10.8	6.3	0.5
		MCDB	-1.6	-2.1	-0.4	2.8	7.4	12.3	15.4	17.8	16.5	11.4	6.7	0.9
	5%	WB	-3.1	-3.8	-1.4	1.0	5.2	9.7	13.9	16.2	14.2	10.0	5.0	-0.5
		MCDB	-2.8	-3.4	-0.9	2.1	6.4	10.7	14.6	16.9	15.0	10.7	5.6	-0.1
	10%	WB	-4.8	-5.6	-2.0	0.4	4.3	8.5	13.1	15.2	13.3	9.1	4.0	-1.6
		MCDB	-4.4	-5.0	-1.5	1.3	5.3	9.4	13.7	15.9	14.0	9.9	4.7	-0.9
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	4.4	3.2	3.3	3.8	3.6	3.9	3.6	3.1	3.2	3.3
		MCDBR	5.2	5.8	3.9	4.3	5.6	6.3	5.7	5.7	5.0	3.4	3.8	4.0
		MCWBR	5.2	5.8	3.8	3.3	4.2	4.8	4.4	4.5	4.0	3.3	4.3	4.3
	5% WB	MCDBR	4.8	5.6	3.8	3.9	5.3	6.1	5.3	5.5	4.8	3.4	3.7	4.1
		MCWBR	5.1	5.8	3.8	3.1	4.1	4.8	4.4	4.6	4.1	3.6	4.3	4.5
Clear-Sky Solar Irradiance	taub	0.304	0.335	0.400	0.485	0.517	0.481	0.456	0.436	0.392	0.399	0.376	0.338	
	taud	2.057	1.912	1.803	1.750	1.856	2.092	2.245	2.313	2.367	2.162	2.113	2.101	
	Ebn at Noon	716	776	783	757	754	789	805	805	806	708	622	615	
	Edh at Noon	91	133	177	208	195	155	131	118	101	105	88	78	
All-Sky Solar Radiation	RadAvg	1.37	2.52	3.75	4.38	4.63	4.85	4.26	4.06	3.68	2.42	1.23	0.90	
	RadStd	0.16	0.21	0.27	0.48	0.54	0.52	0.51	0.45	0.34	0.17	0.12	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page