

MYS VASIL'YEVA, Russian Federation

WMO: 322170

Lat: 50.004N

Lon: 155.391E

Elev: 52

StdP: 14.67

Time Zone: 11.00 (E11)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	13.6	4.8	7.1	13.7	7.3	8.0	15.4	53.8	28.9	50.1	26.0	13.8	280	0.939

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	59.3	54.2	57.1	52.8	55.2	52.4	55.4	57.2	54.1	55.7	52.9	54.5	8.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.6	63.6	55.9	53.3	60.6	54.3	52.1	57.9	53.3	23.5	57.2	22.7	55.6	22.0	54.7	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
45.7	40.2	35.7	DB	6.4	65.6	2.0	1.9	5.0	67.0	3.8	68.1	2.6	69.2	1.1	70.6	
			WB	5.4	59.8	1.6	3.1	4.3	62.0	3.3	63.8	2.4	65.5	1.3	67.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.9	22.2	23.3	25.4	30.4	35.7	42.6	48.0	51.2	48.8	42.5	33.1	27.0
	DBStd	10.75	5.24	5.54	4.28	3.19	2.88	3.75	3.17	2.43	2.58	3.23	4.68	4.46
	HDD50	5225	862	746	762	587	444	226	80	14	52	232	508	712
	HDD65	10613	1327	1166	1227	1037	909	672	528	429	486	697	958	1177
	CDD50	86	0	0	0	0	0	3	17	50	16	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	15.2	19.9	17.9	17.5	15.7	13.9	10.8	10.4	10.9	12.1	15.6	18.8	18.6
	PrecAvg	46.3	4.0	3.6	3.6	2.6	2.4	2.8	3.5	4.1	4.4	5.3	5.6	4.4
Precipitation	PrecMax	53.7	6.4	6.1	6.5	5.8	3.8	5.4	6.8	7.8	7.0	8.4	9.7	8.1
	PrecMin	36.0	2.6	1.1	1.9	0.7	0.6	0.5	0.5	1.6	2.8	2.7	3.0	1.9
	PrecStd	4.4	0.9	1.2	1.1	1.0	0.8	1.4	1.6	1.6	1.2	1.4	1.5	1.4
	PrecStd	4.4	0.9	1.2	1.1	1.0	0.8	1.4	1.6	1.6	1.2	1.4	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.0	34.2	34.1	37.6	48.2	62.7	61.2	63.5	58.9	53.5	45.8	37.7
		MCWB	33.7	32.8	32.8	35.9	41.5	51.9	55.2	57.5	53.5	48.6	45.3	36.3
	2%	DB	33.1	32.4	32.4	36.0	44.0	56.7	58.3	59.4	56.9	50.3	43.9	35.9
		MCWB	32.2	31.8	31.1	34.6	40.7	49.8	54.2	55.2	52.0	46.9	43.1	34.0
	5%	DB	31.9	31.5	31.7	35.0	41.4	51.9	55.4	57.4	55.0	49.0	42.2	34.2
		MCWB	31.1	30.9	30.5	33.8	39.1	47.7	52.6	53.5	51.8	46.5	41.4	32.4
	10%	DB	30.6	30.6	31.0	34.1	39.7	48.4	53.2	55.5	53.3	47.6	40.4	33.3
		MCWB	29.6	29.9	29.9	32.9	38.2	45.5	51.4	53.2	50.8	45.8	39.3	31.6
	0.4%	WB	34.3	33.3	33.5	36.8	43.3	53.6	57.7	58.8	55.0	49.8	45.6	37.2
		MCDB	34.6	33.6	33.8	37.0	45.9	59.9	58.8	62.0	56.6	51.7	45.6	37.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.5	32.1	31.9	35.2	41.1	50.1	54.5	56.2	53.6	48.5	43.5	34.7
		MCDB	32.8	32.2	32.0	35.4	43.5	55.7	56.7	58.3	55.7	49.6	43.7	35.1
	5%	WB	31.3	31.2	31.2	34.2	39.6	47.8	52.9	54.7	52.3	47.2	41.6	33.2
		MCDB	31.8	31.4	31.4	34.5	41.1	51.7	55.1	56.2	53.8	48.2	42.0	33.8
	10%	WB	29.6	30.2	30.4	33.4	38.4	45.9	51.5	53.6	51.3	46.2	39.5	32.0
		MCDB	30.5	30.5	30.7	33.8	39.5	48.1	53.3	54.7	52.5	47.2	40.1	32.9
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.0	7.3	5.4	6.2	8.7	8.0	7.9	7.7	7.1	6.6	6.3
		MCDBR	5.2	6.2	7.9	5.8	10.4	17.2	13.3	12.4	11.4	9.5	8.1	6.4
		MCWBR	5.7	5.7	7.3	5.0	7.5	11.3	9.8	8.9	8.4	7.7	7.8	6.5
	5% WB	MDBR	4.8	5.9	6.5	4.6	9.4	15.3	11.9	9.9	9.0	7.6	7.3	6.0
		MCWBR	5.6	5.7	6.5	4.6	7.2	10.6	9.3	7.9	7.3	6.9	7.7	6.7
Clear-Sky Solar Irradiance	taub		0.356	0.385	0.437	0.487	0.510	0.483	0.476	0.452	0.393	0.411	0.394	0.362
	taud		2.092	2.039	1.943	1.868	1.884	2.048	2.128	2.201	2.333	2.102	2.041	2.044
	Ebn at Noon		200	226	235	239	240	249	248	248	252	214	180	173
	Edh at Noon		27	37	48	58	60	51	47	41	33	34	29	25
All-Sky Solar Radiation	RadAvg		262	455	809	1122	1319	1407	1302	1137	978	621	315	207
	RadStd		13	42	58	105	157	141	144	105	69	46	20	20

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page