

UST'-VOYAMPOLKA, Russian Federation

WMO: 322520

Lat: 58.510N

Lon: 159.175E

Elev: 24

StdP: 14.68

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.4	-22.1	-29.6	1.0	-25.2	-26.2	1.3	-21.8	44.1	25.8	33.7	21.3	9.0	140	0.852

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	63.0	57.5	60.3	56.0	58.3	54.9	58.7	61.3	56.8	59.5	55.3	57.6	9.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	70.4	60.4	55.4	65.3	58.3	53.8	61.7	56.6	25.6	61.4	24.4	59.8	23.4	57.8	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.4	26.1	22.2	DB	-27.8	71.6	2.8	5.2	-29.8	75.3	-31.5	78.4	-33.0	81.3	-35.1	85.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	1.8	4.6	12.4	24.8	36.2	44.9	51.4	52.8	46.9	34.4	20.9	7.9		
	DBStd	20.21	15.02	14.67	12.55	8.26	4.83	4.15	3.77	3.79	4.54	6.97	10.13	12.18		
	HDD50	8084	1495	1272	1165	755	426	160	26	15	111	482	872	1305		
	HDD65	13363	1960	1692	1630	1205	891	603	423	378	542	947	1322	1770		
	CDD50	197	0	0	0	0	0	7	69	102	19	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	3	0	0	0	0	0	0	3	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	9.9	10.7	10.5	9.9	9.3	8.9	8.3	7.7	8.3	10.0	11.1	12.1	11.5		
	PrecAvg	17.6	0.5	0.4	0.5	0.6	0.7	1.5	2.0	3.0	2.4	2.6	2.1	1.1		
(15) Precipitation	PrecMax	24.8	1.4	1.1	1.3	1.5	2.2	3.5	3.7	6.9	7.2	4.9	4.7	2.5		
	PrecMin	8.0	0.1	0.0	0.1	0.2	0.0	0.2	0.1	0.5	0.3	0.7	0.8	0.1		
	PrecStd	4.2	0.3	0.3	0.3	0.4	0.6	0.9	0.9	1.9	1.6	1.0	0.9	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	38.4	38.7	41.7	55.3	62.4	69.7	67.2	60.7	51.8	41.1	36.4		
		MCWB	33.6	36.3	34.1	37.0	47.9	54.4	60.1	61.7	55.6	44.3	35.9	32.9		
	2%	DB	33.5	34.4	35.4	39.1	50.1	56.8	63.0	63.4	57.1	47.5	37.9	33.5		
		MCWB	30.0	31.2	31.9	35.2	45.0	51.3	57.6	58.1	53.9	43.7	34.8	31.0		
	5%	DB	30.0	31.1	33.1	37.5	47.1	54.0	60.1	60.9	55.2	45.3	35.8	30.4		
		MCWB	27.1	28.7	30.3	34.1	42.5	49.6	55.9	56.6	52.5	42.5	33.7	28.1		
	10%	DB	25.8	26.6	29.8	35.6	43.7	52.0	58.0	58.9	53.8	43.8	33.6	26.0		
		MCWB	23.5	25.2	27.6	32.9	40.1	48.4	54.7	55.7	51.4	41.3	31.8	24.4		
	0.4%	WB	34.1	37.3	34.6	38.3	49.2	55.1	62.3	63.3	56.5	46.4	37.1	33.6		
		MCDB	37.2	38.3	37.4	40.5	54.1	60.3	66.8	66.3	59.3	49.2	40.5	36.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.3	31.5	32.4	35.6	45.6	52.0	58.6	59.3	54.4	44.2	35.2	31.1		
		MCDB	33.0	34.0	35.3	38.2	49.4	55.6	61.5	61.6	56.4	46.7	37.4	33.2		
	5%	WB	27.5	28.7	30.4	34.1	42.5	50.2	56.6	57.3	53.0	42.8	33.8	28.1		
		MCDB	30.2	31.2	33.3	36.9	46.2	53.5	59.6	59.9	54.9	45.2	35.8	30.2		
	10%	WB	24.0	25.3	27.7	32.9	40.3	48.5	54.9	55.8	51.7	41.3	32.0	24.4		
		MCDB	26.1	26.9	29.9	35.5	43.3	51.4	57.4	58.2	53.4	43.5	33.6	26.0		
	5% DB	MDBR	13.4	12.8	14.8	11.9	9.1	9.4	9.2	9.2	9.8	8.6	10.2	13.3		
		MCDBR	14.7	12.1	10.4	11.5	16.1	15.0	14.3	13.6	10.8	10.3	10.5	13.2		
		MCWBR	13.2	10.6	9.0	8.8	11.2	10.4	9.8	9.3	8.5	8.2	8.6	11.5		
		MCWBR	14.6	11.9	10.8	10.1	14.8	13.1	12.9	10.7	9.9	9.2	9.4	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.244	0.282	0.335	0.409	0.458	0.426	0.453	0.427	0.351	0.333	0.286	0.243		
		taud	2.121	2.107	2.008	1.914	1.968	2.203	2.165	2.229	2.437	2.292	2.132	2.052		
	Ebn at Noon		187	233	248	247	244	257	246	243	250	212	161	140		
		Edh at Noon	16	26	39	51	52	42	43	37	26	22	16	12		
(44) All-Sky Solar Radiation	RadAvg		146	407	891	1314	1604	1669	1546	1131	800	401	141	75		
	RadStd		22	47	76	125	174	187	176	127	73	41	14	7		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page