

OZERNOVSKIY, Russian Federation

WMO: 325940

Lat: 51.495N

Lon: 156.504E

Elev: 93

StdP: 14.65

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.3	7.4	-8.4	3.5	5.3	-3.1	4.7	8.8	57.0	31.6	51.9	27.5	13.6	50	0.897

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	62.6	58.4	59.4	56.0	57.3	54.4	59.2	61.5	56.7	58.6	54.9	56.6	17.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.0	72.2	60.5	55.6	66.1	57.9	53.9	62.1	55.9	25.9	61.6	24.3	58.8	23.2	56.8	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.1	39.1	33.0	-1.4	68.9	3.9	3.4	-4.2	71.4	-6.5	73.3	-8.7	75.2	-11.5	77.7		
(5)			-2.0	63.1	3.7	3.5	-4.7	65.6	-6.8	67.7	-8.9	69.7	-11.6	72.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.1	21.4	20.6	24.9	31.1	37.4	43.7	50.4	53.0	49.7	42.0	32.6	25.4		
	DBStd	12.24	6.72	7.35	5.85	4.06	3.79	4.02	3.76	3.35	3.75	4.35	5.47	5.96		
	HDD50	5266	886	824	777	566	391	193	40	7	48	249	522	763		
	HDD65	10548	1351	1244	1242	1016	856	639	454	373	460	713	972	1228		
	CDD50	193	0	0	0	0	0	4	51	99	38	1	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.8	15.2	16.2	16.5	14.7	11.9	9.7	8.8	9.3	12.2	15.9	18.1	16.7		
	PrecAvg	29.5	2.2	1.8	1.9	1.4	1.3	1.9	2.5	3.4	3.4	4.0	3.3	2.6		
	PrecMax	37.8	4.0	3.1	4.2	2.5	2.2	4.1	6.5	7.4	7.0	6.3	5.3	5.1		
(15) Precipitation	PrecMin	20.9	1.3	0.4	0.7	0.4	0.3	0.3	0.2	1.3	1.5	2.2	2.1	0.9		
	PrecStd	3.8	0.7	0.7	0.7	0.6	0.5	1.1	1.4	1.5	1.3	1.2	0.8	0.9		
	DB	36.7	37.3	38.1	44.7	52.4	59.0	66.7	68.2	63.9	55.2	49.0	42.9			
	MCWB	33.9	34.1	33.8	40.9	46.1	52.3	60.5	63.7	59.6	49.7	45.9	40.0			
	2% DB	34.7	34.4	35.8	40.0	48.4	54.2	61.6	63.3	59.5	52.1	45.5	38.6			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	32.1	31.6	32.6	36.1	43.5	49.8	56.7	60.0	56.0	48.7	43.1	36.3			
	5% DB	32.8	32.3	34.1	37.9	45.5	51.7	58.3	59.9	56.7	50.0	42.8	36.0			
	MCWB	30.6	29.8	31.4	34.5	41.3	48.3	54.8	56.9	53.5	46.9	40.7	33.8			
	10% DB	30.9	30.4	32.4	36.3	43.0	49.6	55.8	57.7	54.7	48.4	40.5	33.7			
	MCWB	28.9	28.1	30.4	33.3	39.6	46.7	53.2	55.4	52.2	46.0	38.2	31.5			
	0.4% WB	34.6	34.7	35.3	41.4	47.6	53.7	61.8	64.5	60.3	52.0	46.5	40.2			
	MCDB	36.0	36.5	36.9	44.2	51.4	57.1	65.4	67.1	62.9	53.9	48.5	42.5			
	2% WB	32.5	32.3	33.2	36.9	44.1	50.6	57.5	60.6	56.7	49.3	43.2	36.7			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	34.1	33.9	35.0	39.1	47.4	53.3	60.2	62.8	58.8	51.0	45.0	38.4			
	5% WB	30.8	30.1	31.8	35.2	41.6	48.6	55.4	57.6	54.2	47.8	41.0	34.0			
	MCDB	32.5	32.0	33.5	37.2	44.7	50.9	57.6	59.2	55.8	49.4	42.6	35.7			
	10% WB	29.0	28.2	30.5	33.8	40.0	47.2	53.5	55.8	52.8	46.4	38.4	31.7			
	MCDB	30.8	30.1	32.3	35.8	42.6	49.2	55.3	57.2	54.2	48.0	40.2	33.5			
(35) Mean Daily Temperature Range	MDBR	8.6	8.0	7.2	6.0	7.0	6.9	6.6	6.3	7.4	7.4	7.2	7.8			
	5% DB	7.4	7.9	7.6	8.8	12.0	11.5	11.4	10.5	10.4	10.0	9.9	8.5			
	MCWBR	7.3	6.9	6.5	6.9	8.1	8.2	8.1	7.9	7.7	8.1	9.4	7.5			
	5% WB	7.3	7.4	7.2	8.4	11.2	10.0	10.5	9.7	8.8	8.8	10.1	8.0			
	MCWBR	7.5	7.0	6.9	6.9	8.2	7.7	8.0	7.9	7.3	7.9	9.8	7.5			
(40) Clear-Sky Solar Irradiance	taub	0.317	0.346	0.396	0.453	0.485	0.461	0.460	0.432	0.379	0.389	0.363	0.327			
	taud	2.115	2.054	1.954	1.863	1.891	2.086	2.153	2.241	2.364	2.154	2.066	2.057			
	Ebn at Noon	207	235	245	246	245	253	252	252	255	218	183	176			
	Edh at Noon	25	35	47	57	59	49	45	39	31	31	26	23			
	RadAvg	256	433	729	1093	1321	1573	1451	1241	972	565	281	200			
(45) All-Sky Solar Radiation	RadStd	33	77	72	123	129	187	152	103	63	44	29	34			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page