

OZERNOVSKIY, Russian Federation

WMO: 325940

Lat: 51.495N

Lon: 156.504E

Elev: 28

StdP: 100.98

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.9	-13.7	-22.4	0.5	-14.8	-19.5	0.7	-12.9	25.5	-0.2	23.2	-2.5	6.1	50	0.897

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	17.0	14.6	15.2	13.3	14.0	12.4	15.1	16.4	13.7	14.8	12.7	13.7	7.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	10.3	15.8	13.1	9.4	14.4	12.2	8.9	13.3	42.4	16.4	38.7	14.9	36.1	13.8	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	17.5	14.7	DB	-18.6	20.5	2.2	1.9	-20.1	21.9	-21.4	23.0	-22.6	24.0	-24.2	25.4	(4)
(5)			WB	-18.9	17.3	2.0	2.0	-20.4	18.7	-21.6	19.8	-22.7	20.9	-24.2	22.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-5.9	-6.4	-3.9	-0.5	3.0	6.5	10.2	11.6	9.8	5.6	0.3	-3.7
	DBStd	6.80	3.73	4.08	3.25	2.26	2.11	2.24	2.09	1.86	2.08	2.42	3.04	3.31
	HDD10.0	2926	492	458	432	314	217	107	22	4	27	138	290	424
	HDD18.3	5860	751	691	690	564	476	355	252	207	256	396	540	682
	CDD10.0	107	0	0	0	0	0	2	28	55	21	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.1	6.8	7.3	7.4	6.6	5.3	4.4	3.9	4.1	5.5	7.1	8.1	7.5
Precipitation	PrecAvg	749	55	45	47	36	33	49	64	86	86	101	83	66
	PrecMax	960	101	79	106	63	55	104	166	189	178	161	135	129
	PrecMin	532	32	10	19	11	7	8	4	33	39	55	54	24
	PrecStd	96	18	18	18	14	12	27	35	39	33	30	20	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.6	2.9	3.4	7.0	11.3	15.0	19.3	20.1	17.7	12.9	9.5	6.0
		MCWB	1.1	1.2	1.0	5.0	7.8	11.3	15.9	17.6	15.4	9.8	7.7	4.5
	2%	DB	1.5	1.3	2.1	4.4	9.1	12.3	16.4	17.4	15.3	11.1	7.5	3.6
		MCWB	0.1	-0.2	0.4	2.3	6.4	9.9	13.7	15.5	13.3	9.3	6.2	2.4
	5%	DB	0.4	0.2	1.2	3.3	7.5	11.0	14.6	15.5	13.7	10.0	6.0	2.2
		MCWB	-0.8	-1.2	-0.3	1.4	5.2	9.0	12.7	13.8	11.9	8.3	4.8	1.0
	10%	DB	-0.6	-0.9	0.2	2.4	6.1	9.8	13.2	14.3	12.6	9.1	4.7	1.0
		MCWB	-1.7	-2.2	-0.9	0.7	4.2	8.2	11.8	13.0	11.2	7.8	3.5	-0.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.4	1.5	1.8	5.2	8.7	12.0	16.6	18.0	15.7	11.1	8.0	4.6
		MCDB	2.2	2.5	2.7	6.8	10.8	13.9	18.6	19.5	17.2	12.2	9.1	5.8
	2%	WB	0.3	0.2	0.6	2.7	6.7	10.3	14.2	15.9	13.7	9.6	6.2	2.6
		MCDB	1.2	1.1	1.6	3.9	8.6	11.8	15.7	17.1	14.9	10.6	7.2	3.6
	5%	WB	-0.7	-1.0	-0.1	1.8	5.4	9.2	13.0	14.2	12.3	8.8	5.0	1.1
		MCDB	0.3	0.0	0.8	2.9	7.1	10.5	14.2	15.1	13.2	9.7	5.9	2.1
	10%	WB	-1.7	-2.1	-0.8	1.0	4.4	8.4	12.0	13.2	11.5	8.0	3.5	-0.2
		MCDB	-0.6	-1.1	0.2	2.1	5.9	9.5	12.9	14.0	12.3	8.9	4.6	0.8
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.5	4.0	3.3	3.9	3.9	3.7	3.5	4.1	4.1	4.0	4.3
		MCDBR	4.1	4.4	4.2	4.9	6.7	6.4	6.3	5.8	5.8	5.6	5.5	4.7
		MCWBR	4.0	3.8	3.6	3.8	4.5	4.5	4.5	4.4	4.3	4.5	5.2	4.2
	5% WB	MCDBR	4.1	4.1	4.0	4.7	6.2	5.6	5.8	5.4	4.9	4.9	5.6	4.4
		MCWBR	4.1	3.9	3.8	3.8	4.6	4.3	4.5	4.4	4.0	4.4	5.5	4.1
Clear-Sky Solar Irradiance	taub	0.317	0.346	0.396	0.453	0.485	0.461	0.460	0.432	0.379	0.389	0.363	0.327	
	taud	2.115	2.054	1.954	1.863	1.891	2.086	2.153	2.241	2.364	2.154	2.066	2.057	
	Ebn at Noon	654	741	773	775	772	799	793	795	803	686	577	556	
	Edh at Noon	78	109	147	181	185	154	142	124	98	99	82	71	
All-Sky Solar Radiation	RadAvg	0.81	1.36	2.30	3.45	4.17	4.96	4.58	3.91	3.06	1.78	0.89	0.63	
	RadStd	0.10	0.24	0.23	0.39	0.41	0.59	0.48	0.33	0.20	0.14	0.09	0.11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page