

NIKOLSKOYE, Russian Federation

WMO: 326180

Lat: 55.1934N

Lon: 165.9830E

Elev: 58

StdP: 14.66

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.2	16.6	6.0	7.5	16.0	8.5	8.5	18.4	48.6	28.3	43.9	30.5	11.3	50	0.917

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	58.8	55.8	57.2	54.9	55.9	54.0	56.6	57.9	55.5	56.7	54.5	55.7	9.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.8	66.5	57.2	54.8	64.0	56.2	53.8	61.6	55.3	24.2	58.1	23.6	56.7	22.9	55.8	62.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
38.4	33.9	30.1	DB	11.2	64.0	1.8	3.1	9.9	66.2	8.9	68.0	7.9	69.7	6.6	72.0
			WB	10.0	59.3	1.7	1.6	8.8	60.5	7.9	61.4	6.9	62.3	5.7	63.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	26.4	26.3	27.9	31.9	37.2	42.9	49.3	53.5	50.5	42.5	34.3	28.3
	DBStd	10.33	5.05	5.25	4.97	3.43	2.51	2.97	3.20	2.58	3.17	4.02	4.65	4.95
	HDD50	4697	732	665	684	544	395	212	51	4	32	233	472	673
	HDD65	9984	1197	1085	1149	994	860	662	486	358	435	698	922	1138
	CDD50	189	0	0	0	0	0	0	31	111	47	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.7	16.6	17.3	15.8	15.5	13.2	12.3	12.2	12.0	13.3	15.1	16.3	17.0
Precipitation	PrecAvg	26.5	2.2	2.0	1.8	1.8	1.5	1.4	1.6	2.6	2.8	3.5	2.9	2.4
	PrecMax	40.9	5.5	4.6	3.9	5.8	3.8	3.7	4.0	5.7	10.7	6.4	4.8	4.8
	PrecMin	18.3	0.9	0.8	0.2	0.4	0.2	0.1	0.1	0.1	0.5	1.5	1.1	1.1
	PrecStd	4.1	0.9	0.9	0.7	1.2	0.8	0.8	0.9	1.3	1.5	1.1	1.0	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	37.3	37.6	40.1	48.5	54.8	61.2	62.1	58.3	51.5	44.6	41.3
		MCWB	36.5	35.9	36.2	38.0	43.4	48.5	56.6	57.7	54.4	48.4	42.8	39.7
	2%	DB	35.8	35.6	35.8	38.1	44.0	50.3	57.4	59.5	56.7	50.2	43.1	38.6
		MCWB	34.3	34.5	34.4	36.3	41.2	47.1	54.6	56.6	54.1	47.7	41.2	37.3
	5%	DB	34.7	34.3	34.9	36.9	41.9	48.2	55.1	58.1	55.6	48.9	41.9	36.5
		MCWB	33.4	33.1	33.4	35.1	39.7	46.0	53.2	55.7	53.3	46.7	40.0	35.0
	10%	DB	33.5	33.2	33.9	35.9	40.6	46.8	53.6	56.8	54.7	47.8	40.7	34.8
		MCWB	32.4	31.9	32.4	34.3	38.7	45.2	52.2	54.9	52.6	45.6	38.9	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.5	36.2	36.8	38.8	43.6	49.2	57.5	58.7	56.5	49.9	43.4	40.0
		MCDB	37.7	36.9	37.1	39.5	46.3	53.0	59.9	60.6	57.3	50.5	44.0	41.0
	2%	WB	34.8	34.6	34.8	36.8	41.7	47.5	55.1	57.4	55.2	48.1	41.7	37.6
		MCDB	35.5	35.2	35.4	37.6	43.6	49.5	56.8	58.8	56.1	49.5	42.5	38.6
	5%	WB	33.7	33.3	33.8	35.6	40.2	46.4	53.6	56.3	53.9	47.1	40.4	35.1
		MCDB	34.4	34.0	34.6	36.5	41.7	47.8	54.8	57.5	54.9	48.5	41.5	36.1
	10%	WB	32.7	32.3	32.8	34.6	39.2	45.5	52.3	55.3	52.9	46.0	38.9	33.5
		MCDB	33.5	33.1	33.7	35.6	40.2	46.7	53.5	56.4	54.1	47.6	40.3	34.5
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.1	5.0	4.3	4.8	4.8	4.3	4.7	4.9	4.9	4.6	5.0
		MCDBR	5.2	4.9	4.8	5.0	7.1	7.9	7.2	7.0	5.8	5.5	4.6	5.4
		MCWBR	5.1	5.1	4.6	4.5	5.2	5.4	5.3	4.9	4.6	5.0	4.5	5.6
	5% WB	MCDBR	4.8	5.0	4.6	4.7	6.3	7.1	6.5	6.2	4.7	4.9	4.4	4.9
		MCWBR	5.1	5.3	4.8	4.5	4.9	5.1	4.9	4.6	4.3	4.9	4.6	5.3
Clear-Sky Solar Irradiance	taub	0.338	0.358	0.392	0.430	0.452	0.427	0.443	0.425	0.371	0.368	0.351	0.326	
	taud	2.098	2.125	2.088	2.031	2.048	2.222	2.217	2.266	2.388	2.208	2.101	2.079	
	Ebn at Noon	171	218	239	248	251	260	253	249	250	212	162	144	
	Edh at Noon	21	30	39	47	49	42	41	37	29	27	21	17	
All-Sky Solar Radiation	RadAvg	158	347	728	1128	1316	1308	1293	1099	907	518	219	117	
	RadStd	17	39	67	106	156	150	110	92	66	37	16	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page