

NIKOLSKOYE, Russian Federation

WMO: 326180

Lat: 55.1934N

Lon: 165.9830E

Elev: 18

StdP: 101.11

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.9	-8.5	-14.4	1.1	-8.9	-13.1	1.2	-7.6	21.7	-2.1	19.6	-0.9	5.0	50	0.917

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	14.9	13.2	14.0	12.7	13.3	12.2	13.7	14.4	13.1	13.7	12.5	13.1	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	9.5	14.0	12.7	9.1	13.5	12.1	8.8	13.0	38.5	14.5	36.9	13.7	35.4	13.2	16.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	15.2	13.5	-11.6	17.8	1.0	1.7	-12.3	19.0	-12.9	20.0	-13.4	21.0	-14.1	22.2
			-12.2	15.2	0.9	0.9	-12.9	15.8	-13.4	16.4	-13.9	16.9	-14.6	17.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-3.1	-3.2	-2.3	-0.1	2.9	6.1	9.6	11.9	10.3	5.8	1.3	-2.1		
	DBStd	5.74	2.80	2.92	2.76	1.90	1.40	1.65	1.78	1.43	1.76	2.23	2.58	2.75		
	HDD10.0	2609	407	369	380	302	219	118	28	2	18	129	262	374		
	HDD18.3	5547	665	603	638	552	478	368	270	199	242	388	512	632		
	CDD10.0	105	0	0	0	0	0	0	17	62	26	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	6.6	7.4	7.7	7.1	6.9	5.9	5.5	5.5	5.4	5.9	6.7	7.3	7.6		
(15) Precipitation	PrecAvg	672	57	50	46	45	39	35	41	67	71	88	74	62		
	PrecMax	1039	139	118	100	147	97	93	101	144	271	162	121	122		
	PrecMin	466	23	20	6	10	5	3	3	3	13	39	28	29		
	PrecStd	104	24	24	19	30	21	20	22	34	38	27	25	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	3.0	3.1	4.5	9.1	12.7	16.2	16.7	14.6	10.8	7.0	5.1		
		MCWB	2.5	2.1	2.3	3.3	6.3	9.2	13.6	14.3	12.5	9.1	6.0	4.3		
	2%	DB	2.1	2.0	2.1	3.4	6.6	10.2	14.1	15.3	13.7	10.1	6.2	3.7		
		MCWB	1.3	1.4	1.3	2.4	5.1	8.4	12.5	13.6	12.3	8.7	5.1	2.9		
	5%	DB	1.5	1.3	1.6	2.7	5.5	9.0	12.9	14.5	13.1	9.4	5.5	2.5		
		MCWB	0.8	0.6	0.8	1.7	4.3	7.8	11.8	13.2	11.8	8.2	4.5	1.7		
	10%	DB	0.9	0.6	1.1	2.2	4.8	8.2	12.0	13.8	12.6	8.8	4.8	1.6		
		MCWB	0.2	0.0	0.2	1.3	3.7	7.3	11.2	12.7	11.5	7.6	3.8	0.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.5	2.4	2.6	3.8	6.4	9.6	14.2	14.9	13.6	9.9	6.4	4.4		
		MCDB	3.2	2.7	2.8	4.2	8.0	11.7	15.5	15.9	14.0	10.3	6.7	5.0		
	2%	WB	1.5	1.5	1.6	2.7	5.4	8.6	12.8	14.1	12.9	9.0	5.4	3.1		
		MCDB	2.0	1.8	1.9	3.1	6.4	9.7	13.8	14.9	13.4	9.7	5.9	3.6		
	5%	WB	0.9	0.7	1.0	2.0	4.6	8.0	12.0	13.5	12.2	8.4	4.7	1.7		
		MCDB	1.4	1.1	1.5	2.5	5.4	8.8	12.7	14.2	12.7	9.2	5.3	2.3		
	10%	WB	0.4	0.1	0.5	1.5	4.0	7.5	11.3	13.0	11.6	7.8	3.9	0.9		
		MCDB	0.8	0.6	0.9	2.0	4.6	8.2	11.9	13.6	12.3	8.6	4.6	1.4		
(35) Mean Daily Temperature Range	MDBR		2.8	2.8	2.8	2.4	2.7	2.6	2.4	2.6	2.7	2.7	2.5	2.8		
	5% DB	MCDBR	2.9	2.7	2.6	2.8	3.9	4.4	4.0	3.9	3.2	3.1	2.5	3.0		
		MCWBR	2.8	2.8	2.6	2.5	2.9	3.0	2.9	2.7	2.6	2.8	2.5	3.1		
	5% WB	MCDBR	2.7	2.8	2.6	2.6	3.5	4.0	3.6	3.4	2.6	2.7	2.5	2.7		
		MCWBR	2.8	2.9	2.7	2.5	2.7	2.8	2.7	2.6	2.4	2.7	2.6	2.9		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.358	0.392	0.430	0.452	0.427	0.443	0.425	0.371	0.368	0.351	0.326		
	taud		2.098	2.125	2.088	2.031	2.048	2.222	2.217	2.266	2.388	2.208	2.101	2.079		
	Ebn at Noon		538	686	755	783	791	820	797	786	787	667	512	453		
	Edh at Noon		67	93	122	148	154	132	130	117	90	85	66	55		
(44) All-Sky Solar Radiation	RadAvg		0.50	1.09	2.30	3.56	4.15	4.12	4.08	3.46	2.86	1.63	0.69	0.37		
	RadStd		0.05	0.12	0.21	0.33	0.49	0.47	0.35	0.29	0.21	0.12	0.05	0.03		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page