

ZHITCKOVICHI, BelarusWMO: **330270**Lat: **52.2144N**Lon: **27.8667E**Elev: **137**StdP: **99.69**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.6	-15.9	-22.7	0.5	-18.6	-19.2	0.7	-15.4	6.7	1.8	6.1	0.0	1.3	350	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	30.1	20.1	28.4	19.3	26.7	18.5	21.6	27.9	20.5	26.2	19.6	24.7	2.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.5	24.1	18.5	13.6	22.9	17.7	12.9	22.1	63.4	28.1	59.6	26.3	56.4	24.8	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.4	4.8	-24.0	32.4	3.4	1.8	-26.5	33.7	-28.5	34.8	-30.4	35.8	-32.9	37.2		
(5)			-24.2	22.8	3.4	1.4	-26.6	23.8	-28.6	24.6	-30.5	25.4	-33.0	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-3.9	-2.7	1.8	8.8	14.2	17.3	19.7	18.2	12.9	7.4	2.4	-2.1
	DBStd	9.39	5.86	5.78	4.63	4.31	4.25	3.35	3.10	3.16	3.44	4.16	4.80	5.61
	HDD10.0	1845	432	356	256	72	11	0	0	0	12	102	229	376
	HDD18.3	3954	690	589	513	286	141	61	21	41	164	339	477	634
	CDD10.0	1076	0	0	1	37	140	218	301	256	101	22	2	0
	CDD18.3	143	0	0	0	1	12	28	63	38	2	0	0	0
	CDH23.3	1378	0	0	0	13	143	272	588	333	28	1	0	0
	CDH26.7	362	0	0	0	2	31	59	177	90	2	0	0	0
(14) Wind	WSAvg	2.1	2.4	2.4	2.5	2.3	2.2	2.1	1.9	1.8	1.8	2.0	2.2	2.3
(15) Precipitation	PrecAvg	723	45	43	46	45	68	78	116	70	59	55	50	48
	PrecMax	929	82	84	84	99	153	191	242	144	155	222	96	87
	PrecMin	572	9	21	11	4	24	28	27	10	3	4	10	15
	PrecStd	92	18	16	20	20	27	39	57	34	35	46	23	21
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	9.4	16.1	25.1	29.8	30.8	32.8	32.2	26.7	22.0	14.5	9.1
		MCWB	5.5	6.4	9.4	14.7	18.3	19.6	21.4	22.1	17.4	15.4	11.2	7.8
	2%	DB	5.5	6.8	13.4	21.5	27.2	28.8	30.6	29.1	23.6	17.8	12.1	7.2
		MCWB	4.1	4.9	7.6	12.7	17.7	19.1	20.6	20.3	16.4	13.6	10.4	6.2
	5%	DB	4.1	5.3	10.7	19.1	24.6	26.7	28.6	26.7	21.2	15.6	10.1	5.9
		MCWB	3.1	3.7	6.4	11.5	16.4	18.0	19.8	18.7	15.3	12.5	8.7	5.1
	10%	DB	2.6	3.8	8.4	16.7	22.3	24.6	26.8	24.8	19.3	13.7	8.6	4.2
		MCWB	1.9	2.5	5.1	10.2	14.9	17.5	19.2	18.0	14.4	11.3	7.4	3.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	7.0	10.3	15.8	20.0	21.2	23.2	23.2	18.2	16.7	12.0	8.1
		MCDB	7.2	8.9	14.7	23.2	27.2	27.8	29.7	29.7	24.0	20.7	13.6	8.7
	2%	WB	4.3	5.2	8.3	13.7	18.3	20.2	21.9	21.5	17.0	14.5	10.5	6.4
		MCDB	5.2	6.5	12.0	19.4	24.7	26.3	28.4	27.8	21.9	16.9	12.1	7.1
	5%	WB	3.1	3.9	6.7	12.3	17.2	19.2	20.8	20.2	16.1	12.8	8.8	5.1
		MCDB	4.0	5.0	10.1	17.3	23.4	24.6	26.6	25.0	20.1	15.1	9.9	5.8
	10%	WB	1.9	2.6	5.5	11.1	15.9	18.1	19.8	19.0	15.1	11.3	7.5	3.4
		MCDB	2.5	3.6	8.1	15.4	20.9	22.9	25.1	22.9	18.2	13.5	8.5	4.1
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	5.7	7.4	10.3	11.0	10.1	10.5	10.5	9.8	7.8	4.5	4.2
		MCDBR	4.3	6.3	11.5	14.7	14.8	13.8	13.8	13.9	13.4	10.9	7.1	4.8
		MCWBR	3.9	4.7	6.7	7.0	6.3	5.5	5.4	5.8	7.0	6.7	5.3	4.2
	5% WB	MCDWR	4.0	5.6	10.1	12.4	13.0	11.3	12.0	11.7	11.3	9.6	6.5	4.7
		MCWBR	3.8	4.5	6.4	6.4	6.0	5.2	5.3	5.5	6.3	6.3	5.1	4.3
(40) Clear-Sky Solar Irradiance	taub	0.303	0.337	0.371	0.422	0.410	0.399	0.428	0.429	0.394	0.359	0.342	0.304	
	taud	2.179	2.127	2.184	2.173	2.279	2.333	2.259	2.249	2.300	2.378	2.288	2.232	
	Ebn at Noon	669	751	808	810	843	855	820	795	778	734	623	602	
	Edh at Noon	70	100	116	132	125	120	127	122	103	78	65	57	
(44) All-Sky Solar Radiation	RadAvg	0.75	1.54	2.85	4.17	5.31	5.73	5.44	4.73	3.22	1.77	0.69	0.49	
	RadStd	0.12	0.29	0.41	0.45	0.47	0.41	0.46	0.38	0.40	0.31	0.07	0.12	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+1.11	+1.34	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.59	N/A	N/A	N/A	+0.71	+0.78	N/A	-175	+105	N/A

Nomenclature: See separate page