

MAZYR, Belarus

WMO: 330360

Lat: 52.0364N

Lon: 29.1922E

Elev: 622

StdP: 14.37

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	3.6	-8.2	3.6	-1.0	-2.4	4.9	4.9	15.6	26.1	13.9	26.7	3.7	10	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	86.7	67.8	83.3	66.3	80.1	65.2	70.2	81.8	68.6	79.3	67.0	76.9	5.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	99.6	74.8	64.8	94.0	73.3	63.3	89.1	71.9	34.5	82.0	33.2	79.0	31.9	77.3	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	12.0	10.4	-9.4	91.0	8.8	3.2	-15.8	93.3	-20.9	95.2	-25.9	97.0	-32.3	99.4
			-9.8	73.0	8.7	2.1	-16.1	74.5	-21.2	75.7	-26.1	76.9	-32.4	78.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	23.9	26.1	34.7	48.3	57.9	63.5	68.1	65.6	56.1	45.2	35.7	27.2
	DBStd	17.56	10.20	10.26	8.51	8.10	8.17	6.38	5.98	6.26	6.61	7.62	8.61	10.10
	HDD50	3449	808	669	478	125	21	0	0	0	20	189	431	708
	HDD65	7199	1273	1089	940	502	249	105	35	66	274	615	878	1173
	CDD50	2037	0	0	3	75	265	405	560	483	204	39	3	0
	CDD65	312	0	0	0	1	28	60	130	84	9	0	0	0
	CDH74	2582	0	0	0	15	238	491	1092	684	61	1	0	0
	CDH80	700	0	0	0	2	50	108	324	210	6	0	0	0
Wind	WSAvg	4.5	5.1	5.3	5.2	4.8	4.5	4.1	3.6	3.5	3.8	4.2	5.0	5.0
Precipitation	PrecAvg	25.7	1.5	1.5	1.6	1.7	2.5	2.8	3.9	2.3	2.2	2.2	1.9	1.7
	PrecMax	32.8	2.9	3.2	3.5	3.5	4.8	5.4	7.6	5.0	6.2	6.5	4.1	3.3
	PrecMin	19.8	0.5	0.6	0.5	0.2	1.1	0.6	0.8	0.4	0.1	0.1	0.1	0.5
	PrecStd	3.5	0.6	0.6	0.8	0.8	0.9	1.2	1.8	1.2	1.2	1.5	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	48.2	61.4	75.8	85.3	87.5	91.0	92.6	80.2	71.6	56.9	48.1
		MCWB	41.3	42.4	48.7	57.3	64.5	66.7	69.7	70.1	62.1	58.2	51.8	45.9
	2%	DB	40.7	43.3	55.9	69.9	80.2	83.7	87.4	85.3	74.9	64.6	52.9	44.4
		MCWB	38.6	39.6	45.0	54.0	63.4	65.7	68.5	68.3	61.1	56.7	49.9	42.4
	5%	DB	38.2	40.2	50.8	65.7	75.9	80.0	83.7	81.0	70.5	59.6	49.4	41.6
		MCWB	36.4	37.6	42.7	52.1	61.3	64.6	67.0	65.5	59.5	53.7	46.9	40.1
	10%	DB	35.6	37.6	46.5	61.5	72.0	76.3	80.2	77.2	67.1	56.3	46.7	38.5
		MCWB	34.2	35.4	40.4	49.7	58.8	63.5	66.4	64.4	57.7	51.7	44.8	37.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	43.5	49.6	59.7	67.4	69.8	72.9	71.7	65.1	62.1	52.9	46.7
		MCDB	43.9	47.0	59.3	73.7	79.7	80.4	85.6	85.1	75.6	68.3	55.5	47.7
	2%	WB	38.9	40.2	46.3	56.0	64.9	68.0	71.0	69.7	62.4	57.7	50.1	43.0
		MCDB	40.2	42.5	52.8	66.3	76.6	79.5	82.5	81.7	71.7	61.6	52.4	44.0
	5%	WB	36.6	37.9	43.6	53.5	62.7	66.5	69.2	68.0	60.6	54.6	47.3	40.1
		MCDB	38.1	39.8	49.7	62.2	73.6	77.1	80.0	78.1	68.5	58.9	49.1	41.4
	10%	WB	34.3	35.6	41.0	51.4	60.4	64.8	67.5	66.2	58.7	52.0	44.9	37.2
		MCDB	35.4	37.3	45.7	59.7	70.1	73.9	77.3	74.2	65.0	56.1	46.6	38.3
Mean Daily Temperature Range	5% DB	MDBR	7.7	9.4	12.2	16.1	17.8	17.1	17.5	17.5	15.5	13.0	7.4	7.2
		MCDBR	7.1	11.1	18.8	21.9	22.4	22.6	22.3	23.0	20.7	18.4	10.9	7.9
		MCWBR	6.6	8.4	10.9	10.2	9.3	9.3	8.2	9.1	9.8	11.1	8.1	6.8
	5% WB	MCDBR	6.8	10.4	16.7	19.1	20.2	19.2	19.1	19.1	18.4	16.4	9.8	7.6
		MCWBR	6.5	8.4	10.7	9.7	9.3	9.2	8.3	8.4	9.8	10.9	7.8	6.9
Clear-Sky Solar Irradiance	taub	0.300	0.333	0.366	0.420	0.404	0.393	0.420	0.426	0.389	0.356	0.338	0.301	
	taud	2.178	2.121	2.184	2.171	2.292	2.344	2.275	2.253	2.313	2.381	2.289	2.224	
	Ebn at Noon	214	240	258	258	269	273	262	253	249	235	200	193	
	Edh at Noon	23	32	37	42	39	37	40	38	32	25	21	18	
All-Sky Solar Radiation	RadAvg	241	493	914	1328	1698	1825	1746	1513	1036	570	215	154	
	RadStd	39	96	133	146	139	134	141	115	128	96	27	38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+1.17	N/A	N/A	N/A	N/A	+2.48	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+1.21	N/A	N/A	+1.66	+1.30	+1.22	-250	-392	+205	+79

Nomenclature: See separate page