

MAZYR, Belarus

WMO: 330360

Lat: 52.0364N

Lon: 29.1922E

Elev: 190

StdP: 99.07

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.1	-15.8	-22.3	0.5	-18.3	-19.1	0.7	-15.0	7.0	-3.3	6.2	-2.9	1.7	10	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	30.4	19.9	28.5	19.1	26.7	18.4	21.2	27.7	20.3	26.3	19.5	25.0	2.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.2	23.8	18.2	13.4	22.9	17.4	12.7	22.2	62.4	27.8	59.2	26.1	56.2	25.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.4	4.7	-23.0	32.8	4.9	1.8	-26.5	34.1	-29.4	35.1	-32.2	36.1	-35.7	37.4		
(5)			-23.2	22.8	4.8	1.2	-26.7	23.6	-29.5	24.3	-32.3	24.9	-35.8	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-4.5	-3.3	1.5	9.1	14.4	17.5	20.0	18.7	13.4	7.3	2.1	-2.7
	DBStd	9.76	5.66	5.70	4.73	4.50	4.54	3.54	3.32	3.48	3.67	4.23	4.78	5.61
	HDD10.0	1916	449	372	266	69	12	0	0	0	11	105	239	393
	HDD18.3	3999	707	605	522	279	138	58	19	37	152	342	488	652
	CDD10.0	1132	0	0	2	42	147	225	311	268	113	22	2	0
	CDD18.3	173	0	0	0	1	16	33	72	47	5	0	0	0
	CDH23.3	1434	0	0	0	8	132	273	607	380	34	1	0	0
	CDH26.7	389	0	0	0	1	28	60	180	117	3	0	0	0
Wind	WSAvg	2.0	2.3	2.4	2.3	2.1	2.0	1.8	1.6	1.6	1.7	1.9	2.2	2.2
Precipitation	PrecAvg	654	38	39	41	42	64	70	98	58	56	55	48	44
	PrecMax	834	73	81	88	90	121	136	193	126	158	164	103	85
	PrecMin	502	12	16	12	5	28	14	20	9	2	2	3	12
	PrecStd	89	16	16	20	21	24	31	45	31	31	37	24	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	9.0	16.3	24.3	29.6	30.9	32.8	33.7	26.8	22.0	13.8	8.9
		MCWB	5.2	5.8	9.3	14.1	18.0	19.3	21.0	21.2	16.7	14.6	11.0	7.7
	2%	DB	4.8	6.3	13.3	21.1	26.8	28.7	30.8	29.6	23.8	18.1	11.6	6.9
		MCWB	3.6	4.2	7.2	12.2	17.4	18.7	20.3	20.2	16.2	13.7	10.0	5.8
	5%	DB	3.5	4.6	10.5	18.7	24.4	26.7	28.7	27.2	21.4	15.4	9.7	5.3
		MCWB	2.5	3.1	6.0	11.2	16.3	18.1	19.4	18.6	15.3	12.1	8.3	4.5
	10%	DB	2.0	3.1	8.0	16.4	22.2	24.6	26.8	25.1	19.5	13.5	8.2	3.6
		MCWB	1.2	1.9	4.7	9.8	14.9	17.5	19.1	18.0	14.3	10.9	7.1	2.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	6.4	9.8	15.4	19.7	21.0	22.7	22.1	18.4	16.7	11.6	8.2
		MCDB	6.6	8.4	15.1	23.1	26.5	26.9	29.8	29.5	24.2	20.1	13.0	8.7
	2%	WB	3.8	4.6	8.0	13.3	18.3	20.0	21.7	20.9	16.9	14.3	10.1	6.1
		MCDB	4.6	5.8	11.5	19.0	24.8	26.4	28.1	27.6	22.0	16.5	11.3	6.6
	5%	WB	2.5	3.3	6.4	12.0	17.0	19.2	20.7	20.0	15.9	12.5	8.5	4.5
		MCDB	3.4	4.3	9.8	16.8	23.1	25.0	26.7	25.6	20.3	15.0	9.5	5.2
	10%	WB	1.3	2.0	5.0	10.8	15.8	18.2	19.7	19.0	14.8	11.1	7.1	2.9
		MCDB	1.9	3.0	7.6	15.4	21.2	23.3	25.1	23.5	18.4	13.4	8.1	3.5
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.2	6.8	8.9	9.9	9.5	9.7	9.7	8.6	7.2	4.1	4.0
		MCDBR	3.9	6.2	10.4	12.2	12.4	12.5	12.4	12.8	11.5	10.2	6.1	4.4
		MCWBR	3.7	4.7	6.0	5.7	5.2	5.2	4.5	5.0	5.5	6.2	4.5	3.8
	5% WB	MCDBR	3.8	5.8	9.3	10.6	11.2	10.7	10.6	10.6	10.2	9.1	5.4	4.2
		MCWBR	3.6	4.7	5.9	5.4	5.2	5.1	4.6	4.6	5.5	6.1	4.3	3.9
Clear-Sky Solar Irradiance	taub	0.300	0.333	0.366	0.420	0.404	0.393	0.420	0.426	0.389	0.356	0.338	0.301	
	taud	2.178	2.121	2.184	2.171	2.292	2.344	2.275	2.253	2.313	2.381	2.289	2.224	
	Ebn at Noon	676	757	814	813	849	861	827	799	786	740	631	608	
	Edh at Noon	71	100	116	133	123	118	125	121	102	78	65	58	
All-Sky Solar Radiation	RadAvg	0.76	1.55	2.88	4.18	5.35	5.75	5.50	4.77	3.27	1.80	0.68	0.49	
	RadStd	0.12	0.30	0.42	0.46	0.44	0.42	0.45	0.36	0.40	0.30	0.08	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	N/A	N/A	N/A	+1.38	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.67	N/A	N/A	+0.92	+0.72	+0.68	-139	-218	+114	+44

Nomenclature: See separate page