

GOMEL, Belarus

WMO: 330410

Lat: 52.4019N

Lon: 30.9631E

Elev: 126

StdP: 99.82

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.3	-17.1	-23.0	0.5	-20.0	-19.9	0.6	-16.8	10.6	-1.0	9.5	-0.5	2.6	90	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	30.9	20.3	29.1	19.6	27.4	18.8	21.6	28.0	20.7	26.9	19.8	25.6	3.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	14.5	23.9	18.8	13.8	23.1	17.9	13.0	22.2	63.3	28.1	60.2	26.8	57.4	25.8	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	7.8	7.0	-23.9	33.3	3.5	1.9	-26.5	34.7	-28.5	35.9	-30.5	36.9	-33.1	38.3		
(5)			-24.1	23.3	3.5	1.2	-26.6	24.2	-28.7	24.9	-30.6	25.6	-33.1	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-4.9	-3.9	1.0	9.0	14.9	18.2	20.3	19.2	13.6	7.3	1.8	-2.9	(6)
(7)		DBStd	10.12	5.95	6.01	4.66	4.34	4.46	3.65	3.08	3.49	3.95	4.23	4.89	5.72	(7)
(8)		HDD10.0	1973	461	390	279	69	10	0	0	12	105	246	401		(8)
(9)		HDD18.3	4024	719	623	537	281	126	47	15	31	150	342	494	659	(9)
(10)		CDD10.0	1192	0	0	1	39	161	247	319	284	118	22	1	0	(10)
(11)		CDD18.3	202	0	0	0	1	18	43	77	57	7	0	0	0	(11)
(12)		CDH23.3	1853	0	0	0	7	168	384	678	547	68	1	0	0	(12)
(13)		CDH26.7	532	0	0	0	1	33	94	207	188	9	0	0	0	(13)
(14)	Wind	WSAvg	3.5	3.8	3.8	3.9	3.5	3.3	3.3	3.1	3.1	3.2	3.5	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	641	37	36	37	41	64	75	95	56	55	57	48	41	(15)
(16)		PrecMax	882	68	69	85	110	140	131	220	163	122	136	110	87	(16)
(17)		PrecMin	508	12	12	7	3	35	30	32	7	3	5	3	9	(17)
(18)		PrecStd	89	15	13	19	27	24	29	46	32	31	35	25	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	7.9	15.9	24.0	29.8	31.1	33.1	34.9	27.9	21.8	13.2	9.1	(19)
(20)			MCWB	5.5	5.5	8.9	13.8	18.4	20.1	21.2	20.5	17.5	14.7	11.4	8.3	(20)
(21)		2%	DB	4.4	5.3	12.8	21.2	27.2	29.2	30.9	31.0	25.2	18.0	11.1	7.0	(21)
(22)			MCWB	3.6	3.9	7.4	12.6	17.7	19.3	20.6	20.3	16.9	13.7	9.5	6.3	(22)
(23)		5%	DB	3.1	3.9	9.8	18.9	25.1	27.5	29.0	28.6	22.9	15.6	9.3	5.1	(23)
(24)			MCWB	2.3	2.9	5.9	11.7	16.8	18.6	20.0	19.6	15.9	12.3	8.2	4.6	(24)
(25)		10%	DB	1.8	2.5	7.2	16.5	23.0	25.8	27.1	26.2	20.4	13.6	7.9	3.2	(25)
(26)			MCWB	1.3	1.6	4.6	10.4	15.6	17.8	19.4	18.2	14.8	11.1	7.1	2.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	6.1	9.8	15.5	20.4	21.7	23.0	22.5	19.2	16.2	11.9	8.5	(27)
(28)			MCDWB	6.2	7.3	15.1	21.7	27.1	27.9	29.2	29.4	25.2	19.5	13.2	8.9	(28)
(29)		2%	WB	3.6	4.1	7.7	13.6	18.7	20.5	21.8	21.2	17.6	14.2	10.0	6.1	(29)
(30)			MCDWB	4.1	5.1	11.3	19.3	25.3	26.8	28.2	28.1	23.4	17.1	10.8	6.6	(30)
(31)		5%	WB	2.3	2.8	6.2	12.4	17.5	19.6	21.0	20.4	16.5	12.8	8.3	4.5	(31)
(32)			MCDWB	2.8	3.5	8.9	17.4	23.4	25.5	26.8	26.9	21.3	15.2	9.1	5.0	(32)
(33)		10%	WB	1.1	1.7	4.8	11.2	16.4	18.6	20.1	19.3	15.4	11.4	7.0	2.6	(33)
(34)			MCDWB	1.6	2.3	7.0	15.7	21.8	23.9	25.5	24.9	19.3	13.5	7.6	3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.9	7.5	9.7	10.7	10.5	10.4	10.7	9.8	7.6	4.7	4.4	(35)
(36)			MCDBR	3.9	6.1	11.4	13.2	13.1	13.0	13.2	13.9	13.2	10.6	6.1	4.6	(36)
(37)			MCWBR	3.7	5.0	7.0	6.4	5.6	5.3	5.1	5.4	6.1	6.7	4.8	4.1	(37)
(38)		5% WB	MCDBR	3.8	5.4	9.9	11.8	12.4	11.5	11.6	12.2	11.7	9.2	5.3	4.6	(38)
(39)			MCWBR	3.7	4.6	6.7	6.2	5.8	5.5	5.1	5.4	6.0	6.3	4.4	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.336	0.367	0.427	0.405	0.392	0.423	0.429	0.390	0.360	0.340	0.305	(40)	
(41)		taud	2.147	2.085	2.148	2.137	2.281	2.340	2.269	2.236	2.308	2.360	2.261	2.186	(41)	
(42)		Ebn at Noon	661	746	809	803	847	861	824	794	783	729	617	586	(42)	
(43)		Edh at Noon	72	103	119	137	125	119	126	123	102	79	66	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.78	1.62	3.03	4.20	5.50	5.82	5.62	4.80	3.27	1.72	0.65	0.49	(44)	
(45)		RadStd	0.16	0.29	0.43	0.42	0.38	0.48	0.48	0.37	0.36	0.32	0.11	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	N/A	+0.99	+0.58	+0.51	-126	-211	+107	+47
(47) Regional (8 neighbors)		+0.63	N/A	N/A	N/A	+0.60	N/A	-122	-194	+100	+36

Nomenclature: See separate page