

SHEPETIVKA, Ukraine

WMO: 333170

Lat: 50.1614N

Lon: 27.0369E

Elev: 912

StdP: 14.22

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	5.1	-4.8	4.4	-0.1	0.6	5.9	5.9	32.8	32.8	23.5	30.4	4.8	90	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	85.5	69.7	82.6	67.7	79.9	66.3	71.4	82.0	69.6	79.6	67.9	77.0	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.8	105.8	76.7	66.2	99.8	74.3	64.6	94.2	72.2	35.7	81.9	34.2	79.7	32.7	77.2	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
21.7	16.6	13.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-6.8	89.8	6.4	3.0	-11.4	92.0	-15.2	93.7	-18.8	95.4	-23.5	97.6		
			-7.2	73.9	6.3	2.5	-11.8	75.7	-15.5	77.1	-19.1	78.5	-23.7	80.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	25.0	27.3	35.4	48.4	58.2	63.7	67.0	65.7	56.9	46.7	37.1	28.2	(6)
(7)		DBStd	17.03	10.12	10.14	8.58	7.78	7.33	6.20	5.62	6.03	7.06	7.91	8.56	9.36	(7)
(8)		HDD50	3244	776	636	455	118	15	0	0	18	159	392	675		(8)
(9)		HDD65	6953	1241	1056	918	498	231	99	45	65	257	567	836	1140	(9)
(10)		CDD50	2056	0	0	2	71	270	412	526	487	225	57	6	0	(10)
(11)		CDD65	289	0	0	0	1	21	60	106	87	14	0	0	0	(11)
(12)		CDH74	2475	0	0	0	18	222	462	876	765	130	2	0	0	(12)
(13)		CDH80	574	0	0	0	2	32	77	225	214	24	0	0	0	(13)
(14)	Wind	WSAvg	6.1	7.2	7.3	7.5	6.7	5.9	5.1	4.6	4.5	5.2	6.1	7.0	6.8	(14)
(15)	Precipitation	PrecAvg	28.0	1.7	1.3	1.3	2.1	2.7	3.9	4.4	2.9	2.4	1.7	1.8	1.9	(15)
(16)		PrecMax	40.9	5.0	2.7	3.3	4.7	7.6	9.6	9.1	8.2	7.2	4.8	5.5	3.6	(16)
(17)		PrecMin	16.9	0.3	0.1	0.0	0.3	0.9	0.5	0.4	0.5	0.3	0.1	0.4	0.2	(17)
(18)		PrecStd	5.5	1.1	0.7	0.9	1.3	1.4	2.1	2.0	1.6	1.6	1.2	1.1	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.4	50.2	61.4	76.2	83.8	85.4	89.0	90.0	82.9	72.6	60.6	48.6	(19)
(20)			MCWB	42.4	45.3	50.5	59.7	66.1	70.0	71.7	71.2	65.3	60.5	53.2	45.8	(20)
(21)		2%	DB	41.5	45.0	55.5	69.9	79.8	82.2	85.8	85.4	77.7	67.1	55.1	45.0	(21)
(22)			MCWB	39.4	41.6	46.9	56.4	63.7	67.6	70.7	69.4	62.9	57.7	51.0	43.1	(22)
(23)		5%	DB	38.7	41.6	51.0	65.7	76.0	79.4	82.3	81.9	73.2	61.8	51.7	41.9	(23)
(24)			MCWB	37.0	39.2	44.5	54.0	61.9	66.2	68.6	67.2	61.6	54.9	48.9	40.4	(24)
(25)		10%	DB	36.2	38.6	47.0	61.7	72.0	76.3	79.0	78.2	69.0	57.8	48.5	38.7	(25)
(26)			MCWB	34.8	36.5	42.2	51.5	59.9	64.7	67.1	65.7	59.5	52.7	46.4	37.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.7	46.2	51.2	63.2	68.2	72.2	73.8	74.2	67.8	62.1	54.1	46.7	(27)
(28)			MCDWB	45.0	49.8	59.4	72.9	80.9	82.2	86.1	83.5	80.2	70.5	58.7	48.1	(28)
(29)		2%	WB	39.7	42.1	47.7	57.4	65.3	69.8	71.7	70.9	64.8	58.5	51.7	43.1	(29)
(30)			MCDWB	41.2	44.7	54.2	67.6	76.5	79.5	82.3	81.9	73.6	65.0	54.6	44.7	(30)
(31)		5%	WB	37.1	39.3	45.0	54.8	63.4	67.8	69.9	68.9	62.5	56.0	49.0	40.4	(31)
(32)			MCDWB	38.3	41.4	49.9	64.0	73.2	76.4	79.8	78.8	70.4	60.9	51.3	41.8	(32)
(33)		10%	WB	35.0	36.7	42.6	52.6	61.2	65.9	68.1	66.9	60.5	53.2	46.5	37.5	(33)
(34)			MCDWB	36.0	38.3	46.6	59.9	69.6	73.9	77.0	75.8	67.4	57.0	48.6	38.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.6	12.4	17.0	18.7	17.8	18.0	18.7	16.3	13.8	8.8	7.6	(35)
(36)			MCDBR	7.6	11.6	19.0	23.0	23.9	21.7	22.9	23.6	23.0	20.1	14.5	9.6	(36)
(37)			MCWBR	6.5	8.9	11.8	11.8	10.7	10.1	9.9	10.2	11.0	11.3	9.8	8.0	(37)
(38)		5% WB	MCDWB	7.1	11.2	17.5	21.2	21.5	19.5	20.7	21.1	20.0	18.3	13.1	9.1	(38)
(39)	MCWBR		6.4	8.8	11.5	11.5	10.6	10.3	9.7	10.1	10.7	11.3	9.2	7.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.339	0.376	0.429	0.407	0.403	0.434	0.432	0.396	0.360	0.340	0.306	(40)	
(41)		taud	2.221	2.171	2.188	2.129	2.265	2.295	2.221	2.222	2.278	2.360	2.318	2.279	(41)	
(42)		Ebn at Noon	224	246	259	257	270	272	260	254	250	239	212	208	(42)	
(43)		Edh at Noon	23	32	38	45	41	40	42	40	34	26	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	281	545	919	1358	1730	1840	1752	1554	1072	641	272	193	(44)	
(45)		RadStd	51	85	133	141	154	137	136	104	163	101	29	39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.17	N/A	N/A	+1.28	+1.08	N/A	N/A	-331	+187	+72
(47)	Regional (7 neighbors)	+1.28	N/A	N/A	+1.62	+1.01	+0.79	-250	-378	+221	+90

Nomenclature: See separate page