

LVIV, Ukraine

WMO: 333930

Lat: 49.8075N

Lon: 23.9650E

Elev: 323

StdP: 97.50

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-13.7	-20.2	0.6	-15.7	-17.0	0.9	-13.1	10.2	0.2	9.3	-0.8	1.9	140	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	29.9	20.4	28.0	19.4	26.2	18.5	21.3	27.3	20.2	26.0	19.5	24.8	3.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.5	24.2	18.2	13.6	22.8	17.2	12.8	21.8	63.3	27.4	59.6	26.2	56.5	24.9	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.7	6.9	DB	-21.0	32.3	3.6	1.3	-23.6	33.2	-25.7	34.0	-27.7	34.7	-30.4	35.6	(4)
(5)			WB	-21.3	23.0	3.5	1.0	-23.8	23.7	-25.9	24.2	-27.9	24.8	-30.4	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	-3.0	-1.5	2.6	9.2	14.0	17.3	19.2	18.7	13.8	8.6	3.7	-1.4	(6)	
	DBStd	8.96	5.42	5.51	4.72	4.22	3.78	3.33	3.10	3.13	3.59	4.25	4.62	5.07	(7)	
	HDD10.0	1662	404	322	231	63	8	0	0	0	8	78	194	353	(8)	
	HDD18.3	3734	663	555	488	274	141	59	28	34	142	301	439	611	(9)	
	CDD10.0	1107	0	0	2	39	133	218	284	269	121	36	5	0	(10)	
	CDD18.3	139	0	0	0	1	7	28	53	45	6	0	0	0	(11)	
	CDH23.3	1297	0	0	0	10	85	253	476	408	64	1	0	0	(12)	
	CDH26.7	311	0	0	0	1	8	49	127	116	10	0	0	0	(13)	
(14) Wind	WSAvg	3.1	3.5	3.5	3.6	3.2	2.8	2.7	2.5	2.3	2.6	3.1	3.5	3.4	(14)	
(15) Precipitation	PrecAvg	745	44	43	46	50	84	92	101	74	62	51	48	53	(15)	
	PrecMax	942	162	104	140	104	217	181	205	170	146	177	109	106	(16)	
	PrecMin	422	7	2	4	11	20	24	10	1	4	3	1	6	(17)	
	PrecStd	112	25	22	27	22	38	40	46	38	37	36	26	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	12.2	17.2	24.7	27.9	30.2	31.9	32.2	28.0	22.6	17.2	10.9	(19)	
		MCWB	6.3	7.3	9.7	14.9	17.7	20.5	21.3	19.9	17.9	15.5	11.6	7.6	(20)	
	2%	DB	7.0	9.1	14.2	21.6	25.8	28.0	30.0	29.8	25.1	20.1	14.2	8.0	(21)	
		MCWB	5.1	6.1	8.2	12.8	16.6	19.6	20.8	20.1	17.2	14.4	10.3	6.0	(22)	
	5%	DB	5.1	7.0	11.9	19.1	23.9	26.2	28.0	27.7	22.9	17.8	12.1	6.2	(23)	
		MCWB	3.5	4.8	6.9	11.6	16.1	18.6	19.7	19.4	16.3	13.1	9.5	4.7	(24)	
	10%	DB	3.7	5.1	9.3	16.9	21.5	24.3	26.0	25.4	20.7	15.1	10.1	4.8	(25)	
		MCWB	2.3	3.6	5.9	10.6	15.0	17.6	18.9	18.3	15.1	11.9	8.3	3.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.0	10.4	15.4	19.1	21.8	22.9	22.4	19.6	16.4	12.4	7.8	(27)	
		MCDB	8.3	11.1	15.9	23.2	25.5	27.7	29.4	28.9	26.0	20.8	15.7	9.9	(28)	
	2%	WB	5.1	6.3	8.8	13.6	17.7	20.4	21.6	20.9	18.0	15.0	11.0	6.1	(29)	
		MCDB	6.6	8.7	13.1	19.9	23.6	26.3	27.7	26.8	23.1	19.2	13.8	7.6	(30)	
	5%	WB	3.6	4.8	7.5	12.3	16.7	19.4	20.6	19.9	16.8	13.6	9.7	4.8	(31)	
		MCDB	4.9	6.4	10.7	17.6	22.2	24.8	26.4	25.7	21.4	17.0	11.8	5.9	(32)	
	10%	WB	2.3	3.6	6.3	11.1	15.5	18.4	19.6	19.0	15.7	12.1	8.4	3.5	(33)	
		MCDB	3.4	5.1	8.9	15.9	20.6	23.3	24.7	24.3	19.5	14.8	10.1	4.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.5	8.0	10.1	10.6	10.5	10.4	10.9	9.7	8.7	6.1	5.4	(35)	
		MCDBR	6.2	8.6	12.5	14.2	13.9	13.5	13.6	14.3	13.8	12.8	9.9	7.5	(36)	
	5% WB	MCWBR	4.9	6.1	7.4	7.0	6.8	6.5	5.9	6.3	7.0	7.6	6.4	5.7	(37)	
		MCWBR	5.8	7.9	10.6	12.5	12.6	12.0	11.9	12.5	12.2	11.7	8.7	6.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.308	0.336	0.379	0.429	0.415	0.415	0.441	0.439	0.399	0.364	0.341	0.306	(40)	
		taud	2.259	2.221	2.210	2.134	2.237	2.259	2.199	2.204	2.273	2.350	2.343	2.319	(41)	
	Edn at Noon		717	788	817	812	844	845	815	795	788	751	676	669	(42)	
		Edh at Noon	72	97	117	140	132	130	137	130	109	85	68	60	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.89	1.66	2.79	4.13	5.13	5.50	5.31	4.82	3.33	2.05	0.97	0.65	(44)	
	RadStd		0.14	0.25	0.36	0.44	0.57	0.41	0.47	0.40	0.50	0.31	0.11	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.64	N/A	N/A	+1.00	+0.45	N/A	-138	-209	+101	+40	(46)
(47)	Regional (15 neighbors)	+0.60	N/A	N/A	+1.01	+0.53	+0.49	N/A	-196	+105	+44	(47)

Nomenclature: See separate page