

MYRONIVKA, Ukraine

WMO: 334660

Lat: 49.6461N

Lon: 31.0828E

Elev: 502

StdP: 14.43

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.4	(c) 4.8	(d) -7.1	(e) 3.8	(f) -0.6	(g) -1.2	(h) 5.2	(i) 5.7	(j) 17.5	(k) 35.3	(l) 16.0	(m) 32.9	(n) 3.5	(o) 270	(p) 0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.9	(c) 88.9	(d) 68.6	(e) 85.6	(f) 67.6	(g) 82.7	(h) 66.5	(i) 71.2	(j) 83.1	(k) 69.8	(l) 81.3	(m) 68.4	(n) 79.4	(o) 6.4	(p) 30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.5	102.8	76.4	66.0	97.5	74.7	64.6	92.7	73.2	35.3	83.7	34.1	81.5	33.0	79.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.5	(b) 13.7	(c) 12.0	(e) -6.6	(f) 93.1	(g) 8.1	(h) 4.0	(i) -12.5	(j) 96.0	(k) -17.2	(l) 98.3	(m) -21.8	(n) 100.6	(o) -27.7	(p) 103.5		
(a) 15.5	(b) 13.7	(c) 12.0	(e) -7.1	(f) 74.4	(g) 7.9	(h) 2.0	(i) -12.8	(j) 75.8	(k) -17.5	(l) 77.0	(m) -21.9	(n) 78.2	(o) -27.7	(p) 79.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	24.9	27.3	36.3	50.0	60.2	66.3	69.8	68.4	58.8	47.5	37.6	28.7		
	DBStd	17.94	10.38	10.55	8.13	7.41	7.51	6.17	5.34	6.12	7.14	7.90	8.78	9.89		
	HDD50	3139	778	637	429	90	10	0	0	0	11	142	381	661		
	HDD65	6641	1243	1057	891	453	185	60	17	33	210	543	823	1126		
	CDD50	2438	0	0	3	89	328	488	614	569	274	65	8	0		
	CDD65	464	0	0	0	2	37	98	166	137	23	1	0	0		
	CDH74	4341	0	0	0	23	351	829	1487	1400	245	6	0	0		
	CDH80	1300	0	0	0	4	65	198	472	509	52	0	0	0		
(14) Wind	WSAvg	5.6	6.5	6.6	7.0	6.2	5.3	4.7	4.4	4.4	4.7	5.3	6.2	6.4		
(15) Precipitation	PrecAvg	23.5	1.5	1.3	1.4	1.7	2.4	3.2	2.9	2.2	2.2	1.6	1.6	1.5		
	PrecMax	28.9	3.2	3.4	4.3	4.3	6.8	7.7	6.4	5.4	6.1	4.3	3.2	4.4		
	PrecMin	17.7	0.5	0.3	0.2	0.1	0.6	0.6	0.7	0.0	0.0	0.0	0.2	0.4		
	PrecStd	2.8	0.7	0.7	0.9	0.9	1.3	1.7	1.5	1.5	1.8	1.1	0.7	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	49.4	61.9	76.9	86.1	88.2	92.3	95.4	85.6	73.6	61.3	50.2		
		MCWB	41.2	44.4	49.3	58.0	65.9	68.7	70.2	68.9	63.8	59.1	54.1	47.4		
	2%	DB	41.9	44.7	56.1	71.1	81.3	85.0	88.3	90.1	80.5	68.5	56.2	46.1		
		MCWB	39.3	41.1	46.1	54.9	63.4	67.5	69.4	67.9	62.0	57.9	51.7	44.0		
	5%	DB	38.9	41.4	51.4	67.3	78.1	82.2	85.3	85.4	76.2	63.5	52.1	43.1		
		MCWB	36.9	38.8	44.3	53.6	62.1	66.8	68.9	67.0	60.8	55.3	49.4	41.5		
	10%	DB	36.6	38.9	47.7	63.3	74.2	79.1	82.0	81.7	71.8	59.0	49.1	40.2		
		MCWB	35.0	36.6	42.0	51.4	60.5	65.7	67.7	65.5	59.5	53.1	46.7	38.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	45.0	50.4	60.4	68.8	72.2	73.6	72.5	66.5	62.5	55.8	48.0		
		MCDB	43.7	48.3	59.2	74.2	81.2	82.4	85.4	86.2	79.4	70.2	59.2	49.8		
	2%	WB	39.6	41.4	47.5	56.8	66.0	70.1	71.6	70.2	64.2	58.9	52.0	44.4		
		MCDB	41.4	43.8	54.5	67.1	77.1	80.5	83.7	83.2	76.2	65.9	55.2	45.9		
	5%	WB	37.1	39.1	44.9	54.6	63.9	68.6	70.3	68.7	62.2	56.4	49.5	41.5		
		MCDB	38.7	41.4	50.4	64.1	74.2	78.9	81.8	81.2	72.5	62.3	51.9	43.0		
	10%	WB	35.1	36.8	42.5	52.7	62.0	67.0	68.9	67.2	60.5	53.9	47.0	38.8		
		MCDB	36.4	38.6	47.5	61.3	71.4	76.5	79.5	78.8	69.3	58.3	48.9	40.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.2	11.8	16.9	18.9	18.1	18.9	20.3	17.2	13.8	8.3	7.5		
		MCDBR	7.6	10.4	18.5	23.0	23.3	22.5	23.8	26.3	24.7	20.6	12.1	8.5		
		MCWBR	6.7	8.2	11.5	11.0	9.9	9.4	9.0	9.0	10.5	11.3	8.8	7.3		
		MCDBR	7.0	9.8	16.7	19.8	20.5	19.8	21.0	21.7	20.9	17.6	10.8	8.4		
	5% WB	MCWBR	6.4	8.2	11.1	10.3	9.8	9.3	9.1	8.7	10.5	10.7	8.6	7.4		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.344	0.376	0.439	0.409	0.403	0.431	0.433	0.399	0.363	0.344	0.314		
	taud		2.214	2.167	2.207	2.108	2.273	2.310	2.241	2.223	2.285	2.364	2.317	2.267		
	Ebn at Noon		224	246	260	255	270	272	261	254	251	239	213	207		
	Edh at Noon		24	32	37	46	41	39	42	40	34	27	22	20		
(44) All-Sky Solar Radiation	RadAvg		292	545	949	1391	1819	1929	1870	1659	1121	661	269	202		
	RadStd		55	92	148	140	142	139	119	98	170	100	40	52		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.40	N/A	N/A	+1.87	N/A	N/A	-277	-387	+234
(47) Regional (11 neighbors)		+1.33	N/A	N/A	+1.78	N/A	N/A	-261	-369	+223

Nomenclature: See separate page