

MYRONIVKA, Ukraine

WMO: 334660

Lat: 49.6461N

Lon: 31.0828E

Elev: 153

StdP: 99.50

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.6	-15.1	-21.7	0.5	-18.1	-18.5	0.7	-14.6	7.8	1.8	7.1	0.5	1.6	270	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	31.6	20.3	29.8	19.8	28.2	19.2	21.8	28.4	21.0	27.4	20.2	26.3	2.9	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.7	14.7	24.7	18.9	13.9	23.7	18.1	13.2	22.9	64.2	28.7	61.4	27.5	58.8	26.4	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	6.1	5.4	-21.5	34.0	4.5	2.2	-24.7	35.5	-27.3	36.8	-29.9	38.1	-33.2	39.7		
(5)			-21.7	23.5	4.4	1.1	-24.9	24.4	-27.5	25.0	-30.0	25.6	-33.1	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-3.9	-2.6	2.4	10.0	15.7	19.0	21.0	20.2	14.9	8.6	3.1	-1.8		
	DBStd	9.96	5.77	5.86	4.52	4.12	4.17	3.43	2.96	3.40	3.97	4.39	4.88	5.49		
	HDD10.0	1744	432	354	238	50	6	0	0	0	6	79	212	367		
	HDD18.3	3689	691	587	495	252	103	33	9	18	117	302	457	626		
	CDD10.0	1354	0	0	2	49	182	271	341	316	152	36	4	0		
	CDD18.3	258	0	0	0	1	21	54	92	76	13	1	0	0		
	CDH23.3	2412	0	0	0	13	195	461	826	778	136	3	0	0		
	CDH26.7	722	0	0	0	2	36	110	262	283	29	0	0	0		
(14) Wind	WSAvg	2.5	2.9	2.9	3.1	2.8	2.4	2.1	2.0	2.0	2.1	2.4	2.8	2.9		
(15) Precipitation	PrecAvg	597	37	34	36	42	61	81	73	56	56	40	41	39		
	PrecMax	734	81	86	108	109	172	196	163	138	156	108	81	113		
	PrecMin	450	12	8	4	2	14	15	19	0	0	0	4	10		
	PrecStd	72	19	17	24	24	33	44	39	37	46	28	18	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	9.7	16.6	25.0	30.0	31.2	33.5	35.2	29.8	23.1	16.3	10.1		
		MCWB	5.1	6.9	9.6	14.5	18.8	20.4	21.2	20.5	17.6	15.1	12.3	8.6		
	2%	DB	5.5	7.1	13.4	21.7	27.4	29.5	31.3	32.3	26.9	20.3	13.4	7.8		
		MCWB	4.1	5.0	7.8	12.7	17.4	19.7	20.8	20.0	16.7	14.4	10.9	6.6		
	5%	DB	3.9	5.2	10.8	19.6	25.6	27.9	29.6	29.7	24.6	17.5	11.2	6.2		
		MCWB	2.7	3.8	6.8	12.0	16.7	19.4	20.5	19.4	16.0	12.9	9.6	5.3		
	10%	DB	2.6	3.9	8.7	17.4	23.5	26.1	27.8	27.6	22.1	15.0	9.5	4.5		
		MCWB	1.6	2.6	5.6	10.8	15.8	18.7	19.8	18.6	15.3	11.7	8.2	3.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	7.2	10.2	15.8	20.5	22.3	23.1	22.5	19.2	16.9	13.2	8.9		
		MCDB	6.5	9.1	15.1	23.4	27.3	28.0	29.6	30.1	26.3	21.2	15.1	9.9		
	2%	WB	4.2	5.2	8.6	13.8	18.9	21.2	22.0	21.2	17.9	14.9	11.1	6.9		
		MCDB	5.2	6.6	12.5	19.5	25.1	26.9	28.7	28.4	24.6	18.8	12.9	7.7		
	5%	WB	2.9	3.9	7.1	12.6	17.7	20.4	21.3	20.4	16.8	13.5	9.7	5.3		
		MCDB	3.7	5.2	10.2	17.8	23.4	26.0	27.7	27.4	22.5	16.8	11.1	6.1		
	10%	WB	1.7	2.7	5.9	11.5	16.6	19.4	20.5	19.5	15.8	12.2	8.3	3.8		
		MCDB	2.5	3.7	8.6	16.3	21.9	24.7	26.4	26.0	20.7	14.6	9.4	4.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.1	6.5	9.4	10.5	10.0	10.5	11.3	9.6	7.7	4.6	4.2		
		MCDBR	4.2	5.8	10.3	12.8	12.9	12.5	13.2	14.6	13.7	11.5	6.7	4.7		
		MCWBR	3.7	4.5	6.4	6.1	5.5	5.2	5.0	5.0	5.8	6.3	4.9	4.1		
		MCDBR	3.9	5.4	9.3	11.0	11.4	11.0	11.6	12.0	11.6	9.8	6.0	4.7		
	5% WB	MCWBR	3.5	4.6	6.2	5.7	5.4	5.2	5.1	4.8	5.8	5.9	4.8	4.1		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.344	0.376	0.439	0.409	0.403	0.431	0.433	0.399	0.363	0.344	0.314		
	taud		2.214	2.167	2.207	2.108	2.273	2.310	2.241	2.223	2.285	2.364	2.317	2.267		
	Ebn at Noon		707	775	821	803	850	857	824	801	790	755	672	653		
	Edh at Noon		76	102	117	144	128	124	131	127	108	84	70	64		
(44) All-Sky Solar Radiation	RadAvg		0.92	1.72	2.99	4.39	5.74	6.08	5.89	5.23	3.53	2.08	0.85	0.64		
	RadStd		0.17	0.29	0.47	0.44	0.45	0.44	0.38	0.31	0.54	0.31	0.12	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.78	N/A	N/A	+1.04	N/A	N/A	-154	-215	+130	+65
(47) Regional (11 neighbors)		+0.74	N/A	N/A	+0.99	N/A	N/A	-145	-205	+124	+64

Nomenclature: See separate page