

SVITLOVODS'K, Ukraine

WMO: 336140

Lat: 49.0711N

Lon: 33.2494E

Elev: 276

StdP: 14.55

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.7	5.8	-6.2	4.0	1.9	-1.2	5.2	7.1	22.1	29.6	19.5	27.3	4.8	270	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	89.7	69.3	86.4	69.1	83.4	68.2	73.7	83.3	72.0	81.8	70.3	80.1	6.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.5	113.3	80.4	68.5	105.8	78.0	66.9	99.8	76.1	37.4	83.1	35.9	81.7	34.4	80.1	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.4	13.5	DB	-4.8	94.5	6.8	3.8	-9.7	97.2	-13.7	99.5	-17.5	101.6	-22.4	104.3	(4)
			WB	-5.5	77.3	6.6	2.8	-10.2	79.3	-14.1	81.0	-17.8	82.6	-22.6	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	25.2	27.7	36.3	50.2	61.9	69.1	72.5	70.8	60.6	48.9	38.9	30.2
	DBStd	18.45	10.27	10.04	7.91	7.14	7.03	5.75	5.03	5.71	6.50	7.51	8.18	9.33
	HDD50	2981	770	625	427	84	3	0	0	0	4	111	342	615
	HDD65	6327	1235	1045	890	447	147	25	3	11	160	500	784	1080
	CDD50	2788	0	0	2	88	372	574	698	646	322	77	9	0
	CDD65	657	0	0	0	1	50	149	236	192	28	1	0	0
	CDH74	5045	0	0	0	15	398	1059	1783	1571	214	5	0	0
	CDH80	1528	0	0	0	1	83	289	571	538	46	0	0	0
Wind	WSAvg	6.1	6.9	7.1	7.1	6.1	5.4	5.4	4.9	5.1	5.4	5.8	7.1	7.1
Precipitation	PrecAvg	22.5	1.6	1.3	1.4	1.4	2.0	2.9	3.0	2.2	2.2	1.7	1.6	1.5
	PrecMax	32.7	4.1	4.1	3.4	3.3	4.2	11.0	7.3	4.8	5.7	5.2	3.9	3.2
	PrecMin	16.8	0.5	0.3	0.0	0.0	0.4	0.2	0.3	0.2	0.0	0.0	0.1	0.3
	PrecStd	4.3	0.9	0.9	0.9	0.9	1.1	2.3	2.0	1.3	1.7	1.5	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.6	49.4	61.8	76.2	86.9	90.3	93.3	95.2	85.4	72.9	62.1	52.2
		MCWB	42.9	44.0	49.3	57.8	64.7	67.5	70.0	68.3	64.1	60.3	55.6	49.3
	2%	DB	41.9	44.7	55.6	69.6	82.0	86.5	89.5	89.9	79.8	67.3	56.1	47.9
		MCWB	39.6	41.9	46.0	54.8	62.9	68.4	69.5	70.7	63.1	59.1	52.2	45.7
	5%	DB	39.1	41.3	50.8	65.6	78.6	83.3	86.1	85.7	75.5	63.0	52.8	43.9
		MCWB	37.2	38.7	43.3	53.4	63.0	68.1	70.0	69.5	62.4	56.9	50.2	42.0
	10%	DB	37.0	38.7	46.8	62.0	74.7	80.1	82.9	82.0	71.7	59.5	49.7	41.2
		MCWB	35.4	36.4	41.6	51.4	62.2	67.2	69.5	68.3	61.0	54.8	47.4	39.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	45.4	50.4	60.4	69.5	74.4	76.2	76.9	69.2	63.4	56.4	49.8
		MCDB	45.2	48.2	59.5	70.4	80.1	82.9	85.8	86.5	78.1	68.5	61.1	52.0
	2%	WB	39.9	42.0	46.8	56.7	67.0	72.0	73.8	73.6	66.5	60.0	53.0	45.6
		MCDB	41.7	44.5	53.8	65.9	76.7	81.1	83.4	83.7	74.9	65.2	55.7	47.6
	5%	WB	37.5	39.0	44.2	54.6	65.0	70.1	72.1	71.6	64.1	57.7	50.3	42.3
		MCDB	38.8	40.9	49.4	62.7	74.3	79.4	82.0	81.6	72.4	62.1	52.4	43.7
	10%	WB	35.6	36.7	41.9	52.8	63.0	68.3	70.6	69.6	62.0	55.3	47.6	39.8
		MCDB	36.8	38.4	46.3	60.1	72.0	77.8	80.2	80.3	69.3	59.2	49.4	41.1
Mean Daily Temperature Range	5% DB	MDBR	8.3	9.1	10.9	14.7	16.0	14.8	15.3	16.8	14.8	11.9	8.0	7.5
		MCDBR	7.5	10.6	18.4	20.9	22.3	20.5	21.1	22.9	22.0	17.9	12.1	9.5
		MCWBR	6.5	8.4	11.0	10.0	9.2	9.0	8.4	9.6	10.6	10.7	9.1	8.3
	5% WB	MCDBR	7.2	10.1	16.0	17.3	18.3	16.8	17.0	18.8	18.2	15.0	11.1	9.0
		MCWBR	6.6	8.5	10.6	9.3	9.6	9.6	8.9	10.3	11.1	10.1	8.9	8.1
Clear-Sky Solar Irradiance	taub	0.323	0.356	0.387	0.450	0.417	0.410	0.441	0.436	0.409	0.371	0.353	0.326	
	taud	2.194	2.152	2.195	2.086	2.271	2.314	2.234	2.233	2.269	2.352	2.300	2.263	
	Ebn at Noon	222	243	258	252	268	270	259	254	248	239	212	205	
	Edh at Noon	25	33	38	47	41	39	42	40	35	27	23	21	
All-Sky Solar Radiation	RadAvg	301	561	945	1431	1848	1980	1939	1734	1177	697	288	206	
	RadStd	56	95	149	128	154	165	109	108	166	100	48	45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.48	N/A	N/A	N/A	N/A	N/A	-311	-409	+259	+185
Regional (9 neighbors)		+1.37	N/A	N/A	+1.94	N/A	N/A	-261	-362	+221	+144

Nomenclature: See separate page