

UZHHOROD, Ukraine

WMO: 336310

Lat: 48.6333N

Lon: 22.2611E

Elev: 407

StdP: 14.48

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.3	14.0	1.1	5.9	13.8	6.0	7.6	17.6	18.4	29.9	16.4	28.4	1.7	310	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	89.6	70.5	86.4	69.3	83.9	67.7	72.5	85.4	70.7	83.1	69.2	80.9	5.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.1	104.9	79.1	66.4	98.6	76.5	64.7	93.1	74.7	36.3	85.7	34.8	83.0	33.5	81.0	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.3	13.2	1.1	93.3	6.6	2.8	-3.6	95.3	-7.4	97.0	-11.1	98.6	-15.9	100.7		
(5)			0.6	75.1	6.5	2.0	-4.0	76.5	-7.8	77.7	-11.5	78.9	-16.2	80.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	29.7	33.3	41.8	53.0	61.1	67.0	70.2	69.9	60.8	51.1	42.1	32.5	(6)
(7)		DBStd	16.02	8.65	8.45	7.62	7.24	6.48	5.98	5.79	5.55	6.55	7.33	7.90	8.19	(7)
(8)		HDD50	2299	629	468	268	51	3	0	0	2	77	259	542	(8)	
(9)		HDD65	5589	1094	887	719	362	156	48	18	160	433	688	1006	(9)	
(10)		CDD50	2710	0	0	14	141	346	510	627	615	325	110	21	1	(10)
(11)		CDD65	526	0	0	0	2	34	107	181	168	33	1	0	0	(11)
(12)		CDH74	5033	0	0	0	39	359	981	1740	1606	302	6	0	0	(12)
(13)		CDH80	1588	0	0	0	4	63	270	618	567	66	0	0	0	(13)
(14)	Wind	WSAvg	5.2	4.8	5.4	6.4	6.4	5.7	5.4	5.0	4.6	4.5	4.4	4.6	4.8	(14)
(15)	Precipitation	PrecAvg	28.7	2.1	1.9	1.8	1.9	2.6	3.2	3.3	2.7	2.4	2.1	2.5	2.6	(15)
(16)		PrecMax	44.3	5.2	4.6	4.7	4.4	5.7	9.0	7.8	6.3	5.8	11.6	7.3	5.2	(16)
(17)		PrecMin	17.2	0.3	0.1	0.0	0.5	0.7	0.3	0.7	0.2	0.1	0.0	0.7	0.2	(17)
(18)		PrecStd	5.7	1.0	0.9	1.1	0.9	1.4	1.8	1.5	1.3	1.4	2.0	1.3	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.9	55.6	66.2	78.7	85.1	89.7	93.6	94.2	86.4	74.8	64.9	53.5	(19)
(20)			MCWB	46.2	47.1	51.5	59.7	66.3	71.6	71.2	70.1	67.9	60.7	54.4	47.1	(20)
(21)		2%	DB	46.7	50.6	61.6	73.6	81.6	86.2	89.6	89.7	80.9	70.5	60.6	49.7	(21)
(22)			MCWB	43.6	44.2	49.2	56.8	64.7	69.7	70.8	70.1	64.6	59.3	52.6	45.7	(22)
(23)		5%	DB	43.8	47.8	57.5	69.8	78.2	82.8	86.3	86.1	77.2	66.5	57.1	46.1	(23)
(24)			MCWB	41.1	42.8	47.1	55.3	63.0	67.5	69.2	69.4	63.1	57.7	50.9	43.5	(24)
(25)		10%	DB	41.0	44.7	53.8	66.2	74.6	80.1	83.3	82.5	73.5	62.9	54.0	43.0	(25)
(26)			MCWB	38.9	41.1	45.6	52.9	61.4	66.4	67.9	67.3	61.5	56.0	49.2	40.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	48.0	53.3	61.6	68.6	73.8	74.5	74.8	68.6	63.2	56.4	48.5	(27)
(28)			MCD B	48.8	53.1	61.9	75.5	81.7	86.5	88.0	86.9	82.5	70.5	61.6	51.3	(28)
(29)		2%	WB	44.2	45.4	50.6	58.7	65.9	71.2	72.4	72.3	66.3	60.7	53.9	45.7	(29)
(30)			MCD B	45.9	49.2	58.4	70.8	78.1	83.1	86.0	84.4	77.8	67.5	59.1	48.6	(30)
(31)		5%	WB	41.2	43.4	48.5	56.4	64.2	69.3	70.7	70.2	64.5	58.8	51.7	43.5	(31)
(32)			MCD B	42.6	46.7	55.8	67.2	75.9	80.5	83.4	82.7	74.3	65.6	56.3	45.8	(32)
(33)		10%	WB	38.9	41.2	46.4	54.4	62.4	67.4	69.2	68.6	62.7	56.7	49.6	40.9	(33)
(34)			MCD B	40.7	44.4	52.9	63.8	72.5	77.6	80.6	80.6	71.5	62.5	53.4	42.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	11.7	15.6	19.1	19.7	19.7	20.1	21.4	18.9	16.6	12.0	8.5	(35)
(36)			MCDBR	10.1	15.5	22.1	25.5	25.6	24.6	25.3	26.3	25.2	22.4	16.9	10.8	(36)
(37)			MCWBR	7.9	10.4	12.4	12.1	11.8	11.0	9.9	10.3	11.4	12.4	10.7	8.3	(37)
(38)		5% WB	MCD BR	8.4	13.4	18.9	22.8	23.1	21.9	22.8	23.8	21.7	19.1	13.5	9.7	(38)
(39)			MCWBR	7.1	9.7	11.5	11.5	11.4	10.5	9.8	10.4	10.5	11.3	9.2	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.348	0.390	0.442	0.430	0.432	0.452	0.448	0.410	0.381	0.358	0.323	(40)	
(41)		taud	2.259	2.224	2.203	2.112	2.205	2.234	2.191	2.199	2.269	2.319	2.318	2.310	(41)	
(42)		Ebn at Noon	227	249	258	255	264	264	256	251	249	235	213	212	(42)	
(43)		Edh at Noon	24	31	38	46	43	43	44	42	35	29	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	289	539	907	1344	1636	1765	1714	1589	1105	678	354	215	(44)	
(45)		RadStd	51	85	132	145	187	126	168	145	157	104	52	31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.06	N/A	N/A	+1.62	+1.24	+1.21	-234	-349	+158	+74
(47) Regional (37 neighbors)		+1.12	N/A	N/A	+1.75	+0.92	+0.85	-229	-346	+173	+70

Nomenclature: See separate page