

MOHYLIV-PODIL'S'KYI, Ukraine

WMO: 336630

Lat: 48.4523N

Lon: 27.7797E

Elev: 78

StdP: 100.39

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-12.9	-19.4	0.7	-16.5	-16.1	0.9	-12.2	5.6	1.0	4.5	0.4	0.6	290	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	32.9	21.1	31.1	20.4	29.6	19.9	22.6	30.0	21.7	28.8	20.9	27.4	1.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.1	25.8	19.4	14.3	24.5	18.6	13.6	23.7	67.1	29.8	63.5	28.9	60.6	27.5	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.2	3.5	-20.0	35.5	4.0	2.0	-22.8	37.0	-25.2	38.2	-27.4	39.4	-30.3	40.9		
(5)			-20.2	24.3	4.0	1.3	-23.1	25.2	-25.4	26.0	-27.6	26.7	-30.5	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	-2.3	-0.7	4.1	10.7	16.2	19.6	21.6	20.8	15.8	9.8	4.7	-0.7		
	DBStd	9.45	5.22	5.41	4.50	3.96	3.71	3.20	2.92	3.12	3.66	4.18	4.51	5.25		
	HDD10.0	1466	382	299	188	38	0	0	0	2	55	167	333			
	HDD18.3	3330	640	533	441	229	87	24	6	93	266	408	591			
	CDD10.0	1472	0	0	4	59	193	288	359	336	175	49	8	0		
	CDD18.3	296	0	0	0	1	20	62	107	89	16	1	0	0		
	CDH23.3	3342	0	0	0	29	298	701	1136	969	196	12	0	0		
	CDH26.7	1197	0	0	0	6	78	226	451	388	48	2	0	0		
(14) Wind	WSAvg	1.3	1.4	1.5	1.6	1.5	1.4	1.3	1.1	1.0	1.1	1.2	1.4	1.4		
(15) Precipitation	PrecAvg	612	35	33	29	45	73	90	93	55	44	30	41	40		
	PrecMax	912	158	97	69	102	205	214	226	109	141	102	149	77		
	PrecMin	371	3	6	0	11	21	16	19	9	0	6	4	6		
	PrecStd	131	29	25	19	23	42	51	52	26	40	24	31	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	12.9	19.5	26.5	31.1	33.0	35.9	35.5	30.6	24.9	18.5	12.0		
		MCWB	6.5	7.7	11.2	15.6	18.7	21.1	21.8	22.3	19.4	17.1	13.4	9.1		
	2%	DB	6.8	9.8	16.2	23.3	28.9	30.9	33.1	32.9	27.9	21.2	15.0	9.5		
		MCWB	4.9	6.5	9.6	13.9	18.2	20.4	21.2	21.1	17.9	15.2	11.8	7.6		
	5%	DB	5.4	7.7	13.6	21.1	26.6	29.3	31.1	30.8	25.6	18.6	13.1	7.2		
		MCWB	3.8	5.4	8.1	13.0	17.3	19.8	20.8	20.4	17.2	13.8	10.8	5.8		
	10%	DB	4.0	5.8	11.3	18.9	24.5	27.7	29.2	28.7	23.2	16.2	11.3	5.4		
		MCWB	2.7	3.7	6.9	11.7	16.4	19.2	20.4	19.9	16.2	12.7	9.4	4.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	8.5	11.7	16.4	20.5	23.2	23.9	24.1	20.6	18.1	14.0	9.9		
		MCDB	9.0	11.9	18.0	24.9	28.3	29.8	30.8	32.0	28.6	23.9	17.1	11.5		
	2%	WB	5.3	6.9	10.1	14.9	19.2	21.7	22.7	22.5	19.0	15.9	12.3	7.6		
		MCDB	6.5	9.2	15.2	21.7	26.4	28.4	30.1	30.2	25.7	20.2	14.5	9.2		
	5%	WB	4.0	5.5	8.7	13.5	18.1	20.8	21.8	21.4	17.8	14.4	11.0	6.0		
		MCDB	5.2	7.6	12.6	19.6	24.7	27.3	28.9	28.5	23.6	17.9	13.0	7.3		
	10%	WB	2.8	3.9	7.4	12.4	16.9	19.9	21.0	20.4	16.8	13.0	9.4	4.2		
		MCDB	3.9	5.6	10.8	17.6	23.2	25.9	27.5	26.7	22.1	15.7	11.2	5.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.8	9.2	11.7	13.1	12.4	12.5	13.1	11.6	9.7	6.1	5.4		
		MCDBR	6.7	9.9	13.9	16.1	16.7	15.6	16.3	16.9	16.0	13.7	9.4	7.1		
	5% WB	MCWBR	5.0	6.9	8.1	7.8	7.5	6.5	6.1	6.4	7.2	7.8	6.1	5.5		
		MCWBR	6.3	9.1	12.5	14.2	14.6	13.3	13.5	14.6	13.6	12.4	8.3	6.8		
(40) Clear-Sky Solar Irradiance	taub		0.324	0.356	0.395	0.455	0.422	0.420	0.452	0.456	0.412	0.378	0.355	0.322		
		taud	2.223	2.170	2.174	2.063	2.234	2.266	2.188	2.171	2.249	2.319	2.304	2.288		
	Ebn at Noon		713	773	807	792	841	844	808	784	782	746	675	668		
		Edh at Noon	79	105	123	152	134	130	139	136	114	90	74	66		
(44) All-Sky Solar Radiation	RadAvg		1.02	1.81	3.04	4.45	5.67	6.01	5.86	5.22	3.63	2.26	1.00	0.75		
	RadStd		0.16	0.30	0.34	0.44	0.47	0.46	0.37	0.35	0.51	0.30	0.10	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.66	N/A	N/A	N/A	N/A	N/A	-129	-190	+112	+55
(47) Regional (20 neighbors)		+0.67	N/A	N/A	+0.79	N/A	N/A	N/A	-196	+119	+53

Nomenclature: See separate page