

CHISINAU, Moldova, Republic of

WMO: 338150

Lat: 47.017N

Lon: 28.983E

Elev: 568

StdP: 14.40

Time Zone: 2.00 (MDA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	11.2	-0.7	5.4	8.0	4.5	7.1	13.7	20.1	25.6	17.8	28.9	5.5	340	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	91.0	67.5	87.7	66.6	85.1	65.7	70.8	83.8	69.2	81.9	67.9	80.1	5.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	100.1	75.9	65.1	94.9	74.6	63.6	90.0	73.5	35.0	83.9	33.7	82.0	32.6	79.8	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	14.5	12.5	DB	2.2	94.8	6.7	3.4	-2.6	97.2	-6.5	99.2	-10.3	101.2	-15.1	103.6	(4)
(5)			WB	1.4	72.9	6.7	1.7	-3.4	74.2	-7.3	75.2	-11.0	76.1	-15.8	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	28.4	31.4	40.5	52.5	62.7	69.6	73.4	72.9	62.9	51.6	41.6	31.7	(6)
(7)		DBStd	17.77	9.40	9.66	8.48	7.11	6.74	5.78	5.43	6.14	7.13	8.10	8.79	9.12	(7)
(8)		HDD50	2478	669	520	308	53	2	0	0	0	2	79	276	569	(8)
(9)		HDD65	5649	1134	940	759	380	125	23	4	8	121	421	701	1033	(9)
(10)		CDD50	3098	0	0	14	127	395	587	724	708	389	128	25	1	(10)
(11)		CDD65	795	0	0	0	4	53	160	263	251	59	5	0	0	(11)
(12)		CDH74	6502	0	0	0	35	406	1211	2216	2206	407	21	0	0	(12)
(13)		CDH80	2152	0	0	0	6	83	335	794	837	96	1	0	0	(13)
(14)	Wind	WSAvg	5.7	5.8	6.1	6.6	6.0	5.6	5.4	5.1	5.2	5.2	5.7	6.0	(14)	
(15)	Precipitation	PrecAvg	21.4	1.5	1.3	1.3	1.6	2.0	2.6	2.8	1.9	2.0	1.2	1.7	1.5	(15)
(16)		PrecMax	30.2	6.0	3.4	3.4	4.6	5.6	7.8	6.5	7.9	8.5	6.8	4.4	3.8	(16)
(17)		PrecMin	13.9	0.2	0.1	0.2	0.1	0.1	0.2	0.2	0.2	0.1	0.0	0.1	0.0	(17)
(18)		PrecStd	4.0	1.1	0.9	0.9	0.8	1.2	1.5	1.6	1.5	1.9	1.2	1.2	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.1	57.5	66.7	78.9	86.8	90.0	95.0	95.8	87.4	77.0	65.9	54.0	(19)
(20)			MCWB	42.9	47.2	51.5	58.8	63.5	67.3	67.9	67.8	63.1	62.8	56.2	48.1	(20)
(21)		2%	DB	45.8	51.4	61.2	72.2	81.9	86.6	91.0	91.5	82.4	71.5	60.3	50.1	(21)
(22)			MCWB	41.0	44.4	49.0	55.4	62.7	66.4	68.0	67.4	61.6	58.8	53.3	46.3	(22)
(23)		5%	DB	42.8	46.9	56.9	68.4	78.7	83.9	87.6	88.0	78.6	67.0	56.4	46.8	(23)
(24)			MCWB	39.4	42.0	46.3	53.4	61.3	65.8	67.3	66.4	61.1	57.2	51.7	43.8	(24)
(25)		10%	DB	40.1	43.3	52.7	64.8	75.0	81.2	84.5	84.8	74.8	63.2	53.5	43.3	(25)
(26)			MCWB	37.6	39.8	44.0	52.1	60.0	64.9	66.5	65.5	60.2	55.2	49.8	40.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.6	49.2	52.5	59.6	66.7	71.7	72.5	73.3	67.6	64.6	57.2	50.3	(27)
(28)			MCD B	47.9	56.4	64.2	75.5	80.3	83.3	85.2	86.9	78.2	74.7	62.5	52.5	(28)
(29)		2%	WB	41.9	45.2	49.7	57.0	64.7	69.1	70.9	70.6	65.4	61.1	54.5	46.7	(29)
(30)			MCD B	44.8	49.8	59.7	69.4	77.3	81.0	84.2	84.0	76.0	68.1	58.4	49.1	(30)
(31)		5%	WB	39.9	42.7	47.4	55.0	63.0	67.7	69.6	68.7	63.5	58.3	52.5	44.0	(31)
(32)			MCD B	42.3	46.3	55.4	65.6	74.7	79.6	82.3	82.2	73.3	64.9	56.2	46.9	(32)
(33)		10%	WB	37.8	40.1	45.1	53.0	61.2	66.4	68.3	67.2	61.6	56.1	50.1	40.9	(33)
(34)			MCD B	40.0	43.1	51.5	62.3	72.4	78.2	80.1	80.3	71.4	62.2	53.3	43.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	9.7	13.2	16.0	16.8	16.7	16.8	17.1	15.1	13.0	9.7	8.5	(35)
(36)			MCDBR	11.2	15.0	20.7	21.8	21.5	20.5	21.2	21.1	20.5	19.0	14.0	11.9	(36)
(37)			MCWBR	8.1	10.0	11.2	9.9	8.6	7.4	6.7	6.6	7.6	9.2	8.3	8.8	(37)
(38)		5% WB	MCD BR	9.9	14.1	19.3	19.8	19.6	18.0	18.0	18.6	17.4	17.0	12.5	11.4	(38)
(39)			MCWBR	7.8	10.0	11.0	9.8	8.5	7.6	7.2	6.9	8.2	9.2	8.0	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.322	0.352	0.385	0.443	0.415	0.411	0.440	0.445	0.405	0.370	0.348	0.322	(40)
(41)		taud		2.263	2.246	2.239	2.097	2.253	2.291	2.220	2.197	2.272	2.361	2.358	2.323	(41)
(42)		Ebn at Noon		235	253	263	257	270	271	261	254	253	245	226	222	(42)
(43)		Edh at Noon		25	32	37	47	42	41	43	42	36	28	23	22	(43)
(44)	All-Sky Solar Radiation	RadAvg		346	583	997	1454	1879	1982	1948	1767	1240	784	373	271	(44)
(45)		RadStd		64	93	92	127	162	150	125	106	147	86	49	56	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)	
		+1.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47)	Regional (21 neighbors)		+1.15	N/A	N/A	+1.31	N/A	N/A	N/A	-301	+187	+112	(47)

Nomenclature: See separate page