

CHISINAU INTL, Moldova, Republic of

WMO: 338387

Lat: 46.928N

Lon: 28.931E

Elev: 122

StdP: 99.87

Time Zone: 2.00 (MDA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-11.9	-18.8	0.7	-14.3	-15.8	1.0	-10.7	10.6	-1.7	9.6	-2.3	3.2	330	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	34.0	20.0	32.1	19.8	30.8	19.2	22.2	29.5	21.2	28.2	20.5	27.3	3.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	14.9	24.9	19.0	14.0	24.0	18.1	13.2	23.2	65.6	29.5	62.5	28.3	59.7	27.1	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.4	-18.3	36.2	3.7	1.7	-21.0	37.4	-23.2	38.5	-25.3	39.4	-28.0	40.7		
(5)			-18.6	23.5	3.7	1.2	-21.3	24.3	-23.5	25.0	-25.6	25.7	-28.2	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-2.1	-0.2	5.0	11.1	16.7	20.7	22.8	22.4	17.0	10.6	5.8	0.3		
	DBStd	9.66	5.35	5.51	4.77	3.75	3.53	3.21	2.83	3.14	3.68	4.40	4.64	4.94		
	HDD10.0	1342	374	284	163	29	1	0	0	0	1	47	142	301		
	HDD18.3	3118	632	518	413	218	73	14	2	4	67	242	377	558		
	CDD10.0	1677	0	0	9	63	210	320	398	385	211	65	16	1		
	CDD18.3	409	0	0	0	2	23	84	142	131	27	2	0	0		
	CDH23.3	4516	0	0	0	32	300	873	1484	1477	328	22	0	0		
	CDH26.7	1736	0	0	0	7	76	297	617	642	95	2	0	0		
(14) Wind	WSAvg	3.4	3.5	3.7	4.0	3.6	3.3	3.3	3.1	2.9	3.0	3.1	3.5	3.5		
(15) Precipitation	PrecAvg	525	33	29	30	39	57	65	52	51	43	47	36	43		
	PrecMax	661	73	63	67	64	176	130	126	119	137	165	92	121		
	PrecMin	344	5	7	5	6	10	17	6	18	2	11	1	3		
	PrecStd	95	19	16	16	15	36	30	26	28	34	36	26	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	14.2	20.2	27.2	31.1	33.8	36.1	36.8	32.1	26.0	20.0	13.2		
		MCWB	6.8	9.7	11.5	15.7	17.5	20.2	19.6	20.2	18.6	16.6	14.2	9.6		
	2%	DB	8.0	11.1	17.8	23.1	28.9	31.2	34.0	34.1	29.2	23.0	16.8	10.9		
		MCWB	5.9	7.1	10.3	13.9	17.4	19.7	20.2	20.0	17.1	15.3	12.5	8.6		
	5%	DB	6.1	8.8	14.9	21.0	26.9	30.0	32.0	32.1	27.0	20.2	14.2	9.0		
		MCWB	4.5	6.3	8.7	12.6	16.6	19.4	20.1	19.7	16.6	14.2	11.4	7.5		
	10%	DB	4.8	6.8	12.2	19.0	24.8	28.1	30.1	30.2	24.9	17.9	12.8	6.9		
		MCWB	3.6	5.1	7.1	11.6	16.0	18.4	19.6	19.0	16.0	13.1	10.6	5.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	10.4	12.2	16.0	20.1	23.4	23.3	23.2	20.0	18.2	14.8	10.8		
		MCDB	9.3	13.9	18.9	24.0	26.3	29.6	30.7	31.5	28.0	24.3	18.1	12.3		
	2%	WB	6.0	7.8	10.6	14.9	18.7	21.6	22.2	22.0	18.7	16.4	13.2	8.9		
		MCDB	7.4	10.0	16.5	21.8	25.7	28.0	29.5	29.7	25.7	20.9	15.8	10.1		
	5%	WB	4.7	6.3	9.3	13.5	17.6	20.7	21.3	20.9	17.7	15.0	12.0	7.3		
		MCDB	5.7	8.0	14.2	19.3	24.3	27.0	28.3	28.3	24.1	19.1	14.3	8.8		
	10%	WB	3.3	4.9	7.9	12.3	16.6	19.7	20.6	20.0	16.8	13.8	10.7	5.4		
		MCDB	4.4	6.5	11.1	17.6	23.0	25.7	27.4	27.3	22.8	17.4	12.5	6.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.6	9.5	11.4	12.3	11.8	12.2	12.9	11.7	10.1	6.8	6.1		
		MCDBR	7.5	10.1	14.1	15.3	15.5	14.3	14.9	15.8	15.8	14.1	9.6	8.5		
	5% WB	MCWBR	5.6	6.9	7.9	7.6	6.4	5.5	4.9	5.1	6.2	7.5	6.1	6.3		
		MCWBR	6.8	9.0	12.7	13.5	13.3	12.1	12.3	13.1	12.9	12.3	8.4	8.0		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.356	0.390	0.450	0.421	0.417	0.446	0.452	0.411	0.374	0.352	0.325		
		taud	2.257	2.237	2.226	2.077	2.237	2.279	2.206	2.181	2.257	2.350	2.349	2.317		
	Ebn at Noon		738	794	824	804	846	850	817	794	793	767	707	696		
		Edh at Noon	81	101	119	152	134	129	138	136	115	90	74	69		
(44) All-Sky Solar Radiation	RadAvg		1.10	1.84	3.15	4.59	5.93	6.26	6.15	5.58	3.92	2.48	1.19	0.86		
	RadStd		0.20	0.29	0.29	0.40	0.51	0.47	0.39	0.33	0.46	0.27	0.16	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+120	+70
(47) Regional (23 neighbors)		+0.65	N/A	N/A	+0.77	N/A	N/A	-116	-167	+106	+63

Nomenclature: See separate page